



November 28, 2016:

Dear Troy High School Families and Staff:

Water quality testing for lead has been completed at all District schools in compliance with New York State legislation enacted in September. All five elementary schools were tested by the deadline of September 30 and Troy Middle School and Troy High School were tested by their deadline of October 31.

The District tested 868 water outlets for lead, including all drinking fountains, sinks and ice machines in each of our buildings. The sample and analysis is conducted by a certified water testing agency. Complete lab results for each building can be found on our website at [www.troycsd.org/watertesting](http://www.troycsd.org/watertesting).

Of the 331 samples drawn in Troy High School, 64 tested above the allowable 15 micrograms of lead per liter (mcg/L) as per the new regulations. We have isolated those faucets immediately to prevent consumption until we have the opportunity to investigate further. Those 64 faucets are identified on Pages 2-3 of this letter.

We also tested five samples at the Pickens Athletic Building; all tested negative.

In addition to sharing our test results with parents, guardians and staff, we also shared all data with the Rensselaer County Department of Health and Questar III's Health & Safety Service.

At Troy City School District, we are committed to providing a safe and healthy environment for students and staff. Please be assured that we will continue to take the necessary steps to ensure that the quality of our drinking water meets the new state regulations.

Please feel free to contact the Business Office at 518-328-5005 with any questions or concerns.

Sincerely,

John Carmello  
Superintendent of Schools

<b>Date Sampled</b>	<b>Building</b>	<b>Location</b>	<b>Outlet</b>	<b>Results</b>
Oct. 13, 2016	Troy High School	Pool	Water Fountain	15.9 mcg/L
Oct. 13, 2016	Troy High School	Maintenance Tunnel	Sink 2	24.5 mcg/L
Oct. 13, 2016	Troy High School	Rm 126/124	Sink 2	108 mcg/L
Oct. 13, 2016	Troy High School	Rm 126/124	Sink 3	15.4 mcg/L
Oct. 13, 2016	Troy High School	Rm 126/124	Sink 4	16.9 mcg/L
Oct. 13, 2016	Troy High School	Rm 126/124	Sink 5	264 mcg/L
Oct. 13, 2016	Troy High School	Rm 126/124	Sink 6	23.8 mcg/L
Oct. 13, 2016	Troy High School	Rm 123/122	Sink 1	103 mcg/L
Oct. 13, 2016	Troy High School	Rm 123/122	Sink 4	15.2 mcg/L
Oct. 13, 2016	Troy High School	Rm 123/122	Sink 5	19 mcg/L
Oct. 13, 2016	Troy High School	Rm 123/122	Sink 6	33.2 mcg/L
Oct. 13, 2016	Troy High School	Rm 014A Bathroom	Sink	44.8 mcg/L
Oct. 13, 2016	Troy High School	Rm 13	Sink 4	31.4 mcg/L
Oct. 13, 2016	Troy High School	Rm 13	Sink 6	18.2 mcg/L
Oct. 13, 2016	Troy High School	Rm 4	Sink 1	462 mcg/L
Oct. 13, 2016	Troy High School	Rm 4	Sink 4	19.7 mcg/L
Oct. 13, 2016	Troy High School	Rm 4	Sink 5	84.4 mcg/L
Oct. 13, 2016	Troy High School	Rm 221	Sink 3	15.7 mcg/L
Oct. 13, 2016	Troy High School	Rm 221	Sink 5	16.1 mcg/L
Oct. 13, 2016	Troy High School	Rm 221	Sink 8	16 mcg/L
Oct. 13, 2016	Troy High School	Rm 221	Sink 9	16.5 mcg/L
Oct. 13, 2016	Troy High School	Rm 224	Sink 3	25.9 mcg/L
Oct. 13, 2016	Troy High School	Rm 226	Sink 4	20.6 mcg/L
Oct. 13, 2016	Troy High School	Rm 226	Sink 5	20.2 mcg/L
Oct. 13, 2016	Troy High School	Rm 226	Sink 7	30.1 mcg/L
Oct. 13, 2016	Troy High School	Rm 226	Sink 8	31.4 mcg/L
Oct. 13, 2016	Troy High School	Rm 328	Sink 1	24.5 mcg/L
Oct. 13, 2016	Troy High School	Rm 328	Sink 2	39.7 mcg/L
Oct. 13, 2016	Troy High School	Rm 328	Sink 3	62.3 mcg/L
Oct. 13, 2016	Troy High School	Rm 328	Sink 4	35.3 mcg/L
Oct. 13, 2016	Troy High School	Rm 328	Sink 5	89 mcg/L
Oct. 13, 2016	Troy High School	Rm 328	Sink 6	19.5 mcg/L
Oct. 13, 2016	Troy High School	Rm 328	Sink 7	51.5 mcg/L
Oct. 13, 2016	Troy High School	Rm 328	Sink 9	20.2 mcg/L
Oct. 13, 2016	Troy High School	Rm 328	Sink 10	74.8 mcg/L
Oct. 13, 2016	Troy High School	Rm 328	Sink 11	29.6 mcg/L
Oct. 13, 2016	Troy High School	Rm 328	Sink 12	33.9 mcg/L
Oct. 13, 2016	Troy High School	Rm 328	Sink 13	45.4 mcg/L
Oct. 13, 2016	Troy High School	Rm 328	Sink 17	33.8 mcg/L
Oct. 13, 2016	Troy High School	Rm 328	Sink 19	29.1 mcg/L
Oct. 13, 2016	Troy High School	Rm 328	Sink 20	15.9 mcg/L
Oct. 13, 2016	Troy High School	Rm 328	Sink 23	93.9 mcg/L
Oct. 13, 2016	Troy High School	Rm 328	Sink 24	191 mcg/L
Oct. 13, 2016	Troy High School	Rm 328	Sink 25	1010 mcg/L

<b>Date Sampled</b>	<b>Building</b>	<b>Location</b>	<b>Outlet</b>	<b>Results</b>
Oct. 13, 2016	Troy High School	Rm 326	Sink 1	21.3 mcg/L
Oct. 13, 2016	Troy High School	Rm 326	Sink 2	29.4 mcg/L
Oct. 13, 2016	Troy High School	Rm 326	Sink 3	85.2 mcg/L
Oct. 13, 2016	Troy High School	Rm 326	Sink 4	23.9 mcg/L
Oct. 13, 2016	Troy High School	Rm 326	Sink 5	15.6
Oct. 13, 2016	Troy High School	Rm 326	Sink 6	20.3
Oct. 13, 2016	Troy High School	Rm 326	Sink 7	17.9
Oct. 13, 2016	Troy High School	Rm 326	Sink 9	32.9
Oct. 13, 2016	Troy High School	Rm 326	Sink 16	20.9
Oct. 13, 2016	Troy High School	Rm 326	Sink 21	919
Oct. 13, 2016	Troy High School	Rm 326	Sink 23	520
Oct. 13, 2016	Troy High School	Rm 326	Sink 24	29.8
Oct. 13, 2016	Troy High School	Rm 325 prep	Sink	52.2
Oct. 13, 2016	Troy High School	Rm 323	Sink 11	17.2
Oct. 13, 2016	Troy High School	Rm 323	Sink 19	17.2
Oct. 13, 2016	Troy High School	Rm 323	Sink 24	77.5
Oct. 13, 2016	Troy High School	Rm 323	Sink 25	689
Oct. 13, 2016	Troy High School	Rm 351	Sink	1240
Oct. 13, 2016	Troy High School	Rm 364	Sink 4	35.7
Oct. 13, 2016	Troy High School	Rm 364	Sink 5	38.4