

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

CLIENT INFORMATION

Appendix D

Name:	Enlarged City School District of Troy
Address:	475 First Street Troy NY 12180
Client Rep:	Guy Gardner

Date of Sampling:	9/28/2016	3/15/2018
Samples Taken By:	Tim LeVan	Steve Warner
Samples Taken By:	Paul Swieton	

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Carroll Hill Elementary
BLDG ADDRESS:	112 Delaware Ave Troy NY 12180
CONTACT NAME & NUMBERS:	Guy Gardner 518 328-5426

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information							
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	Initial test Result Lead	Retest Result 2/8/17	Retest lead mg/L result 3/2018	Remediation
123	CHE-01-BF-P-123	Principal Bathroom	Sink			X	4:45	6.45			
124	CHE-01-CF-P-124	Rm 7	Sink			X	4:46	9.18			
125	CHE-01-DW-P-125	Rm 7	Water fountain			X	4:46	50.4		0.006	
126	CHE-01-CF-P-126	Rm 6	Sink			X	4:47	8.09			
127	CHE-01-DW-P-127	Rm 6	Water fountain			X	4:47	8.37			
128	CHE-01-NF1-P-128	Nurses office	Sink 1			X	4:54	11.6			
129	CHE-01-NF2-P-129	Nurses office	Sink 2			X	4:54	2.74			
130	CHE-01-NF3-P-130	Nurses office	Sink 3			X	4:54	5.29			
131	CHE-01-CF-P-131	Rm 5	Sink			X	4:56	2.48			
132	CHE-01-DW-P-132	Rm 5	Water fountain			X	4:56	8.58			
133	CHE-01-CF-P-133	Rm 4	Sink			X	5:01	2.56			
134	CHE-01-DW-P-134	Rm 4	Water fountain			X	5:01	4.64			
135	CHE-01-BF-P-135	Womens room	Sink			X	5:02	1.11			
136	CHE-01-CF-P-136	Rm 3	Sink			X	5:03	3.22			
137	CHE-01-DW-P-137	Rm 3	Water fountain			X	5:03	6.42			
138	CHE-01-BF-P-138	Mens room	Sink			X	5:04	1.79			
139	CHE-01-CF-P-139	Rm 2	Sink			X	5:05	4.4			
140	CHE-01-DW-P-140	Rm 2	Water fountain			X	5:05	4.55			
141	CHE-01-CF-P-141	Prep room	Sink			X	5:06	2.09			
142	CHE-01-FS-P-142	Faculty lounge	Sink			X	5:10	2.6			
143	CHE-01-CF-P-143	Rm 1	Sink			X	5:11	4.94			
144	CHE-01-DW-P-144	Rm 1	Water fountain			X	5:11	4.44			
145	CHE-01-KF1-P-145	Kitchen	Sink 1			X	5:13	1.33			
146	CHE-01-KF2-P-146	Kitchen	Sink 2			X	5:13	4.06			
147	CHE-01-DW-P-147	Lobby	Water fountain			X	5:17	ND			

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab:	CNA Environmental St. Peters environmental Lab
Contact:	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	

CLIENT INFORMATION

Name:	Enlarged City School District of Troy
Address:	475 First Street Troy NY 12180
Client Rep:	Guy Gardner

Date of Sampling:	9/28/2016	3/15/2018
Samples Taken By:	Tim LeVan	Steve Warner
Samples Taken By:	Paul Swieton	

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Carroll Hill Elementary
BLDG ADDRESS:	112 Delaware Ave Troy NY 12180
CONTACT NAME & NUMBERS:	Guy Gardner 518 328-5426

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information							
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	Initial Test Result Lead	Re-test Result 2/8/17	Retest lead mg/L result 3/2018	Remediation
148	CHE-01-CF-P-148	Rm 8	Sink			X	5:18	8.98			
149	CHE-01-DW-P-149	Rm 8	Water fountain			X	5:18	4.14			
150	CHE-01-CF-P-150	Rm 9	Sink			X	5:20	0.95			
151	CHE-01-CF-P-151	Library office	Sink			X	5:28	497		0.001	
152	CHE-01-BF1-P-152	Girls room	Sink 1			X	5:23	0.83			
153	CHE-01-BF2-P-153	Girls room	Sink 2			X	5:23	0.67			
154	CHE-01-CF-P-154	Rm 10	Sink			X	5:24	13.8			
155	CHE-01-DW-P-155	Rm 10	Water fountain			X	5:24	7.01			
156	CHE-01-BF1-P-156	Boys room	Sink 1			X	5:25	ND			
157	CHE-01-BF2-P-157	Boys room	Sink 2			X	5:25	ND			
158	CHE-01-CF-P-158	Library office	Sink			X	5:28	17.3		0.002	
159	CHE-01-CF-P-159	Rm 11	Sink			X	5:29	13.2			
160	CHE-01-DW-P-160	Rm 11	Water fountain			X	5:29	8.48			
161	CHE-01-CF-P-161	Rm 12	Sink			X	5:31	8.41			
162	CHE-01-DW-P-162	Rm 12	Sink			X	5:31	8.81			
163	CHE-01-BF1-P-163	Girls room	Sink 1			X	5:38	ND			
164	CHE-01-BF2-P-164	Girls room	Sink 2			X	5:38	ND			
165	CHE-01-BF1-P-165	Boys room	Sink 1			X	5:39	ND			
166	CHE-01-BF2-P-166	Boys room	Sink 2			X	5:39	ND			
167	CHE-01-CF-P-167	Rm 13	Sink			X	5:44	1.32			
168	CHE-01-DW-P-168	Rm 13	Water fountain			X	Not	In service	34	0.004	
169	CHE-01-CF-P-169	Rm 14	Sink			X	5:45	3.12			
170	CHE-01-DW-P-170	Rm 14	Water fountain			X	5:45	0.8			
171	CHE-01-CF-P-171	Rm 15	Sink			X	5:47	1.41			
172	CHE-01-DW-P-172	Rm 15	Water fountain			X	6:05	24.5		<0.001	

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab:	CNA Environmental St. Peters Environmental Lab
Contact:	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	

CLIENT INFORMATION

Name:	Enlarged City School District of Troy
Address:	475 First Street Troy NY 12180
Client Rep:	Guy Gardner

Date of Sampling:	9/28/2016	3/15/2018
Samples Taken By:	Tim LeVan	Steve Warner
Samples Taken By:	Paul Swieton	

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Carroll Hill Elementary
BLDG ADDRESS:	112 Delaware Ave Troy NY 12180
CONTACT NAME & NUMBERS:	Guy Gardner 518 328-5426

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information						
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	Initial test Result Lead	Retest Result 2/8/17	Remediation
173	CHE-01-CF-P-173	Rm 16	Sink			X	5:48	1.23		
174	CHE-01-DW-P-174	Rm 16	Water fountain			X	Out	Of Service	1	
175	CHE-01-CF-P-175	Rm 17	Sink			X	5:50	0.68		
176	CHE-01-DW-P-176	Rm 17	Water fountain			X	5:50	ND		
177	CHE-01-CF-P-177	Rm 18	Sink			X	5:51	1.76		
178	CHE-01-DW-P-178	Rm 18	Water fountain			X	5:51	1.53		
179	CHE-01-DW-P-179	Corridor	Water fountain			X	Duplicated	Not	Sampled	See 166A
180	CHE-01-BF1-P-180	Boys room	Sink 1			X	5:54	0.61		
181	CHE-01-BF2-P-181	Boys room	Sink 2			X	5:54	ND		
182	CHE-01-BF1-P-182	Girls room	Sink 1			X	5:55	ND		
183	CHE-01-BF2-P-183	Girls room	Sink 2			X	5:55	ND		
184	CHE-02-BF1-P-184	Girls room	Sink 1			X	5:57	ND		
185	CHE-02-BF2-P-185	Girls room	Sink 2			X	5:57	ND		
186	CHE-02-BF1-P-186	Boys room	Sink 1			X	6:00	2.3		
187	CHE-02-BF2-P-187	Boys room	Sink 2			X	6:05	2.44		
188	CHE-02-CF-P-188	Rm 24	Sink			X	6:01	3.21		
189	CHE-02-DW-P-189	Rm 24	Water fountain			X	6:01	0.82		
190	CHE-02-CF-P-190	Rm 23	Sink			X	6:02	1.88		
191	CHE-02-DW-P-191	Rm 23	Water fountain			X	6:02	1.22		
192	CHE-02-CF-P-192	Rm 22	Sink			X	6:07	1.24		
193	CHE-02-DW-P-193	Rm 22	Water fountain			X	6:07	1.98		
194	CHE-02-BF-P-194	Mens room	Sink			X	6:09	2.9		
195	CHE-02-CF-P-195	Rm 21	Sink			X	6:09	2.32		
196	CHE-02-DW-P-196	Rm 21	Water fountain			X	6:09	2.36		
197	CHE-02-BF-P-197	Womens room	Sink			X	6:11	6.07		

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab:	CNA Environmental St. Peters Environmental Lab
Contact:	
Comments:	Provide Laboratory Data Report (LDR) and Chain of Custody

