

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM Page 1 of 4

CLIENT INFORMATION

Appendix D

Name:	Enlarged City School District of Troy
Address:	475 First Street Troy NY 12180
Client Rep:	Bob Garland

Date of Sampling:	9/27/2016	3/9/2018	5/9/2018
Samples Taken By:	Craig Hansen	Steve Warner	Steve Warner
Samples Taken By:	Tim LeVan		

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	PS12
BLDG ADDRESS:	475 First Street Troy NY 12180
CONTACT NAME & NUMBERS:	Bob Garland 518-328-5426

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information							
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	initial test result Lead	Retest lead mg/L result 3/2018	Retest lead mg/L result 5/2018	Remediation
309	PS12-01-CF-P-309	117	Sink			X	4:46	6.4			
310	PS12-01-DW-P-310	117	Water fountain			X	4:46	5.73			
311	PS12-01-CF-P-311	118	Sink			X	4:50	3.9			
312	PS12-01-DW-P-312	118	Water fountain			X	4:50	3.37			
313	PS12-01-KF1-P-313	Kitchen	Sink 1			X	4:52	8.06			
314	PS12-01-KF2-P-314	Kitchen	Sink 2			X	4:52	5.63			
315	PS12-01-KF3-P-315	Kitchen	Sink 3			X	4:53	4.22			
316	PS12-01-CF-P-316	119	Sink			X	4:55	1.69			
317	PS12-01-DW-P-317	119	Water fountain			X	4:55	2.02			
318	PS12-01-CF-P-318	114	Sink			X	4:55	9.34			
319	PS12-01-DW-P-319	114	Water fountain			X	4:55	2.98			
320	PS12-01-CF-P-320	113	Sink			X	4:58	5.92			
321	PS12-01-DW-P-321	113	Water fountain			X	4:58	3.62			
322	PS12-01-BF-P-322	Girls room	Sink 1			X	5:01	8.31			
323	PS12-01-BF-P-323	Girls room	Sink 2			X	5:01	10.6			
324	PS12-01-BF-P-324	Boys room	Sink			X	5:02	2.1			
325	PS12-01-CF-P-325	123	Sink			X	5:02	9			
326	PS12-01-DW-P-326	123	Water fountain			X	5:03	6.93			
327	PS12-01-BF-P-327	Girls room	Sink 1			X	5:06	0.57			
328	PS12-02-BF-P-328	Girls room	Sink 2			X	5:06	0.51			
329	PS12-03-BF-P-329	Girls room	Sink 3			X	5:06	0.75			
330	PS12-04-BF-P-330	Girls room	Sink 4			X	5:06	1.11			
331	PS12-01-DW-P-331	Corridor	Water fountain			X	5:08	0.62			
332	PS12-01-BF-P-332	Main office bathroom	Sink			X	5:10	6.06			
333	PS12-B-BF-P-333	Girls locker room	Sink			X	5:15	17.2	<0.001		

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab:	CNA Environmental initial testing St. Peter's Environmental Lab Retest
Contact:	
Comments:	Provide Laboratory Data Report (LDR) and Chain of Custody

CLIENT INFORMATION

Name:	Enlarged City School District of Troy
Address:	475 First Street Troy NY 12180
Client Rep:	Bob Garland

Date of Sampling:	9/27/2016	3/9/2018	5/9/2018
Samples Taken By:	Craig Hansen	Steve Warner	Steve Warner
Samples Taken By:	Tim LeVan		

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	PS12
BLDG ADDRESS:	475 First Street Troy NY 12180
CONTACT NAME & NUMBERS:	Bob Garland 518-328-5426

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information							
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	initial Lead test result	Retest lead mg/L result 3/2018	Retest lead mg/L result 5/2018	Remediation
334	PS12-B-DW-P-334	Girls locker room	Water fountain			X	5:16	61.9	0.002		
335	PS12-01-DW-P-335	126 weight room	Water fountain			X	6:17	9			
336	PS12-01-BF-P-336	Weight room bathroom	Sink			X	5:19	8.58			
337	PS12-01-BF-P-337	Custodians office	Sink			X	5:21	6.8			
338	PS12-01-BF-P-338	Boys locker room	Sink			X	5:23	1.16			
339	PS12-01-DW-P-339	Boys locker room	Water fountain			X	5:23	1.33			
340	PS12-01-DW-P-340	Corridor	Water fountain			X	6:20	3			
341	PS12-01-BF1-P-341	Boys room	Sink 1			X	6:21	3			
342	PS12-01-BF2-P-342	Boys room	Sink 2			X	6:21	2			
343	PS12-01-BF3-P-343	Boys room	Sink 3			X	5:26	ND			
344	PS12-02-BF1-P-344	Boys room	Sink 1			X	5:34	0.85			
345	PS12-02-BF2-P-345	Boys room	Sink 2			X	5:34	0.8			
346	PS12-02-BF3-P-346	Boys room	Sink 3			X	5:34	9.73			
347	PS12-02-DW-P-347	Corridor	Water fountain			X	5:34	0.53			
348	PS12-02-BF-P-348	209 Bathroom	Sink			X	5:37	11.6			
349	PS12-02-CF-P-349	210	Sink			X	5:38	2.85			
350	PS12-02-BF-P-350	211 bathroom	Sink			X	5:40	6.18			
351	PS12-02-DW-P-351	Corridor	Water fountain			X	5:41	0.84			
352	PS12-02-BF1-P-352	Girls room	Sink 1			X	5:40	0.76			
353	PS12-02-BF2-P-353	Girls room	Sink 2			X	5:42	0.91			
354	PS12-02-BF3-P-354	Girls room	Sink 2			X	5:42	0.62			
355	PS12-02-BF4-P-355	Girls room	Sink 4			X	5:42	0.64			
356	PS12-02-DW-P-356	Corridor	Water fountain			X	6:27	72	0.015		
357	PS12-02-BF-P-357	Bathroom gang sink	Sink 1			X	5:45	1.9			
358	PS12-02-BF-P-358	Bathroom gang sink	Sink 2			X	5:45	1.14			

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab:	CNA Environmental initial sampling St. Peter's Environmental Lab Retest
Contact:	
Comments:	Provide Laboratory Data Report (LDR) and Chain of Custody

CLIENT INFORMATION

Name:	Enlarged City School District of Troy
Address:	475 First Street Troy NY 12180
Client Rep:	Bob Garland

Date of Sampling:	9/27/2016	3/9/2018	5/9/2018
Samples Taken By:	Craig Hansen	Steve Warner	Steve Warner
Samples Taken By:	Tim LeVan		

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	PS12
BLDG ADDRESS:	475 First Street Troy NY 12180
CONTACT NAME & NUMBERS:	Bob Garland 518-328-5426

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information							
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	Lead	Retest lead mg/L result 3/2018	Retest lead mg/L result 5/2018	Remediation
359	PS12-02-CF-P-359	223	Sink			X	5:47	25.4	0.001		
360	PS12-02-DW-P-360	223	Water fountain			X	5:47	21.5	<0.001		
361	PS12-02-CF-P-361	216	Sink			X	5:48	17.2	0.002		
362	PS12-02-DW-P-362	216	Water fountain			X	5:48	26.5	0.001		
363	PS12-02-CF-P-363	222	Sink			X	6:00	21.3	0.006		
364	PS12-02-DW-P-364	222	Water fountain			X	6:00	9.67			
365	PS12-02-CF-P-365	217	Sink			X	6:01	29.2	0.002		
366	PS12-02-DW-P-366	217	Water fountain			X	6:01	6.09			
367	PS12-02-CF-P-367	218	Sink			X	6:02	22.2	0.002		
368	PS12-02-DW-P-368	218	Water fountain			X	6:02	10.9			
369	PS12-02-CF-P-369	221	Sink			X	6:04	20.9	0.0-01		
370	PS12-02-DW-P-370	221	Water fountain			X	6:04	5.95			
371	PS12-02-CF-P-371	219	Sink			X	6:06	15.3			Removed
372	PS12-02-DW-P-372	219	Water fountain			X	6:28	38			Removed
373	PS12-02-CF-P-373	220	Sink			X	6:07	24.6	<0.001		
374	PS12-02-DW-P-374	220	Water fountain			X	6:09	8.03			
375	PS12-03-OF-P-375	320	Sink			X	6:14	13.9	<0.001		
376	PS12-03-DW-P-376	320	Water fountain			X	6:14	8.45	<0.001		
377	PS12-03-OF-P-377	319	Sink			X	6:17	163	<0.001		
378	PS12-03-DW-P-378	319	Water fountain			X	6:31	29	<0.001		
379	PS12-03-OF-P-379	321	Sink			X	6:18	13.6			
380	PS12-03-DW-P-380	321	Water fountain			X	6:18	28.4	0.002		
381	PS12-03-OF-P-381	318	Sink			X	6:20	22.6	<0.001		
382	PS12-03-DW-P-382	318	Water fountain			X	6:20	15.3	<0.001		
383	PS12-03-OF-P-383	317	Sink			X	6:22	19.7	0.002		

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO₃@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab:	CNA Environmental Initial testing St. Peter's Environmental Lab Retest
Contact:	
Comments:	Provide Laboratory Data Report (LDR) and Chain of Custody

CLIENT INFORMATION

Name:	Enlarged City School District of Troy
Address:	475 First Street Troy NY 12180
Client Rep:	Bob Garland

Date of Sampling:	9/27/2016	3/9/2018	5/9/2018
Samples Taken By:	Craig Hansen	Steve Warner	Steve Warner
Samples Taken By:	Tim LeVan		

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	PS12
BLDG ADDRESS:	475 First Street Troy NY 12180
CONTACT NAME & NUMBERS:	Bob Garland 518-328-5426

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information							
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	Initial Lead test result	Retest lead mg/L result 3/2018	Retest lead mg/L result 5/2018	Remediation
384	PS12-03-DW-P-384	317	Water fountain			X	6:22	26.9	0.001		
385	PS12-03-OF-P-385	322	Sink			X	6:25	31.7	0.002		
386	PS12-03-DW-P-386	322	Water fountain			X	6:25	34.4	0.002		
387	PS12-03-OF-P-387	316	Sink			X	6:26	16.6	0.001		
388	PS12-03-DW-P-388	316	Water fountain			X	6:26	14.5			
389	PS12-03-OF-P-389	323	Sink			X	6:27	62.8	<0.001		
390	PS12-03-DW-P-390	323	Water fountain			X	6:27	27.4	0.002		
391	PS12-03-BF1-P-391	Corridor	Gang sink 1			X	6:28	3.55			
392	PS12-03-BF2-P-392	Corridor	Gang sink 2			X	6:28	3.55			
393	PS12-03-BF1-P-393	Girls room	Sink 1			X	6:32	0.84			
394	PS12-03-BF2-P-394	Girls room	Sink 2			X	6:32	0.62			
395	PS12-03-BF3-P-395	Girls room	Sink 3			X	6:32	ND			
396	PS12-03-BF4-P-396	Girls room	Sink 4			X	6:32	1.73			
397	PS12-03-DW-P-397	Corridor	Water fountain			X	6:33	1.47			
398	PS12-03-BF-P-398	Mens room	Sink			X	6:35	10.8			
399	PS12-03-SF-P-399	Faculty room	Sink			X	6:36	5.87			
400	PS12-03-BF-P-400	Womens room	Sink			X	6:37	11.5			
401	PS12-03-DW-P-401	Corridor	Water fountain			X	6:38	2.23			
402	PS12-03-BF1-P-402	Boys room	Sink 1			X	6:40	0.75			
403	PS12-03-BF2-P-403	Boys room	Sink 2			X	6:40	0.8			
404	PS12-03-BF3-P-404	Boys room	Sink 3			X	6:40	0.53			
342A	PS12-01-CF-P-342A	Receiving	Sink			X	6:24	5			
389A	PS12-03-DW-P-389A	Corridor	Water fountain			X	6:35	28	0.024	0.005	
405	PS12-01-DW-P-405	cafeteria	Water fountain			X	6:27		<0.001		Newly installed

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab:	CNA Environmental Initial testing St. Peter's Lab Retesting
Contact:	
Comments:	Provide Laboratory Data Report (LDR) and Chain of Custody