

November 16, 2020

Paul Swieton  
Rensselaer-Columbia-Greene Counties and  
BOCES  
10 Empire State Blvd.  
Fl 2  
Castleton On Hudson, NY 12033

RE: Project: ENLARGED CITY SCHOOL 11/4  
Pace Project No.: 70152944

Dear Paul Swieton:

Enclosed are the analytical results for sample(s) received by the laboratory on November 10, 2020. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Ormond Beach

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Rebeka K. Smith for  
Nicolette M. Lovari  
nicolette.lovvari@pacelabs.com  
(631)694-3040  
Project Manager

Enclosures

cc: Robert Garland, Troy City SD



## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## CERTIFICATIONS

Project: ENLARGED CITY SCHOOL 11/4  
Pace Project No.: 70152944

---

### **Pace Analytical Services Ormond Beach**

8 East Tower Circle, Ormond Beach, FL 32174  
Alaska DEC- CS/UST/LUST  
Alabama Certification #: 41320  
Arizona Certification# AZ0819  
Colorado Certification: FL NELAC Reciprocity  
Connecticut Certification #: PH-0216  
Delaware Certification: FL NELAC Reciprocity  
Florida Certification #: E83079  
Georgia Certification #: 955  
Guam Certification: FL NELAC Reciprocity  
Hawaii Certification: FL NELAC Reciprocity  
Illinois Certification #: 200068  
Indiana Certification: FL NELAC Reciprocity  
Kansas Certification #: E-10383  
Kentucky Certification #: 90050  
Louisiana Certification #: FL NELAC Reciprocity  
Louisiana Environmental Certificate #: 05007  
Maryland Certification: #346  
Michigan Certification #: 9911  
Mississippi Certification: FL NELAC Reciprocity  
Missouri Certification #: 236

Montana Certification #: Cert 0074  
Nebraska Certification: NE-OS-28-14  
New Hampshire Certification #: 2958  
New Jersey Certification #: FL022  
New York Certification #: 11608  
North Carolina Environmental Certificate #: 667  
North Carolina Certification #: 12710  
North Dakota Certification #: R-216  
Ohio DEP 87780  
Oklahoma Certification #: D9947  
Pennsylvania Certification #: 68-00547  
Puerto Rico Certification #: FL01264  
South Carolina Certification: #96042001  
Tennessee Certification #: TN02974  
Texas Certification: FL NELAC Reciprocity  
US Virgin Islands Certification: FL NELAC Reciprocity  
Virginia Environmental Certification #: 460165  
West Virginia Certification #: 9962C  
Wisconsin Certification #: 399079670  
Wyoming (EPA Region 8): FL NELAC Reciprocity

---

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### SAMPLE ANALYTE COUNT

Project: ENLARGED CITY SCHOOL 11/4  
Pace Project No.: 70152944

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
70152944001	PS18-B-BF-P-200	EPA 200.8	SLG	1	PASI-O
70152944002	PS18-01-BF1-P-201	EPA 200.8	SLG	1	PASI-O
70152944003	PS18-01-BF2-P-202	EPA 200.8	SLG	1	PASI-O
70152944004	PS18-01-BF3-P-203	EPA 200.8	SLG	1	PASI-O
70152944005	PS18-01-DW-P-204	EPA 200.8	SLG	1	PASI-O
70152944006	PS18-01-KF-P-206	EPA 200.8	SLG	1	PASI-O
70152944007	PS18-B-BF-P-207	EPA 200.8	SLG	1	PASI-O
70152944008	PS18-01-BF1-P-208	EPA 200.8	SLG	1	PASI-O
70152944009	PS18-01-BF2-P-209	EPA 200.8	SLG	1	PASI-O
70152944010	PS18-01-BF3-P-210	EPA 200.8	SLG	1	PASI-O
70152944011	PS18-02-DW-P-211	EPA 200.8	SLG	1	PASI-O
70152944012	PS18-02-BF1-P-212	EPA 200.8	SLG	1	PASI-O
70152944013	PS18-02-BF2-P-213	EPA 200.8	SLG	1	PASI-O
70152944014	PS18-02-BF-P-215	EPA 200.8	SLG	1	PASI-O
70152944015	PS18-02-BF1-P-216	EPA 200.8	SLG	1	PASI-O
70152944016	PS18-02-BF2-P-217	EPA 200.8	SLG	1	PASI-O
70152944017	PS18-02-BF3-P-218	EPA 200.8	SLG	1	PASI-O
70152944018	PS18-02-DW-P-219	EPA 200.8	SLG	1	PASI-O
70152944019	PS18-02-BF-P-220	EPA 200.8	SLG	1	PASI-O
70152944020	PS18-02-BF-P-221	EPA 200.8	SLG	1	PASI-O
70152944021	PS18-03-DW-P-222	EPA 200.8	SLG	1	PASI-O
70152944022	PS18-03-BF1-P-223	EPA 200.8	SLG	1	PASI-O
70152944023	PS18-03-BF2-P-224	EPA 200.8	SLG	1	PASI-O
70152944024	PS18-03-BF3-P-225	EPA 200.8	AMS	1	PASI-O
70152944025	PS18-03-BF-P-226	EPA 200.8	AMS	1	PASI-O
70152944026	PS18-03-BF1-P-227	EPA 200.8	AMS	1	PASI-O
70152944027	PS18-03-BF2-P-228	EPA 200.8	AMS	1	PASI-O
70152944028	PS18-03-BF3-P-229	EPA 200.8	AMS	1	PASI-O
70152944029	PS18-03-DW-P-230	EPA 200.8	AMS	1	PASI-O
70152944030	PS18-01-SF-P-231	EPA 200.8	AMS	1	PASI-O
70152944031	PS18-01-DW-P-231A	EPA 200.8	AMS	1	PASI-O
70152944032	PS18-01-SF-P-231B	EPA 200.8	AMS	1	PASI-O

PASI-O = Pace Analytical Services - Ormond Beach

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

Sample: PS18-B-BF-P-200		Lab ID: 70152944001	Collected: 11/04/20 05:42	Received: 11/10/20 09:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	<b>4.3</b>	ug/L	1.0	1		11/13/20 15:32	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

Sample: PS18-01-BF1-P-201	Lab ID: 70152944002	Collected: 11/04/20 05:45	Received: 11/10/20 09:50	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	<b>1.2</b>	ug/L	1.0	1		11/13/20 15:33	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

Sample: PS18-01-BF2-P-202		Lab ID: 70152944003		Collected: 11/04/20 05:45	Received: 11/10/20 09:50	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	1.1	ug/L	1.0	1		11/13/20 15:34	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: PS18-01-BF3-P-203      Lab ID: 70152944004      Collected: 11/04/20 05:45      Received: 11/10/20 09:50      Matrix: Drinking Water</b>								
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	<b>2.2</b>	ug/L	1.0	1		11/13/20 14:46	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

Sample: PS18-01-DW-P-204	Lab ID: 70152944005	Collected: 11/04/20 05:47	Received: 11/10/20 09:50	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach								
Lead	<b>1.9</b>	ug/L	1.0	1		11/13/20 14:48	7439-92-1		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: PS18-01-KF-P-206</b>								
<b>Lab ID: 70152944006</b>								
Collected: 11/04/20 05:50								
Received: 11/10/20 09:50								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Ormond Beach								
Lead	<b>6.0</b>	ug/L	1.0	1		11/13/20 14:49	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

Sample: PS18-B-BF-P-207		Lab ID: 70152944007		Collected: 11/04/20 05:39	Received: 11/10/20 09:50	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	1.7	ug/L	1.0	1		11/13/20 14:50	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: PS18-01-BF1-P-208      Lab ID: 70152944008      Collected: 11/04/20 05:52      Received: 11/10/20 09:50      Matrix: Drinking Water</b>								
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	1.7	ug/L	1.0	1		11/13/20 14:51	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: PS18-01-BF2-P-209      Lab ID: 70152944009      Collected: 11/04/20 05:52      Received: 11/10/20 09:50      Matrix: Drinking Water</b>								
<b>200.8 MET ICPMS Drinking Water</b> Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach								
Lead	<1.0	ug/L	1.0	1		11/13/20 14:52	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: PS18-01-BF3-P-210      Lab ID: 70152944010      Collected: 11/04/20 05:52      Received: 11/10/20 09:50      Matrix: Drinking Water</b>								
<b>200.8 MET ICPMS Drinking Water</b> Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach								
Lead	<1.0	ug/L	1.0	1		11/13/20 14:52	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

Sample: PS18-02-DW-P-211		Lab ID: 70152944011		Collected: 11/04/20 06:05	Received: 11/10/20 09:50	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	<b>1.3</b>	ug/L	1.0	1		11/13/20 14:53	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

Sample: PS18-02-BF1-P-212	Lab ID: 70152944012	Collected: 11/04/20 06:05	Received: 11/10/20 09:50	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	<b>1.4</b>	ug/L	1.0	1		11/13/20 14:56	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: PS18-02-BF2-P-213      Lab ID: 70152944013      Collected: 11/04/20 06:05      Received: 11/10/20 09:50      Matrix: Drinking Water</b>								
<b>200.8 MET ICPMS Drinking Water</b> Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach								
Lead	<1.0	ug/L	1.0	1		11/13/20 14:57	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

Sample: PS18-02-BF-P-215		Lab ID: 70152944014	Collected: 11/04/20 06:03	Received: 11/10/20 09:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	<1.0	ug/L	1.0	1		11/13/20 14:58	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

Sample: PS18-02-BF1-P-216		Lab ID: 70152944015	Collected: 11/04/20 06:02	Received: 11/10/20 09:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	1.6	ug/L	1.0	1		11/13/20 14:59	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

Sample: PS18-02-BF2-P-217	Lab ID: 70152944016	Collected: 11/04/20 06:02	Received: 11/10/20 09:50	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	<b>&lt;1.0</b>	ug/L	1.0	1		11/13/20 15:00	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: PS18-02-BF3-P-218      Lab ID: 70152944017      Collected: 11/04/20 06:02      Received: 11/10/20 09:50      Matrix: Drinking Water</b>								
<b>200.8 MET ICPMS Drinking Water</b> Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach								
Lead	<1.0	ug/L	1.0	1		11/13/20 15:00	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: PS18-02-DW-P-219</b>								
<b>Lab ID: 70152944018</b>								
Collected: 11/04/20 06:00								
Received: 11/10/20 09:50								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Ormond Beach								
Lead	<1.0	ug/L	1.0	1		11/13/20 15:01	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: PS18-02-BF-P-220</b>								
<b>Lab ID: 70152944019</b>								
Collected: 11/04/20 05:59								
Received: 11/10/20 09:50								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Ormond Beach								
Lead	<b>27.5</b>	ug/L	1.0	1		11/13/20 15:02	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

Sample: PS18-02-BF-P-221		Lab ID: 70152944020		Collected: 11/04/20 05:59	Received: 11/10/20 09:50	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	<b>4.5</b>	ug/L	1.0	1		11/13/20 15:03	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

Sample: PS18-03-DW-P-222		Lab ID: 70152944021	Collected: 11/04/20 06:12	Received: 11/10/20 09:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	<1.0	ug/L	1.0	1		11/13/20 15:04	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

Sample: PS18-03-BF1-P-223		Lab ID: 70152944022	Collected: 11/04/20 06:12	Received: 11/10/20 09:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	<1.0	ug/L	1.0	1		11/13/20 15:07	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: PS18-03-BF2-P-224      Lab ID: 70152944023      Collected: 11/04/20 06:12      Received: 11/10/20 09:50      Matrix: Drinking Water</b>								
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	<1.0	ug/L	1.0	1		11/13/20 15:07	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: PS18-03-BF3-P-225      Lab ID: 70152944024      Collected: 11/04/20 06:12      Received: 11/10/20 09:50      Matrix: Drinking Water</b>								
<b>200.8 MET ICPMS Drinking Water</b> Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach								
Lead	<1.0	ug/L	1.0	1		11/16/20 12:48	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

Sample: PS18-03-BF-P-226		Lab ID: 70152944025	Collected: 11/04/20 06:11	Received: 11/10/20 09:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	<b>5.2</b>	ug/L	1.0	1		11/16/20 11:53	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: PS18-03-BF1-P-227      Lab ID: 70152944026      Collected: 11/04/20 06:09      Received: 11/10/20 09:50      Matrix: Drinking Water</b>								
<b>200.8 MET ICPMS Drinking Water</b> Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach								
Lead	1.4	ug/L	1.0	1		11/16/20 12:53	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: PS18-03-BF2-P-228</b>								
<b>Lab ID: 70152944027</b>								
Collected: 11/04/20 06:09								
Received: 11/10/20 09:50								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Ormond Beach								
Lead	<1.0	ug/L	1.0	1		11/16/20 12:53	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: PS18-03-BF3-P-229      Lab ID: 70152944028      Collected: 11/04/20 06:09      Received: 11/10/20 09:50      Matrix: Drinking Water</b>								
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	<1.0	ug/L	1.0	1		11/16/20 12:54	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: PS18-03-DW-P-230      Lab ID: 70152944029      Collected: 11/04/20 06:08      Received: 11/10/20 09:50      Matrix: Drinking Water</b>								
<b>200.8 MET ICPMS Drinking Water</b> Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach								
Lead	<1.0	ug/L	1.0	1		11/16/20 12:55	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

Sample: PS18-01-SF-P-231	Lab ID: 70152944030	Collected: 11/04/20 05:55	Received: 11/10/20 09:50	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach								
Lead	<b>22.8</b>	ug/L	1.0	1		11/16/20 12:56	7439-92-1		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

Sample: PS18-01-DW-P-231A		Lab ID: 70152944031	Collected: 11/04/20 06:23	Received: 11/10/20 09:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	<b>19.5</b>	ug/L	1.0	1		11/16/20 12:57	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

**Sample: PS18-01-SF-P-231B**      **Lab ID: 70152944032**      Collected: 11/04/20 06:23      Received: 11/10/20 09:50      Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

**200.8 MET ICPMS Drinking Water**

Analytical Method: EPA 200.8  
Pace Analytical Services - Ormond Beach

Lead	<b>3.5</b>	ug/L	1.0	1		11/16/20 12:58	7439-92-1	
------	------------	------	-----	---	--	----------------	-----------	--

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

**QUALITY CONTROL DATA**

Project: ENLARGED CITY SCHOOL 11/4  
Pace Project No.: 70152944

QC Batch: 681721	Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8	Analysis Description: 200.8 MET No Prep Drinking Water
	Laboratory: Pace Analytical Services - Ormond Beach

Associated Lab Samples: 70152944001, 70152944002, 70152944003

METHOD BLANK: 3710016 Matrix: Water  
Associated Lab Samples: 70152944001, 70152944002, 70152944003

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/13/20 15:38	

LABORATORY CONTROL SAMPLE: 3710017

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	46.0	92	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3710012 3710013

Parameter	Units	35590949004 Result	MS		MSD		% Rec		% Rec Limits	RPD	Qual
			Spike Conc.	MS Result	MSD Result	% Rec	% Rec				
Lead	ug/L	0.0025 mg/L	50	44.4	45.6	84	86	70-130	3		

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3710014 3710015

Parameter	Units	70152944003 Result	MS		MSD		% Rec		% Rec Limits	RPD	Qual
			Spike Conc.	MS Result	MSD Result	% Rec	% Rec				
Lead	ug/L	1.1	50	41.4	42.2	81	82	70-130	2		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

**QUALITY CONTROL DATA**

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

QC Batch:	681722	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Ormond Beach
Associated Lab Samples:	70152944004, 70152944005, 70152944006, 70152944007, 70152944008, 70152944009, 70152944010, 70152944011, 70152944012, 70152944013, 70152944014, 70152944015, 70152944016, 70152944017, 70152944018, 70152944019, 70152944020, 70152944021, 70152944022, 70152944023		

METHOD BLANK:	3710023	Matrix:	Water
Associated Lab Samples:	70152944004, 70152944005, 70152944006, 70152944007, 70152944008, 70152944009, 70152944010, 70152944011, 70152944012, 70152944013, 70152944014, 70152944015, 70152944016, 70152944017, 70152944018, 70152944019, 70152944020, 70152944021, 70152944022, 70152944023		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/13/20 15:10	

LABORATORY CONTROL SAMPLE:	3710024					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	46.4	93	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE:	3710019												3710020
Parameter	Units	70152944004 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Qual		
Lead	ug/L	2.2	50	50	49.0	48.9	94	93	70-130	0			

MATRIX SPIKE & MATRIX SPIKE DUPLICATE:	3710021												3710022
Parameter	Units	70152944023 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Qual		
Lead	ug/L	<1.0	50	50	47.0	45.9	92	90	70-130	2			

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

### QUALITY CONTROL DATA

Project: ENLARGED CITY SCHOOL 11/4  
Pace Project No.: 70152944

QC Batch: 681733 Analysis Method: EPA 200.8  
QC Batch Method: EPA 200.8 Analysis Description: 200.8 MET No Prep Drinking Water  
Laboratory: Pace Analytical Services - Ormond Beach  
Associated Lab Samples: 70152944024, 70152944026, 70152944027, 70152944028, 70152944029, 70152944030, 70152944031, 70152944032

METHOD BLANK: 3710147 Matrix: Water  
Associated Lab Samples: 70152944024, 70152944026, 70152944027, 70152944028, 70152944029, 70152944030, 70152944031, 70152944032

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/16/20 13:19	

LABORATORY CONTROL SAMPLE: 3710148

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.2	98	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3710143 3710144

Parameter	70152944024 Units	70152944024 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Qual
Lead	ug/L	<1.0	50	50	52.4	44.9	103	88	70-130	15	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3710145 3710146

Parameter	70152953012 Units	70152953012 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Qual
Lead	ug/L	1.8	50	50	51.1	44.2	99	85	70-130	15	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

**QUALITY CONTROL DATA**

Project: ENLARGED CITY SCHOOL 11/4  
Pace Project No.: 70152944

QC Batch: 681783	Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8	Analysis Description: 200.8 MET No Prep Drinking Water
	Laboratory: Pace Analytical Services - Ormond Beach

Associated Lab Samples: 70152944025

METHOD BLANK: 3711052 Matrix: Water  
Associated Lab Samples: 70152944025

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/16/20 12:19	

LABORATORY CONTROL SAMPLE: 3711053

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.4	101	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3711048 3711049

Parameter	Units	70152944025		3711049		MS % Rec	MSD % Rec	% Rec Limits	RPD	Qual
		MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result					
Lead	ug/L	5.2	50	50	56.5	56.0	103	102	70-130	1

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3711050 3711051

Parameter	Units	70152953051		3711051		MS % Rec	MSD % Rec	% Rec Limits	RPD	Qual
		MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result					
Lead	ug/L	1.6	50	50	49.8	50.3	96	97	70-130	1

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## QUALIFIERS

Project: ENLARGED CITY SCHOOL 11/4

Pace Project No.: 70152944

---

### DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: ENLARGED CITY SCHOOL 11/4  
Pace Project No.: 70152944

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70152944001	PS18-B-BF-P-200	EPA 200.8	681721		
70152944002	PS18-01-BF1-P-201	EPA 200.8	681721		
70152944003	PS18-01-BF2-P-202	EPA 200.8	681721		
70152944004	PS18-01-BF3-P-203	EPA 200.8	681722		
70152944005	PS18-01-DW-P-204	EPA 200.8	681722		
70152944006	PS18-01-KF-P-206	EPA 200.8	681722		
70152944007	PS18-B-BF-P-207	EPA 200.8	681722		
70152944008	PS18-01-BF1-P-208	EPA 200.8	681722		
70152944009	PS18-01-BF2-P-209	EPA 200.8	681722		
70152944010	PS18-01-BF3-P-210	EPA 200.8	681722		
70152944011	PS18-02-DW-P-211	EPA 200.8	681722		
70152944012	PS18-02-BF1-P-212	EPA 200.8	681722		
70152944013	PS18-02-BF2-P-213	EPA 200.8	681722		
70152944014	PS18-02-BF-P-215	EPA 200.8	681722		
70152944015	PS18-02-BF1-P-216	EPA 200.8	681722		
70152944016	PS18-02-BF2-P-217	EPA 200.8	681722		
70152944017	PS18-02-BF3-P-218	EPA 200.8	681722		
70152944018	PS18-02-DW-P-219	EPA 200.8	681722		
70152944019	PS18-02-BF-P-220	EPA 200.8	681722		
70152944020	PS18-02-BF-P-221	EPA 200.8	681722		
70152944021	PS18-03-DW-P-222	EPA 200.8	681722		
70152944022	PS18-03-BF1-P-223	EPA 200.8	681722		
70152944023	PS18-03-BF2-P-224	EPA 200.8	681722		
70152944024	PS18-03-BF3-P-225	EPA 200.8	681733		
70152944025	PS18-03-BF-P-226	EPA 200.8	681783		
70152944026	PS18-03-BF1-P-227	EPA 200.8	681733		
70152944027	PS18-03-BF2-P-228	EPA 200.8	681733		
70152944028	PS18-03-BF3-P-229	EPA 200.8	681733		
70152944029	PS18-03-DW-P-230	EPA 200.8	681733		
70152944030	PS18-01-SF-P-231	EPA 200.8	681733		
70152944031	PS18-01-DW-P-231A	EPA 200.8	681733		
70152944032	PS18-01-SF-P-231B	EPA 200.8	681733		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

Page 1 of 2

CLIENT INFORMATION

Name: Enlarged City School District of Troy  
 Address: 475 First Street Troy NY 12180  
 Client Rep: Bob Garland

Date of Sampling: 11/4/2020  
 Samples Taken By: Paul Swieton  
 Samples Taken By: Tracey Catalfamo

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME: PS 18  
 BLDG ADDRESS: 417 Hoosick Street Troy NY 12180  
 CONTACT NAME & NUMBERS: Bob Garland 518-328-5426

(1) Yr. Built: 1927  
 (2) Yr. 1st Add: (3) Yr. 2nd Add: (4) Yr. 1st Mod: (5) Yr. 2nd Mod:

WO#: 70152944



SAMPLE DATA

Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	30 Second Flush Draw	Time of Collection (24hr)	Service Connection Draw	Time of Collection (24hr)	Water Main Draw	Time of Collection (24hr)
200	PS18-8-BF-P-200	Faculty bathroom/Old boys locker room	Sink			X	5:42						
201	PS18-01-BF1-P-201	Boys room	Sink 1			X	5:45						
202	PS18-01-BF2-P-202	Boys room	Sink 2			X	5:45						
203	PS18-01-BF3-P-203	Boys room	Sink 3			X	5:45						
204	PS18-01-DW-P-204	Corridor	Water fountain			X	5:47						
205	PS18-01-DW-P-205	Corridor	Water fountain			X	Out of Service, No Sample						
206	PS18-01-KF-P-206	Kitchen	Sink			X	5:50						
207	PS18-8-BF-P-207	Faculty bathroom/Old girls locker room	Sink			X	5:39						
208	PS18-01-BF1-P-208	Girls room	Sink 1			X	5:52						
209	PS18-01-BF2-P-209	Girls room	Sink 2			X	5:52						
210	PS18-01-BF3-P-210	Girls room	Sink 3			X	5:52						
211	PS18-02-DW-P-211	Corridor	Water fountain			X	6:05						
212	PS18-02-BF1-P-212	Girls room	Sink 1			X	6:05						
213	PS18-02-BF2-P-213	Girls room	Sink 2			X	6:05						
214	PS18-02-BF3-P-214	Girls room	Sink 3			X	Out of Service, No Sample						
215	PS18-02-BF-P-215	219 bathroom	Sink			X	6:03						
216	PS18-02-BF1-P-216	Boys room	Sink 1			X	6:02						
217	PS18-02-BF2-P-217	Boys room	Sink 2			X	6:02						
218	PS18-02-BF3-P-218	Boys room	Sink 3			X	6:02						
219	PS18-02-DW-P-219	Corridor	Water fountain			X	6:00						
220	PS18-02-BF-P-220	Asst. Principal bathroom	Sink			X	5:59						
221	PS18-02-BF-P-221	Principal bathroom	Sink			X	5:59						
222	PS18-03-DW-P-222	Corridor	Water fountain			X	6:12						
223	PS18-03-BF1-P-223	Boys room	Sink 1			X	6:12						
224	PS18-03-BF2-P-224	Boys room	Sink 2			X	6:12						

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By: *Paul Swieton* Received By: *J. Swieton*  
 Date: 11/11/20  
 Time: 1:50 PM

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab: Pace Analytical

Contact:

Comments: Provide Laboratory Data Report (LDR) and Chain of Custody





# Sample Condition Upon Receipt

## WO#: 70152944

Client Name: QUESTAR

Project

PM: NML

Due Date: 11/24/20

CLIENT: QUESTAR

Courier:  Fed Ex  UPS  USPS  Client  Commercial  Pace  Other

Tracking #: 9099 9901 1102

Custody Seal on Cooler/Box Present:  Yes  No Seals intact:  Yes  No

Packing Material:  Bubble Wrap  Bubble Bags  Ziploc  None  Other

Thermometer Used: TA091 Correction Factor: -0.2

Cooler Temperature (°C): 21.3 Cooler Temperature Corrected (°C): 21.1

Temp should be above freezing to 6.0°C

USDA Regulated Soil (  N/A, water sample)

Date and Initials of person examining contents: KW 11/10/20

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)?  YES  NO

Did samples originate from a foreign source (internationally, including Hawaii and Puerto Rico)?  Yes  No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

			COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr):	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD)	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
Containers Intact:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	12.
-Includes date/time/ID/Analysis Matrix SL WT OIL			
All containers needing preservation have been checked	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	13. <input type="checkbox"/> HNO <sub>3</sub> <input type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot #			Sample #
All containers needing preservation are found to be in compliance with EPA recommendation? (HNO <sub>3</sub> , H <sub>2</sub> SO <sub>4</sub> , HCl, NaOH>9 Sulfide, NaOH>12 Cyanide) Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	Initial when completed: Lot # of added preservative: Date/Time preservative added
Samples checked for dechlorination:	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
KI starch test strips Lot #			
Residual chlorine strips Lot #			
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	15.
Trip Blank Present:	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable):			

Client Notification/ Resolution: \_\_\_\_\_ Field Data Required? Y / N

Person Contacted: \_\_\_\_\_ Date/Time: \_\_\_\_\_

Comments/ Resolution: \_\_\_\_\_

\* PM (Project Manager) review is documented electronically in LIMS.

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

Appendix D

CLIENT INFORMATION

Name:	Enlarged City School District of Troy
Address:	475 First Street Troy NY 12180
Client Rep:	Bob Garland

Date of Sampling:	11/4/2020
Samples Taken By:	Paul Swieton
Samples Taken By:	Tracey Catafamo

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	PS 18
BLDG ADDRESS:	417 Hoosick Street Troy NY 12180
CONTACT NAME & NUMBERS:	Bob Garland 518-328-5426

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:
1927				

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information						
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Lead test Results ug/L from 11/4/2020			Remediation
200	PS18-B-BF-P-200	Faculty bathroom/Old boys locker room	Sink			X	4.3			
201	PS18-01-BF1-P-201	Boys room	Sink 1			X	1.2			
202	PS18-01-BF2-P-202	Boys room	Sink 2			X	1.1			
203	PS18-01-BF3-P-203	Boys room	Sink 3			X	2.2			
204	PS18-01-DW-P-204	Corridor	Water fountain			X	1.9			
205	PS18-01-DW-P-205	Corridor	Water fountain			X	Out of Service, No Sample			
206	PS18-01-KF-P-206	Kitchen	Sink			X	6.0			
207	PS18-B-BF-P-207	Faculty bathroom/Old girls locker room	Sink			X	1.7			
208	PS18-01-BF1-P-208	Girls room	Sink 1			X	1.7			
209	PS18-01-BF2-P-209	Girls room	Sink 2			X	<1.0			
210	PS18-01-BF3-P-210	Girls room	Sink 3			X	<1.0			
211	PS18-02-DW-P-211	Corridor	Water fountain			X	1.3			
212	PS18-02-BF1-P-212	Girls room	Sink1			X	1.4			
213	PS18-02-BF2-P-213	Girls room	Sink 2			X	<1.0			
214	PS18-02-BF3-P-214	Girls room	Sink 3			X	Out of Service, No Sample			
215	PS18-02-BF-P-215	219 bathroom	Sink			X	<1.0			
216	PS18-02-BF1-P-216	Boys room	Sink 1			X	1.6			
217	PS18-02-BF2-P-217	Boys room	Sink 2			X	<1.0			
218	PS18-02-BF3-P-218	Boys room	Sink 3			X	<1.0			
219	PS18-02-DW-P-219	Corridor	Water fountain			X	<1.0			
220	PS18-02-BF-P-220	Asst. Principal bathroom	Sink			X	27.5			
221	PS18-02-BF-P-221	Principal bathroom	Sink			X	4.5			
222	PS18-03-DW-P-222	Corridor	Water fountain			X	<1.0			
223	PS18-03-BF1-P-223	Boys room	Sink 1			X	<1.0			
224	PS18-03-BF2-P-224	Boys room	Sink 2			X	<1.0			

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab: Pace Analytical	
Contact:	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	







Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
PS18-B-BF-P-200	11/4/2020 05:42	11/13/2020 15:32	70152944001	Lead	4.3	15	ug/L
PS18-01-BF1-P-201	11/4/2020 05:45	11/13/2020 15:33	70152944002	Lead	1.2	15	ug/L
PS18-01-BF2-P-202	11/4/2020 05:45	11/13/2020 15:34	70152944003	Lead	1.1	15	ug/L
PS18-01-BF3-P-203	11/4/2020 05:45	11/13/2020 14:46	70152944004	Lead	2.2	15	ug/L
PS18-01-DW-P-204	11/4/2020 05:47	11/13/2020 14:48	70152944005	Lead	1.9	15	ug/L
PS18-01-KF-P-206	11/4/2020 05:50	11/13/2020 14:49	70152944006	Lead	6.0	15	ug/L
PS18-B-BF-P-207	11/4/2020 05:39	11/13/2020 14:50	70152944007	Lead	1.7	15	ug/L
PS18-01-BF1-P-208	11/4/2020 05:52	11/13/2020 14:51	70152944008	Lead	1.7	15	ug/L
PS18-01-BF2-P-209	11/4/2020 05:52	11/13/2020 14:52	70152944009	Lead	<1.0	15	ug/L
PS18-01-BF3-P-210	11/4/2020 05:52	11/13/2020 14:52	70152944010	Lead	<1.0	15	ug/L
PS18-02-DW-P-211	11/4/2020 06:05	11/13/2020 14:53	70152944011	Lead	1.3	15	ug/L
PS18-02-BF1-P-212	11/4/2020 06:05	11/13/2020 14:56	70152944012	Lead	1.4	15	ug/L
PS18-02-BF2-P-213	11/4/2020 06:05	11/13/2020 14:57	70152944013	Lead	<1.0	15	ug/L
PS18-02-BF-P-215	11/4/2020 06:03	11/13/2020 14:58	70152944014	Lead	<1.0	15	ug/L
PS18-02-BF1-P-216	11/4/2020 06:02	11/13/2020 14:59	70152944015	Lead	1.6	15	ug/L
PS18-02-BF2-P-217	11/4/2020 06:02	11/13/2020 15:00	70152944016	Lead	<1.0	15	ug/L
PS18-02-BF3-P-218	11/4/2020 06:02	11/13/2020 15:00	70152944017	Lead	<1.0	15	ug/L
PS18-02-DW-P-219	11/4/2020 06:00	11/13/2020 15:01	70152944018	Lead	<1.0	15	ug/L
PS18-02-BF-P-220	11/4/2020 05:59	11/13/2020 15:02	70152944019	Lead	27.5	15	ug/L
PS18-02-BF-P-221	11/4/2020 05:59	11/13/2020 15:03	70152944020	Lead	4.5	15	ug/L
PS18-03-DW-P-222	11/4/2020 06:12	11/13/2020 15:04	70152944021	Lead	<1.0	15	ug/L
PS18-03-BF1-P-223	11/4/2020 06:12	11/13/2020 15:07	70152944022	Lead	<1.0	15	ug/L
PS18-03-BF2-P-224	11/4/2020 06:12	11/13/2020 15:07	70152944023	Lead	<1.0	15	ug/L
PS18-03-BF3-P-225	11/4/2020 06:12	11/16/2020 12:48	70152944024	Lead	<1.0	15	ug/L
PS18-03-BF-P-226	11/4/2020 06:11	11/16/2020 11:53	70152944025	Lead	5.2	15	ug/L
PS18-03-BF1-P-227	11/4/2020 06:09	11/16/2020 12:53	70152944026	Lead	1.4	15	ug/L
PS18-03-BF2-P-228	11/4/2020 06:09	11/16/2020 12:53	70152944027	Lead	<1.0	15	ug/L
PS18-03-BF3-P-229	11/4/2020 06:09	11/16/2020 12:54	70152944028	Lead	<1.0	15	ug/L
PS18-03-DW-P-230	11/4/2020 06:08	11/16/2020 12:55	70152944029	Lead	<1.0	15	ug/L
PS18-01-SF-P-231	11/4/2020 05:55	11/16/2020 12:56	70152944030	Lead	22.8	15	ug/L
PS18-01-DW-P-231A	11/4/2020 06:23	11/16/2020 12:57	70152944031	Lead	19.5	15	ug/L
PS18-01-SF-P-231B	11/4/2020 06:23	11/16/2020 12:58	70152944032	Lead	3.5	15	ug/L

NYSDOH Action Level for Lead of 15 ppb