

December 22, 2016:

Dear Troy High School Families and Staff:

We are continuing the process of testing our faucets for lead and remediating where necessary. We have received the results of the latest round of testing. We will also be fixing faucets that are currently inoperable and testing them once fixed. In addition, faucets that have been remediated will be tested once again. We will continue to notify you, along with the Rensselaer County Department of Health, as we receive the results.

Of the most recent 25 samples tested at Troy High School, 18 tested above the allowable 15 micrograms of lead per liter (mcg/L) as per the new regulations. As with any sample we find to be over the allowable limit, we have isolated those faucets immediately to prevent consumption until we have the opportunity to investigate further. Those 18 faucets are identified on page 2 of this letter.

Results for each building will be posted on our website at [www.troycsd.org/watertesting](http://www.troycsd.org/watertesting) as we receive them.

As always, we are committed to providing a safe and healthy environment for students and staff. Please be assured that we will continue to take the necessary steps to ensure that the quality of our drinking water meets the new state regulations.

Please feel free to contact the Business Office at 518-328-5005 with any questions or concerns.

Sincerely,



John Carmello  
Superintendent of Schools

<b>Date Sampled</b>	<b>Building</b>	<b>Location</b>	<b>Outlet</b>	<b>Results</b>
Dec. 16, 2016	Troy High School	Boys Room	Sink 2	16 mcg/L
Dec. 16, 2016	Troy High School	Boys Room	Sink 1	256 mcg/L
Dec. 16, 2016	Troy High School	Rm 123/122	Sink 2	171 mcg/L
Dec. 16, 2016	Troy High School	Women's Room	Sink 3	18 mcg/L
Dec. 16, 2016	Troy High School	Rm 1	Sink 3	21 mcg/L
Dec. 16, 2016	Troy High School	Rm 226	Sink 9	127 mcg/L
Dec. 16, 2016	Troy High School	Rm 226	Sink 10	240 mcg/L
Dec. 16, 2016	Troy High School	Rm 228	Sink 7	103 mcg/L
Dec. 16, 2016	Troy High School	Rm 228	Sink 8	369 mcg/L
Dec. 16, 2016	Troy High School	Rm 228	Sink 9	40 mcg/L
Dec. 16, 2016	Troy High School	Rm 228	Sink 10	50 mcg/L
Dec. 16, 2016	Troy High School	Rm 326	Sink 22	445 mcg/L
Dec. 16, 2016	Troy High School	Rm 324/324	Sink 4	19 mcg/L
Dec. 16, 2016	Troy High School	Rm 324/324	Sink 6	16 mcg/L
Dec. 16, 2016	Troy High School	Rm 324/324	Sink 14	99 mcg/L
Dec. 16, 2016	Troy High School	Rm 324/324	Sink 22	39 mcg/L
Dec. 16, 2016	Troy High School	Rm 324/324	Sink 26	55 mcg/L
Dec. 16, 2016	Troy High School	Boys Room	Sink 3	35 mcg/L