

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

Appendix D

CLIENT INFORMATION

Name:	Enlarged City School District of Troy
Address:	475 First Street Troy NY 12180
Client Rep:	Guy Gardner

Date of Sampling:	9/27/2016
Samples Taken By:	Paul Swieton
Samples Taken By:	Tim LeVan

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	PS 14
BLDG ADDRESS:	1700 Tibbits Ave. Troy NY 12180
CONTACT NAME & NUMBERS:	Guy Gardner 518-328-5426

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information						
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	Initial Test Result Lead	Retest result 2/8/17	Remediation
239	PS14-01-MF-P-239	Custodian storage	Sink			X	4:54	2.1		
240	PS14-01-BF-P-240	Mens room	Sink			X	4:55	ND		
241	PS14-01-BF-P-241	Womens room	Sink			X	4:52	0.5		
242	PS14-01-KF1-P-242	Kitchen	Sink 1			X	4:58	0.5		
243	PS14-01-KF2-P-243	Kitchen	Sink 2			X	4:59	1.56		
244	PS14-01-DW-P-244	Cafeteria	Water fountain			X	4:59	ND		
245	PS14-01-BF1-P-245	Boys locker room	Gang sink 1			X	5:06	8.44		
246	PS14-01-BF2-P-246	Boys locker room	Gang sink 2			X	5:06	6.8		
247	PS14-01-BF3-P-247	Boys locker room	Gang sink 3			X	5:06	8.46		
248	PS14-01-DW-P-248	Gym	Water fountain			X	5:04	ND		
249	PS14-01-BF1-P-249	Girls locker room	Gang sink 1			X	5:06	6.83		
250	PS14-01-BF2-P-250	Girls locker room	Gang sink 2			X	5:06	6.04		
251	PS14-01-BF3-P-251	Girls locker room	Gang sink 3			X	5:06	7.05		
252	PS14-01-BF-P-252	Mens room	Sink			X	5:09	12.1		
253	PS14-01-BF-P-253	Womens room	Sink			X	5:10	3.45		
254	PS14-01-CF1-P-254	Pink cluster	Sink 1			X	5:12	6.67		
255	PS14-01-CF2-P-255	Pink cluster	Sink 2			X	5:13	6.12		
256	PS14-01-DW-P-256	Pink cluster	Water fountain			X	5:13	ND		
257	PS14-01-BF-P-257	Pink girls room	Sink			X	5:16	ND		
258	PS14-01-BF-P-258	Pink boys room	Sink			X	5:16	0.76		
259	PS14-01-NF-P-259	Nurses office	Sink 1			X	5:20	4.58		
260	PS14-01-NF-P-260	Nurses office	Sink 2			X	5:20	1.3		
261	PS14-01-BF-P-261	Nurses bathroom	Sink			X	5:21	1.29		
262	PS14-01-BF-P-262	Principal bathroom	Sink			X	5:22	ND		
263	PS14-01-CF-P-263	Art room	Sink			X	5:24	3.44		

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab:	CNA Environmental
Contact:	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	

CLIENT INFORMANTION

Name:	Enlarged City School District of Troy
Address:	475 First Street Troy NY 12180
Client Rep:	Guy Gardner

Date of Sampling:	9/27/2016
Samples Taken By:	Paul Swieton
Samples Taken By:	Tim LeVan

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	PS 14
BLDG ADDRESS:	1700 Tibbits Ave. Troy NY 12180
CONTACT NAME & NUMBERS:	Guy Gardner 518-328-5426

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information						
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	Initial test result Lead	Retest result 2/8/17	Remediation
264	PS14-01-BF-P-264	Art bathroom	Sink			X	5:25	1.77		
265	PS14-01-CF1-P-265	Red cluster	Sink 1			X	5:27	13.9		
266	PS14-01-CF2-P-266	Red cluster	Sink 2			X	5:27	7.81		
267	PS14-01-DW-P-267	Red cluster	Water fountain			X	5:28	ND		
268	PS14-01-BF-P-268	Red girls room	Sink			X	5:28	0.69		
269	PS14-01-BF-P-269	Red boys room	Sink			X	5:29	1.42		
270	PS14-01-DW-P-270	Faculty room	Water fountain			X	5:30	ND		
271	PS14-01-BF-P-271	Faculty room bathroom	Sink			X	5:31	1.35		
272	PS14-01-CF1-P-272	Green cluster	Sink 1			X	5:32	5.55		
273	PS14-01-CF2-P-273	Green cluster	Sink 2			X	5:33	7.45		
274	PS14-01-DW-P-274	Green cluster	Water fountain			X	5:33	ND		
275	PS14-01-BF-P-275	Green girls room	Sink			X	5:34	0.54		
276	PS14-01-BF-P-276	Green boys room	Sink			X	5:35	0.57		
277	PS14-01-BF-P-277	Mens room	Sink			X	5:37	0.62		
278	PS14-01-BF-P-278	Womens room	Sink			X	5:38	1.65		
279	PS14-01-CF1-P-279	Yellow cluster	Sink 1			X	5:39	2.66		
280	PS14-01-CF2-P-280	Yellow cluster	Sink 2			X	5:40	3.17		
281	PS14-01-DW-P-281	Yellow cluster	Water fountain			X	5:40	ND		
282	PS14-01-BF-P-282	Yellow girls room	Sink			X	5:41	ND		
283	PS14-01-BF-P-283	Yellow boys room	Sink			X	5:41	ND		
284	PS14-02-CF1-P-284	Blue cluster	Sink			X	5:43	7.93		
285	PS14-02-CF2-P-285	Blue cluster	Sink			X	5:44	5.5		
286	PS14-02-DW-P-286	Blue cluster	Water fountain			X	5:45	ND		
287	PS14-02-BF-P-287	Blue girls room	Sink			X	5:45	ND		
288	PS14-02-BF-P-288	Blue boys room	Sink			X	5:45	ND		

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab:	CNA Environmental
Contact:	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	

CLIENT INFORMANTION

Name:	Enlarged City School District of Troy
Address:	475 First Street Troy NY 12180
Client Rep:	Guy Gardner

Date of Sampling:	9/27/2016
Samples Taken By:	Paul Swieton
Samples Taken By:	Tim LeVan

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	PS 14
BLDG ADDRESS:	1700 Tibbits Ave. Troy NY 12180
CONTACT NAME & NUMBERS:	Guy Gardner 518-328-5426

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:
1993				

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information						
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	Initial Test Result Lead	Retest Result 2/8/17	Remediation
289	PS14-02-CF1-P-289	Orange cluster	Sink 1			X	5:49	10.2		
290	PS14-02-CF2-P-290	Orange cluster	Sink 2			X	5:49	3.74		
291	PS14-02-DW-P-291	Orange cluster	Water fountain			X	5:49	ND		
292	PS14-02-BF-P-292	Orange girls room	Sink			X	5:50	2.15		
293	PS14-02-BF-P-293	Orange boys room	Sink			X	5:50	1.96		
294A	PS12-02-CF-P-294A	Faculty Room	Sink			X	5:54	2.92		
294	PS14-02-DW-P-294	Faculty room	Water fountain			X	Out of Service		10	
296	PS14-02-BF-P-296	Mens room	Sink			X	5:56	1.1		
297	PS14-02-BF-P-297	Womens room	Sink			X	5:57	ND		
298	PS14-02-CF1-P-298	Turquoise cluster	Sink 1			X	5:58	2.93		
299	PS14-02-CF2-P-299	Turquoise cluster	Sink 2			X	5:59	5.49		
300	PS14-02-DW-P-300	Turquoise cluster	Water fountain			X	5:59	0.5		
301	PS14-02-BF-P-301	Turquoise girls room	Sink			X	6:00	1.05		
302	PS14-02-BF-P-302	Turquoise boys room	Sink			X	6:00	1.01		
303	PS14-02-BF-P-303	Special Ed. Room	Sink			X	6:02	0.71		
304	PS14-02-CF1-P-304	Purple cluster	Sink 1			X	6:04	3.55		
305	PS14-02-CF2-P-305	Purple cluster	Sink 2			X	6:05	5.5		
306	PS14-02-DW-P-306	Purple cluster	Water fountain			X	6:07	ND		
307	PS14-02-BF-P-307	Purple girls room	Sink			X	6:06	1.41		
308	PS14-02-BF-P-308	Purple boys room	Sink			X	6:06	0.58		

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab: CNA Environmental	
Contact:	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	