

December 09, 2020

Paul Swieton
Rensselaer-Columbia-Greene Counties and
BOCES
10 Empire State Blvd.
Fl 2
Castleton On Hudson, NY 12033

RE: Project: ENLARGED SCHOOL OF TROY 11/20
Pace Project No.: 70154703

Dear Paul Swieton:

Enclosed are the analytical results for sample(s) received by the laboratory on November 24, 2020. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Nicolette M. Lovari
nicolette.lovari@pacelabs.com
(631)694-3040
Project Manager

Enclosures

cc: Robert Garland, Troy City SD
Tim LeVan, Questar III



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Pace Analytical Services Long Island

575 Broad Hollow Rd, Melville, NY 11747

New York Certification #: 10478 Primary Accrediting Body

New Jersey Certification #: NY158

Pennsylvania Certification #: 68-00350

Connecticut Certification #: PH-0435

Maryland Certification #: 208

Rhode Island Certification #: LAO00340

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-BF-P-115		Lab ID: 70154703001	Collected: 11/20/20 05:31	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.2	ug/L	1.0	1		12/07/20 18:37	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-CF-P-116		Lab ID: 70154703002		Collected: 11/20/20 05:32	Received: 11/24/20 10:45	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.1	ug/L	1.0	1		12/07/20 18:38	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-DW-P-117		Lab ID: 70154703003	Collected: 11/20/20 05:33	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	17.7	ug/L	1.0	1		12/07/20 18:40	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-CF-118		Lab ID: 70154703004	Collected: 11/20/20 05:34	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	13.5	ug/L	1.0	1		12/07/20 18:42	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-DW-P-119		Lab ID: 70154703005	Collected: 11/20/20 05:36	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	38.0	ug/L	1.0	1		12/07/20 18:43	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-NF1-P-120		Lab ID: 70154703006	Collected: 11/20/20 05:36	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.0	ug/L	1.0	1		12/07/20 18:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-NF2-P-121		Lab ID: 70154703007	Collected: 11/20/20 05:36	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	13.2	ug/L	1.0	1		12/07/20 18:46	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-NF3-P-122		Lab ID: 70154703008	Collected: 11/20/20 05:38	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	6.3	ug/L	1.0	1		12/07/20 18:48	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-CF-P-123		Lab ID: 70154703009	Collected: 11/20/20 05:38	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		12/07/20 18:50	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-DW-P-124		Lab ID: 70154703010	Collected: 11/20/20 05:38	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.8	ug/L	1.0	1		12/07/20 18:51	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-DW-P-125		Lab ID: 70154703011	Collected: 11/20/20 05:39	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	69.0	ug/L	1.0	1		12/07/20 18:59	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-CF-P-126		Lab ID: 70154703012	Collected: 11/20/20 05:39	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.6	ug/L	1.0	1		12/07/20 19:01	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-DW-P-127		Lab ID: 70154703013	Collected: 11/20/20 05:39	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	15.1	ug/L	1.0	1		12/07/20 19:02	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-DW-BF-P-128		Lab ID: 70154703014	Collected: 11/20/20 05:40	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.9	ug/L	1.0	1		12/07/20 19:04	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-CF-P-129		Lab ID: 70154703015	Collected: 11/20/20 05:41	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.1	ug/L	1.0	1		12/07/20 19:06	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-DW-P-130		Lab ID: 70154703016	Collected: 11/20/20 05:41	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	15.8	ug/L	1.0	1		12/07/20 19:07	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-BF-P-131		Lab ID: 70154703017		Collected: 11/20/20 05:43		Received: 11/24/20 10:45		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.9	ug/L	1.0	1		12/07/20 19:09	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-CF-P-132		Lab ID: 70154703018	Collected: 11/20/20 05:44	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.1	ug/L	1.0	1		12/07/20 19:11	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-DW-P-134		Lab ID: 70154703019	Collected: 11/20/20 05:47	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	117	ug/L	1.0	1		12/07/20 19:15	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-FS-P-135		Lab ID: 70154703020	Collected: 11/20/20 05:48	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.8	ug/L	1.0	1		12/07/20 19:20	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-CF-P-136		Lab ID: 70154703021	Collected: 11/20/20 05:49	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.2	ug/L	1.0	1		12/07/20 19:25	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-DW-P-137		Lab ID: 70154703022	Collected: 11/20/20 05:51	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/07/20 19:27	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-KF1-P-155		Lab ID: 70154703023	Collected: 11/20/20 05:51	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/07/20 19:28	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-KF2-P-139		Lab ID: 70154703024	Collected: 11/20/20 05:51	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		12/07/20 19:30	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-KF3-P-140		Lab ID: 70154703025	Collected: 11/20/20 05:51	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/07/20 19:35	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-DW-P-141		Lab ID: 70154703026	Collected: 11/20/20 05:53	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/07/20 19:36	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-DW-P-142		Lab ID: 70154703027	Collected: 11/20/20 05:54	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	9.5	ug/L	1.0	1		12/07/20 19:38	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-DW-P-143		Lab ID: 70154703028	Collected: 11/20/20 05:54	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	12.6	ug/L	1.0	1		12/07/20 19:39	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-CF-P-144		Lab ID: 70154703029	Collected: 11/20/20 05:57	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/07/20 19:41	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-BF1-P-145		Lab ID: 70154703030	Collected: 11/20/20 05:57	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/07/20 19:43	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-BF2-P-146		Lab ID: 70154703031	Collected: 11/20/20 05:58	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/07/20 19:48	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-CF-P-147		Lab ID: 70154703032	Collected: 11/20/20 05:59	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.0	ug/L	1.0	1		12/07/20 19:49	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-BF2-P-150		Lab ID: 70154703033	Collected: 11/20/20 06:01	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/07/20 19:54	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: HE-01-CF-P-151		Lab ID: 70154703034		Collected: 11/20/20 06:01		Received: 11/24/20 10:45		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.8	ug/L	1.0	1		12/07/20 19:56	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-CF-P-152		Lab ID: 70154703035	Collected: 11/20/20 06:02	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	22.5	ug/L	1.0	1		12/07/20 19:57	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-CF-P-154		Lab ID: 70154703036	Collected: 11/20/20 06:02	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.2	ug/L	1.0	1		12/07/20 19:59	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-DW-P-155		Lab ID: 70154703037	Collected: 11/20/20 06:04	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.1	ug/L	1.0	1		12/07/20 20:00	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-DW-P-156		Lab ID: 70154703038	Collected: 11/20/20 06:04	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	13.2	ug/L	1.0	1		12/07/20 20:02	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-BF1-P-157		Lab ID: 70154703039	Collected: 11/20/20 06:04	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/07/20 20:04	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-BF2-P-158		Lab ID: 70154703040	Collected: 11/20/20 06:05	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/07/20 20:08	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-BF1-P-159		Lab ID: 70154703041	Collected: 11/20/20 06:06	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/07/20 20:16	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-DW-P-161		Lab ID: 70154703042	Collected: 11/20/20 06:07	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/07/20 20:18	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-CF-P-162		Lab ID: 70154703043	Collected: 11/20/20 06:07	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/07/20 20:20	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-DW-P-163		Lab ID: 70154703044	Collected: 11/20/20 06:07	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	8.3	ug/L	1.0	1		12/07/20 20:21	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-CF-P-164		Lab ID: 70154703045	Collected: 11/20/20 06:08	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	34.6	ug/L	1.0	1		12/07/20 20:23	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-DW-P-165		Lab ID: 70154703046	Collected: 11/20/20 06:08	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/07/20 20:25	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-CF-P-166		Lab ID: 70154703047	Collected: 11/20/20 06:09	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/07/20 20:26	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-DW-P-167		Lab ID: 70154703048	Collected: 11/20/20 06:09	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/07/20 20:28	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-CF-P-168		Lab ID: 70154703049	Collected: 11/20/20 06:11	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.8	ug/L	1.0	1		12/07/20 20:33	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-CF-P-170		Lab ID: 70154703050	Collected: 11/20/20 06:12	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/07/20 20:34	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-DW-P-171		Lab ID: 70154703051	Collected: 11/20/20 06:12	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/07/20 20:39	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-CF-P-172		Lab ID: 70154703052	Collected: 11/20/20 06:13	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/07/20 20:41	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-BF1-P-174		Lab ID: 70154703053	Collected: 11/20/20 06:14	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/07/20 20:42	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-BF2-P-175		Lab ID: 70154703054	Collected: 11/20/20 06:14	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/07/20 20:44	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-BF1-P-176		Lab ID: 70154703055	Collected: 11/20/20 06:16	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/07/20 20:46	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-02-BF1-P-178		Lab ID: 70154703056	Collected: 11/20/20 06:19	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		12/07/20 20:47	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-02-BF2-P-179		Lab ID: 70154703057	Collected: 11/20/20 06:19	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/07/20 20:52	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-02-BF1-P-180		Lab ID: 70154703058	Collected: 11/20/20 06:19	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/07/20 20:54	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-02-CF-P-181		Lab ID: 70154703059	Collected: 11/20/20 06:20	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	8.5	ug/L	1.0	1		12/07/20 20:55	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-02-DW-P-182		Lab ID: 70154703060	Collected: 11/20/20 06:20	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.8	ug/L	1.0	1		12/07/20 21:00	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-02-CF-P-183		Lab ID: 70154703061	Collected: 11/20/20 06:21	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/07/20 21:05	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-02-DW-P-184		Lab ID: 70154703062	Collected: 11/20/20 06:21	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.3	ug/L	1.0	1		12/07/20 21:07	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-02-CF-P-185		Lab ID: 70154703063		Collected: 11/20/20 06:23		Received: 11/24/20 10:45		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.2	ug/L	1.0	1		12/07/20 21:11	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-02-DW-P-186		Lab ID: 70154703064	Collected: 11/20/20 06:23	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	13.5	ug/L	1.0	1		12/07/20 21:13	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-02-BF-P-187		Lab ID: 70154703065		Collected: 11/20/20 06:25		Received: 11/24/20 10:45		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.0	ug/L	1.0	1		12/07/20 21:15	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-02-CF-P-188		Lab ID: 70154703066	Collected: 11/20/20 06:25	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.3	ug/L	1.0	1		12/07/20 21:16	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-02-BF-P-190		Lab ID: 70154703067	Collected: 11/20/20 06:27	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.0	ug/L	1.0	1		12/07/20 21:18	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-02-CF-P-191		Lab ID: 70154703068	Collected: 11/20/20 06:27	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/07/20 21:19	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-02-DW-P-192		Lab ID: 70154703069	Collected: 11/20/20 06:27	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/07/20 21:21	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-02-CF-P-193		Lab ID: 70154703070	Collected: 11/20/20 06:28	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		12/07/20 21:23	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-02-BF1-P-195		Lab ID: 70154703071	Collected: 11/20/20 06:29	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/07/20 21:31	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-02-BF2-P-196		Lab ID: 70154703072	Collected: 11/20/20 06:29	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/07/20 21:32	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-02-DW-P-197		Lab ID: 70154703073	Collected: 11/20/20 06:30	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.7	ug/L	1.0	1		12/07/20 21:34	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-02-BF1-P-198		Lab ID: 70154703074	Collected: 11/20/20 06:30	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/07/20 21:36	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-02-BF2-P-199		Lab ID: 70154703075	Collected: 11/20/20 06:30	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/07/20 21:37	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Sample: CHE-01-CF-P-133A		Lab ID: 70154703076	Collected: 11/20/20 05:45	Received: 11/24/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	80.5	ug/L	1.0	1		12/07/20 21:39	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

QC Batch:	188459	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70154703001, 70154703002, 70154703003, 70154703004, 70154703005, 70154703006, 70154703007, 70154703008, 70154703009, 70154703010, 70154703011, 70154703012, 70154703013, 70154703014, 70154703015, 70154703016, 70154703017, 70154703018, 70154703019		

METHOD BLANK:	924782	Matrix:	Water
Associated Lab Samples:	70154703001, 70154703002, 70154703003, 70154703004, 70154703005, 70154703006, 70154703007, 70154703008, 70154703009, 70154703010, 70154703011, 70154703012, 70154703013, 70154703014, 70154703015, 70154703016, 70154703017, 70154703018, 70154703019		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/07/20 18:26	

LABORATORY CONTROL SAMPLE:	924783					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.4	105	85-115	

MATRIX SPIKE SAMPLE:		924785					
		70154659020	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	4	13.5	321	70-130	M1

MATRIX SPIKE SAMPLE:		924787					
		70154703010	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	4.8	4	9.4	114	70-130	

SAMPLE DUPLICATE: 924784

Parameter	Units	70154659020 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 924786

Parameter	Units	70154703010 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	4.8	4.9	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

QC Batch:	188460	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70154703020, 70154703021, 70154703022, 70154703023, 70154703024, 70154703025, 70154703026, 70154703027, 70154703028, 70154703029, 70154703030, 70154703031, 70154703032, 70154703033, 70154703034, 70154703035, 70154703036, 70154703037, 70154703038, 70154703039		

METHOD BLANK:	924788	Matrix:	Water
Associated Lab Samples:	70154703020, 70154703021, 70154703022, 70154703023, 70154703024, 70154703025, 70154703026, 70154703027, 70154703028, 70154703029, 70154703030, 70154703031, 70154703032, 70154703033, 70154703034, 70154703035, 70154703036, 70154703037, 70154703038, 70154703039		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/07/20 19:17	

LABORATORY CONTROL SAMPLE:	924789					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.9	106	85-115	

MATRIX SPIKE SAMPLE:		924791					
		70154703020	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	3.8	4	8.4	114	70-130	

MATRIX SPIKE SAMPLE:		924793					
		70154703030	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	4	4.5	111	70-130	

SAMPLE DUPLICATE: 924790					
		70154703020	Dup		
Parameter	Units	Result	Result	RPD	Qualifiers
Lead	ug/L	3.8	3.8	2	

SAMPLE DUPLICATE: 924792

Parameter	Units	70154703030 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

QC Batch:	188462	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70154703040, 70154703041, 70154703042, 70154703043, 70154703044, 70154703045, 70154703046, 70154703047, 70154703048, 70154703049, 70154703050, 70154703051, 70154703052, 70154703053, 70154703054, 70154703055, 70154703056, 70154703057, 70154703058, 70154703059		

METHOD BLANK: 924798

Matrix: Water

Associated Lab Samples: 70154703040, 70154703041, 70154703042, 70154703043, 70154703044, 70154703045, 70154703046, 70154703047, 70154703048, 70154703049, 70154703050, 70154703051, 70154703052, 70154703053, 70154703054, 70154703055, 70154703056, 70154703057, 70154703058, 70154703059

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/07/20 20:05	

LABORATORY CONTROL SAMPLE: 924799

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.7	105	85-115	

MATRIX SPIKE SAMPLE: 924801

Parameter	Units	70154703040 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	4	5.1	113	70-130	

MATRIX SPIKE SAMPLE: 924803

Parameter	Units	70154703050 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	4	4.7	109	70-130	

SAMPLE DUPLICATE: 924800

Parameter	Units	70154703040 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 924802

Parameter	Units	70154703050 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

QC Batch:	188463	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70154703060, 70154703061, 70154703062, 70154703063, 70154703064, 70154703065, 70154703066, 70154703067, 70154703068, 70154703069, 70154703070, 70154703071, 70154703072, 70154703073, 70154703074, 70154703075, 70154703076		

METHOD BLANK:	924804	Matrix:	Water
Associated Lab Samples:	70154703060, 70154703061, 70154703062, 70154703063, 70154703064, 70154703065, 70154703066, 70154703067, 70154703068, 70154703069, 70154703070, 70154703071, 70154703072, 70154703073, 70154703074, 70154703075, 70154703076		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/07/20 20:57	

LABORATORY CONTROL SAMPLE:	924805					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	53.0	106	85-115	

MATRIX SPIKE SAMPLE:		924807					
		70154703060	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	2.8	4	7.4	114	70-130	

MATRIX SPIKE SAMPLE:		924809					
Parameter	Units	70154703070 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.1	4	5.8	116	70-130	

SAMPLE DUPLICATE: 924806					
		70154703060	Dup		
Parameter	Units	Result	Result	RPD	Qualifiers
Lead	ug/L	2.8	2.8	0	

SAMPLE DUPLICATE: 924808

Parameter	Units	70154703070 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.1	1.1	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

ANALYTE QUALIFIERS

M1 Matrix spike recovery exceeded QC limits. Batch accepted based on laboratory control sample (LCS) recovery.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70154703001	CHE-01-BF-P-115	EPA 200.8	188459		
70154703002	CHE-01-CF-P-116	EPA 200.8	188459		
70154703003	CHE-01-DW-P-117	EPA 200.8	188459		
70154703004	CHE-01-CF-118	EPA 200.8	188459		
70154703005	CHE-01-DW-P-119	EPA 200.8	188459		
70154703006	CHE-01-NF1-P-120	EPA 200.8	188459		
70154703007	CHE-01-NF2-P-121	EPA 200.8	188459		
70154703008	CHE-01-NF3-P-122	EPA 200.8	188459		
70154703009	CHE-01-CF-P-123	EPA 200.8	188459		
70154703010	CHE-01-DW-P-124	EPA 200.8	188459		
70154703011	CHE-01-DW-P-125	EPA 200.8	188459		
70154703012	CHE-01-CF-P-126	EPA 200.8	188459		
70154703013	CHE-01-DW-P-127	EPA 200.8	188459		
70154703014	CHE-01-DW-BF-P-128	EPA 200.8	188459		
70154703015	CHE-01-CF-P-129	EPA 200.8	188459		
70154703016	CHE-01-DW-P-130	EPA 200.8	188459		
70154703017	CHE-01-BF-P-131	EPA 200.8	188459		
70154703018	CHE-01-CF-P-132	EPA 200.8	188459		
70154703019	CHE-01-DW-P-134	EPA 200.8	188459		
70154703020	CHE-01-FS-P-135	EPA 200.8	188460		
70154703021	CHE-01-CF-P-136	EPA 200.8	188460		
70154703022	CHE-01-DW-P-137	EPA 200.8	188460		
70154703023	CHE-01-KF1-P-155	EPA 200.8	188460		
70154703024	CHE-01-KF2-P-139	EPA 200.8	188460		
70154703025	CHE-01-KF3-P-140	EPA 200.8	188460		
70154703026	CHE-01-DW-P-141	EPA 200.8	188460		
70154703027	CHE-01-DW-P-142	EPA 200.8	188460		
70154703028	CHE-01-DW-P-143	EPA 200.8	188460		
70154703029	CHE-01-CF-P-144	EPA 200.8	188460		
70154703030	CHE-01-BF1-P-145	EPA 200.8	188460		
70154703031	CHE-01-BF2-P-146	EPA 200.8	188460		
70154703032	CHE-01-CF-P-147	EPA 200.8	188460		
70154703033	CHE-01-BF2-P-150	EPA 200.8	188460		
70154703034	HE-01-CF-P-151	EPA 200.8	188460		
70154703035	CHE-01-CF-P-152	EPA 200.8	188460		
70154703036	CHE-01-CF-P-154	EPA 200.8	188460		
70154703037	CHE-01-DW-P-155	EPA 200.8	188460		
70154703038	CHE-01-DW-P-156	EPA 200.8	188460		
70154703039	CHE-01-BF1-P-157	EPA 200.8	188460		
70154703040	CHE-01-BF2-P-158	EPA 200.8	188462		
70154703041	CHE-01-BF1-P-159	EPA 200.8	188462		
70154703042	CHE-01-DW-P-161	EPA 200.8	188462		
70154703043	CHE-01-CF-P-162	EPA 200.8	188462		
70154703044	CHE-01-DW-P-163	EPA 200.8	188462		
70154703045	CHE-01-CF-P-164	EPA 200.8	188462		
70154703046	CHE-01-DW-P-165	EPA 200.8	188462		
70154703047	CHE-01-CF-P-166	EPA 200.8	188462		
70154703048	CHE-01-DW-P-167	EPA 200.8	188462		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: ENLARGED SCHOOL OF TROY 11/20

Pace Project No.: 70154703

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70154703049	CHE-01-CF-P-168	EPA 200.8	188462		
70154703050	CHE-01-CF-P-170	EPA 200.8	188462		
70154703051	CHE-01-DW-P-171	EPA 200.8	188462		
70154703052	CHE-01-CF-P-172	EPA 200.8	188462		
70154703053	CHE-01-BF1-P-174	EPA 200.8	188462		
70154703054	CHE-01-BF2-P-175	EPA 200.8	188462		
70154703055	CHE-01-BF1-P-176	EPA 200.8	188462		
70154703056	CHE-02-BF1-P-178	EPA 200.8	188462		
70154703057	CHE-02-BF2-P-179	EPA 200.8	188462		
70154703058	CHE-02-BF1-P-180	EPA 200.8	188462		
70154703059	CHE-02-CF-P-181	EPA 200.8	188462		
70154703060	CHE-02-DW-P-182	EPA 200.8	188463		
70154703061	CHE-02-CF-P-183	EPA 200.8	188463		
70154703062	CHE-02-DW-P-184	EPA 200.8	188463		
70154703063	CHE-02-CF-P-185	EPA 200.8	188463		
70154703064	CHE-02-DW-P-186	EPA 200.8	188463		
70154703065	CHE-02-BF-P-187	EPA 200.8	188463		
70154703066	CHE-02-CF-P-188	EPA 200.8	188463		
70154703067	CHE-02-BF-P-190	EPA 200.8	188463		
70154703068	CHE-02-CF-P-191	EPA 200.8	188463		
70154703069	CHE-02-DW-P-192	EPA 200.8	188463		
70154703070	CHE-02-CF-P-193	EPA 200.8	188463		
70154703071	CHE-02-BF1-P-195	EPA 200.8	188463		
70154703072	CHE-02-BF2-P-196	EPA 200.8	188463		
70154703073	CHE-02-DW-P-197	EPA 200.8	188463		
70154703074	CHE-02-BF1-P-198	EPA 200.8	188463		
70154703075	CHE-02-BF2-P-199	EPA 200.8	188463		
70154703076	CHE-01-CF-P-133A	EPA 200.8	188463		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

Appendix D

Page 1 of 4

CLIENT INFORMATION

Name:	Enlarged City School District of Troy
Address:	475 First Street Troy NY 12180
Client Rep:	Bob Garland

Date of Sampling:	11/20/20
Samples Taken By:	Tim LeVan
Samples Taken By:	Barry Cox

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Carroll Hill Elementary
BLDG ADDRESS:	112 Delaware Ave Troy NY 12180
CONTACT NAME & NUMBERS:	Bob Garland 518-328-5426

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:
1965	1968			

WO#: 70154703



70154703

SAMPLE DATA

Sample Description ID (ID must match container label)

Inlet Information			Outlet Information			Service Connection				
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	30 Second Flush Draw	Time of Collection (24hr)	Time of Collection (24hr)
115	CHE-01-BF-P-115	Principal Bathroom	Sink			X	5:31			
116	CHE-01-CF-P-116	Rm 7	Sink			X	5:32			
117	CHE-01-DW-P-117	Rm 7	Water fountain			X	5:33			
118	CHE-01-CF-P-118	Rm 6	Sink			X	5:34			
119	CHE-01-DW-P-119	Rm 6	Water fountain			X	5:36			
120	CHE-01-NF1-P-120	Nurses office	Sink 1			X	5:36			
121	CHE-01-NF2-P-121	Nurses office	Sink 2			X	5:36			
122	CHE-01-NF3-P-122	Nurses office	Sink 3			X	5:38			
123	CHE-01-CF-P-123	Rm 5	Sink			X	5:38			
124	CHE-01-DW-P-124	Rm 5	Water fountain			X	5:38			
125	CHE-01-DW-P-125	Corridor	Water Fountain			X	5:39			
126	CHE-01-CF-P-126	Rm 4	Sink			X	5:39			
127	CHE-01-DW-P-127	Rm 4	Water fountain			X	5:40			
128	CHE-01-BF-P-128	Womens room	Sink			X	5:41			
129	CHE-01-CF-P-129	Rm 3	Sink			X	5:41			
130	CHE-01-DW-P-130	Rm 3	Water fountain			X	5:41			
131	CHE-01-BF-P-131	Mens room	Sink			X	5:43			
132	CHE-01-CF-P-132	Rm 2	Sink			X	5:44			
133	CHE-01-DW-P-133	Rm 2	Water fountain			X	Off due to COVID 19 No sample			
134	CHE-01-DW-P-134	Rm 2 outside exit	Water fountain 2			X	5:47			
135	CHE-01-FS-P-135	Faculty lounge	Sink			X	5:48			
136	CHE-01-CF-P-136	Rm 1	Sink			X	5:49			
137	CHE-01-DW-P-137	Rm 1	Water fountain			X	5:49			
138	CHE-01-KF1-P-155	Kitchen	Sink 1			X	5:57			

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:
Tim LeVan	Barry Cox	9:11	11/20/20

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab: Pace Analytical

CLIENT INFORMATION

Name:	Enlarged City School District of Troy
Address:	475 First Street Troy NY 12180
Client Rep:	Bob Garland

Date of Sampling:	11/20/2020
Samples Taken By:	Tim LeVan
Samples Taken By:	Barry Cox

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Carroll Hill Elementary
BLDG ADDRESS:	112 Delaware Ave Troy NY 12180
CONTACT NAME & NUMBERS:	Bob Garland 518-328-5426

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:
1965	1968			

SAMPLE DATA

Sample Description ID (ID must match container label)													
Outlet Information													
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	30 Second Flush Draw	Time of Collection (24hr)	Service Connection Draw	Time of Collection (24hr)	Water Main Draw	Time of Collection (24hr)
139	CHE-01-KF2-P-139	Kitchen	Sink 2			X	5:51						
140	CHE-01-KF3-P-140	Kitchen	Sink3			X	5:51						
141	CHE-01-DW-P-141	Lobby	Water fountain			X	5:53						
142	CHE-01-CF-P-142	Rm 8	Sink			X	5:54						
143	CHE-01-DW-P-143	Rm 8	Water fountain			X	5:54						
144	CHE-01-CF-P-144	Rm 9	Sink			X	5:56						
145	CHE-01-BF1-P-145	Girls room	Sink 1			X	5:57						
146	CHE-01-BF2-P-146	Girls room	Sink 2			X	5:57						
147	CHE-01-CF-P-147	Rm 10	Sink			X	5:58						
148	CHE-01-DW-P-148	Rm 10	Water fountain			X	Off due to COVID 19 No sample						
149	CHE-01-BF1-P-149	Boys room	Sink 1			X	Not Working, No sample						
150	CHE-01-BF2-P-150	Boys room	Sink 2			X	5:59						
151	CHE-01-CF-P-151	Library office	Sink			X	6:01						
152	CHE-01-CF-P-152	Rm 11	Sink			X	6:01						
153	CHE-01-DW-P-153	Rm 11	Water fountain			X	Off due to COVID 19 No sample						
154	CHE-01-CF-P-154	Rm 12	Sink			X	6:02						
155	CHE-01-DW-P-155	Rm 12	Water fountain			X	6:02						
156	CHE-01-DW-P-156	Girls Locker Rm	Water fountain			X	6:04						
157	CHE-01-BF1-P-157	Girls room	Sink 1			X	6:04						
158	CHE-01-BF2-P-158	Girls room	Sink 2			X	6:04						
159	CHE-01-BF1-P-159	Boys room	Sink 1			X	6:05						
160	CHE-01-BF2-P-160	Boys room	Sink 2			X	Not Working, No sample						
161	CHE-01-DW-P-161	Corridor	Water fountain			X	6:06						
162	CHE-01-CF-P-162	Rm 13	Sink			X	6:07						

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:
<i>Tim LeVan</i>	<i>Barry Cox</i>	9:11	11/20/20

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab: PACE Analytical

Page 87 of 90

Contact:

Comments: Provide Laboratory Data Report (LDR) and Chain of Custody

CLIENT INFORMATION

Name:	Enlarged City School District of Troy
Address:	475 First Street Troy NY 12180
Client Rep:	Bob Garland

Date of Sampling:	11/20/2020
Samples Taken By:	Tim LeVan
Samples Taken By:	Barry Cox

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Carroll Hill Elementary
BLDG ADDRESS:	112 Delaware Ave Troy NY 12180
CONTACT NAME & NUMBERS:	Bob Garland 518-328-5426

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr 2nd Mod:
1965	1968			

SAMPLE DATA

Sample Description ID (ID must match container label)										Outlet Information			
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	30 Second Flush Draw	Time of Collection (24hr)	Service Connection Draw	Time of Collection (24hr)	Water Main Draw	Time of Collection (24hr)
163	CHE-01-DW-P-163	Rm 13	Water fountain			X	6:07						
164	CHE-01-CF-P-164	Rm 14	Sink			X	6:08						
165	CHE-01-DW-P-165	Rm 14	Water fountain			X	6:08						
166	CHE-01-CF-P-166	Rm 15	Sink			X	6:09						
167	CHE-01-DW-P-167	Rm 15	Water fountain			X	6:09						
168	CHE-01-CF-P-168	Rm 16	Sink			X	6:11						
169	CHE-01-DW-P-169	Rm 16	Water fountain			X	Off due to COVID 19 No Sample						
170	CHE-01-CF-P-170	Rm 17	Sink			X	6:12						
171	CHE-01-DW-P-171	Rm 17	Water fountain			X	6:12						
172	CHE-01-CF-P-172	Rm 18	Sink			X	6:13						
173	CHE-01-DW-P-173	Rm 18	Water fountain			X	Off due to COVID 19 No Sample						
174	CHE-01-BF1-P-174	Boys room	Sink 1			X	6:14						
175	CHE-01-BF2-P-175	Boys room	Sink 2			X	6:14						
176	CHE-01-BF1-P-176	Girls room	Sink 1			X	6:16						
177	CHE-01-BF2-P-177	Girls room	Sink 2			X	Not working, No Sample						
178	CHE-02-BF1-P-178	Girls room	Sink 1			X	6:19						
179	CHE-02-BF2-P-179	Girls room	Sink 2			X	6:19						
180	CHE-02-BF1-P-180	Boys room	Sink 1			X	6:19						
181	CHE-02-CF-P-181	Rm 24	Sink			X	6:20						
182	CHE-02-DW-P-182	Rm 24	Water fountain			X	6:20						
183	CHE-02-CF-P-183	Rm 23	Sink			X	6:21						
184	CHE-02-DW-P-184	Rm 23	Water fountain			X	6:21						
185	CHE-02-CF-P-185	Rm 22	Sink			X	6:23						
186	CHE-02-DW-P-186	Rm 22	Water fountain			X	6:23						

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:
<i>Tim LeVan</i>	<i>Barry Cox</i>	9:11	11/20/20

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

LAB: PACE Analytical

Lab # 880

Contact:

Comments: Provide Laboratory Data Report (LDR) and Chain of Custody

CLIENT INFORMATION

Name:	Enlarged City School District of Troy
Address:	475 First Street Troy NY 12180
Client Rep:	Bob Garland

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Carroll Hill Elementary
BLDG ADDRESS:	112 Delaware Ave Troy NY 12180
CONTACT NAME & NUMBERS:	Bob Garland 518-328-5426

(1) Yr. Buil	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:
1965	1968			

SAMPLE DATA

[illegible]

Outlet Information

[illegible]

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:
<i>Tim Wilson</i>	<i>[Signature]</i>	9:11	11/20/20
<i>[Signature]</i>	<i>[Signature]</i>	10:45	11/24/20

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (pb)

Lab PACF Analytical

8

39

of

Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	
---	--

Date of Sampling: 11/20/2020
Samples Taken By: Tim LeVan
Samples Taken By: Barry Cox

WO#: 70154703

PM: NML
Due Date: 12/10/20

CLIENT: QUESTAR

Sample Condition Upon Receipt

Pace Analytical

Client Name:

Project

MO#: 70154703

PM: NML

Due Date: 12/10/20

CLIENT: QUESTAR

Courier: ☐ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ Other

Tracking #: 9099 9901 1503

Custody Seal on Cooler/Box Present: ☒ Yes ☐ No

Packing Material: ☒ Bubble Wrap ☐ Bubble Bags ☐ Ziploc ☐ None ☐ Other

Thermometer Used: TH091

Correction Factor: -0.2

Cooler Temperature (°C): 20.3

Date/Time 5035A kits placed in freezer

Samples on ice, cooling process has begun

Temperature Blank Present: ☐ Yes ☒ No

Type of Ice: Wet Blue ☒ None

Date and Initials of person examining contents:

USDA Regulated Soil (☐ N/A, water sample)

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? ☐ YES ☒ NO

Did samples originate from a foreign source (internationally, including Hawaii and Puerto Rico)? ☐ Yes ☒ No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

Chain of Custody Present:	☒ Yes ☐ No	1.
Chain of Custody Filled Out:	☒ Yes ☐ No	2.
Chain of Custody Relinquished:	☒ Yes ☐ No	3.
Sampler Name & Signature on COC:	☒ Yes ☐ No ☐ N/A	4.
Samples Arrived within Hold Time:	☒ Yes ☐ No	5.
Short Hold Time Analysis (<72hr):	☒ Yes ☐ No	6.
Rush Turn Around Time Requested:	☒ Yes ☐ No	7.
Sufficient Volume: (Triple volume provided for MS/MSD)	☒ Yes ☐ No	8.
Correct Containers Used:	☒ Yes ☐ No	9.
-Pace Containers Used:	☒ Yes ☐ No	10.
Containers Intact:	☒ Yes ☐ No	11.
Filtered volume received for Dissolved tests	☒ Yes ☐ No ☐ N/A	12.
Sample Labels match COC:	☒ Yes ☐ No	13.
-Includes date/time/ID/Analysis Matrix SL WT OIL	☒ Yes ☐ No ☐ N/A	14.
All containers needing preservation have been checked	☒ Yes ☐ No ☐ N/A	15.
pH paper Lot #	MC904195	16.
All containers needing preservation are found to be in compliance with EPA recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH>9 Sulfide, NaOH>12 Cyanide)	☒ Yes ☐ No ☐ N/A	17.
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water), Per Method, VOA pH is checked after analysis		18.
Samples checked for dechlorination:	☒ Yes ☐ No ☐ N/A	19.
KI starch test strips Lot #		20.
Residual chlorine strips Lot #		21.
Headspace in VOA Vials (>6mm):	☒ Yes ☐ No ☐ N/A	22.
Trip Blank Present:	☒ Yes ☐ No ☐ N/A	23.
Trip Blank Custody Seals Present	☒ Yes ☐ No ☐ N/A	24.
Pace Trip Blank Lot # (if applicable):		25.

Client Notification/ Resolution:

Field Data Required?

Y / N

Person Contacted:

Comments/ Resolution:

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

Appendix D

Page 1 of 4

CLIENT INFORMATION

Name:	Enlarged City School District of Troy
Address:	475 First Street Troy NY 12180
Client Rep:	Bob Garland

Date of Sampling:	11/20/20
Samples Taken By:	Tim LeVan
Samples Taken By:	Barry Cox

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Carroll Hill Elementary
BLDG ADDRESS:	112 Delaware Ave Troy NY 12180
CONTACT NAME & NUMBERS:	Bob Garland 518-328-5426

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:
1965	1968			

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information						
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Lead test Results ug/L from	Lead test Results ug/L from	Lead test Results ug/L from	Remediation
115	CHE-01-BF-P-115	Principal Bathroom	Sink			X	5.2			
116	CHE-01-CF-P-116	Rm 7	Sink			X	7.1			
117	CHE-01-DW-P-117	Rm 7	Water fountain			X	17.7			Turned off for repair
118	CHE-01-CF-P-118	Rm 6	Sink			X	13.5			
119	CHE-01-DW-P-119	Rm 6	Water fountain			X	38.0			Turned off for repair
120	CHE-01-NF1-P-120	Nurses office	Sink 1			X	2.0			
121	CHE-01-NF2-P-121	Nurses office	Sink 2			X	13.2			
122	CHE-01-NF3-P-122	Nurses office	Sink 3			X	6.3			
123	CHE-01-CF-P-123	Rm 5	Sink			X	1.1			
124	CHE-01-DW-P-124	Rm 5	Water fountain			X	4.8			
125	CHE-01-DW-P-125	Corridor	Water Fountain			X	69.0			Turned off for repair
126	CHE-01-CF-P-126	Rm 4	Sink			X	5.6			
127	CHE-01-DW-P-127	Rm 4	Water fountain			X	15.1			Turned off for repair
128	CHE-01-BF-P-128	Womens room	Sink			X	2.9			
129	CHE-01-CF-P-129	Rm 3	Sink			X	2.1			
130	CHE-01-DW-P-130	Rm 3	Water fountain			X	15.8			Turned off for repair
131	CHE-01-BF-P-131	Mens room	Sink			X	1.9			
132	CHE-01-CF-P-132	Rm 2	Sink			X	2.1			
133	CHE-01-DW-P-133	Rm 2	Water fountain			X	Off due to COVID 19 No sample			
134	CHE-01-DW-P-134	Rm 2 outside exit	Water fountain 2			X	117			Turned off for repair
135	CHE-01-FS-P-135	Faculty lounge	Sink			X	3.8			
136	CHE-01-CF-P-136	Rm 1	Sink			X	2.2			
137	CHE-01-DW-P-137	Rm 1	Water fountain			X	<1.0			
138	CHE-01-KF1-P-155	Kitchen	Sink 1			X	<1.0			

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be f T

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab: Pace Analytical	
Contact:	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
CHE-01-BF-P-115	11/20/2020 05:31	12/7/2020 18:37	70154703001	Lead	5.2	15	ug/L
CHE-01-CF-P-116	11/20/2020 05:32	12/7/2020 18:38	70154703002	Lead	7.1	15	ug/L
CHE-01-DW-P-117	11/20/2020 05:33	12/7/2020 18:40	70154703003	Lead	17.7	15	ug/L
CHE-01-CF-P-118	11/20/2020 05:34	12/7/2020 18:42	70154703004	Lead	13.5	15	ug/L
CHE-01-DW-P-119	11/20/2020 05:36	12/7/2020 18:43	70154703005	Lead	38.0	15	ug/L
CHE-01-NF1-P-120	11/20/2020 05:36	12/7/2020 18:45	70154703006	Lead	2.0	15	ug/L
CHE-01-NF2-P-121	11/20/2020 05:36	12/7/2020 18:46	70154703007	Lead	13.2	15	ug/L
CHE-01-NF3-P-122	11/20/2020 05:38	12/7/2020 18:48	70154703008	Lead	6.3	15	ug/L
CHE-01-CF-P-123	11/20/2020 05:38	12/7/2020 18:50	70154703009	Lead	1.1	15	ug/L
CHE-01-DW-P-124	11/20/2020 05:38	12/7/2020 18:51	70154703010	Lead	4.8	15	ug/L
CHE-01-DW-P-125	11/20/2020 05:39	12/7/2020 18:59	70154703011	Lead	69.0	15	ug/L
CHE-01-CF-P-126	11/20/2020 05:39	12/7/2020 19:01	70154703012	Lead	5.6	15	ug/L
CHE-01-DW-P-127	11/20/2020 05:39	12/7/2020 19:02	70154703013	Lead	15.1	15	ug/L
CHE-01-DW-BF-P-128	11/20/2020 05:40	12/7/2020 19:04	70154703014	Lead	2.9	15	ug/L
CHE-01-CF-P-129	11/20/2020 05:41	12/7/2020 19:06	70154703015	Lead	2.1	15	ug/L
CHE-01-DW-P-130	11/20/2020 05:41	12/7/2020 19:07	70154703016	Lead	15.8	15	ug/L
CHE-01-BF-P-131	11/20/2020 05:43	12/7/2020 19:09	70154703017	Lead	1.9	15	ug/L
CHE-01-CF-P-132	11/20/2020 05:44	12/7/2020 19:11	70154703018	Lead	2.1	15	ug/L
CHE-01-DW-P-134	11/20/2020 05:47	12/7/2020 19:15	70154703019	Lead	117	15	ug/L
CHE-01-FS-P-135	11/20/2020 05:48	12/7/2020 19:20	70154703020	Lead	3.8	15	ug/L
CHE-01-CF-P-136	11/20/2020 05:49	12/7/2020 19:25	70154703021	Lead	2.2	15	ug/L
CHE-01-DW-P-137	11/20/2020 05:51	12/7/2020 19:27	70154703022	Lead	<1.0	15	ug/L
CHE-01-KF1-P-155	11/20/2020 05:51	12/7/2020 19:28	70154703023	Lead	<1.0	15	ug/L
CHE-01-KF2-P-139	11/20/2020 05:51	12/7/2020 19:30	70154703024	Lead	1.1	15	ug/L
CHE-01-KF3-P-140	11/20/2020 05:51	12/7/2020 19:35	70154703025	Lead	<1.0	15	ug/L
CHE-01-DW-P-141	11/20/2020 05:53	12/7/2020 19:36	70154703026	Lead	<1.0	15	ug/L
CHE-01-DW-P-142	11/20/2020 05:54	12/7/2020 19:38	70154703027	Lead	9.5	15	ug/L
CHE-01-DW-P-143	11/20/2020 05:54	12/7/2020 19:39	70154703028	Lead	12.6	15	ug/L
CHE-01-CF-P-144	11/20/2020 05:57	12/7/2020 19:41	70154703029	Lead	<1.0	15	ug/L
CHE-01-BF1-P-145	11/20/2020 05:57	12/7/2020 19:43	70154703030	Lead	<1.0	15	ug/L
CHE-01-BF2-P-146	11/20/2020 05:58	12/7/2020 19:48	70154703031	Lead	<1.0	15	ug/L
CHE-01-CF-P-147	11/20/2020 05:59	12/7/2020 19:49	70154703032	Lead	5.0	15	ug/L
CHE-01-BF2-P-150	11/20/2020 06:01	12/7/2020 19:54	70154703033	Lead	<1.0	15	ug/L
HE-01-CF-P-151	11/20/2020 06:01	12/7/2020 19:56	70154703034	Lead	1.8	15	ug/L
CHE-01-CF-P-152	11/20/2020 06:02	12/7/2020 19:57	70154703035	Lead	22.5	15	ug/L
CHE-01-CF-P-154	11/20/2020 06:02	12/7/2020 19:59	70154703036	Lead	4.2	15	ug/L
CHE-01-DW-P-155	11/20/2020 06:04	12/7/2020 20:00	70154703037	Lead	5.1	15	ug/L
CHE-01-DW-P-156	11/20/2020 06:04	12/7/2020 20:02	70154703038	Lead	13.2	15	ug/L
CHE-01-BF1-P-157	11/20/2020 06:04	12/7/2020 20:04	70154703039	Lead	<1.0	15	ug/L
CHE-01-BF2-P-158	11/20/2020 06:05	12/7/2020 20:08	70154703040	Lead	<1.0	15	ug/L
CHE-01-BF1-P-159	11/20/2020 06:06	12/7/2020 20:16	70154703041	Lead	<1.0	15	ug/L
CHE-01-DW-P-161	11/20/2020 06:07	12/7/2020 20:18	70154703042	Lead	<1.0	15	ug/L
CHE-01-CF-P-162	11/20/2020 06:07	12/7/2020 20:20	70154703043	Lead	<1.0	15	ug/L
CHE-01-DW-P-163	11/20/2020 06:07	12/7/2020 20:21	70154703044	Lead	8.3	15	ug/L
CHE-01-CF-P-164	11/20/2020 06:08	12/7/2020 20:23	70154703045	Lead	34.6	15	ug/L
CHE-01-DW-P-165	11/20/2020 06:08	12/7/2020 20:25	70154703046	Lead	<1.0	15	ug/L
CHE-01-CF-P-166	11/20/2020 06:09	12/7/2020 20:26	70154703047	Lead	<1.0	15	ug/L
CHE-01-DW-P-167	11/20/2020 06:09	12/7/2020 20:28	70154703048	Lead	<1.0	15	ug/L
CHE-01-CF-P-168	11/20/2020 06:11	12/7/2020 20:33	70154703049	Lead	4.8	15	ug/L
CHE-01-CF-P-170	11/20/2020 06:12	12/7/2020 20:34	70154703050	Lead	<1.0	15	ug/L

CHE-01-DW-P-171	11/20/2020 06:12	12/7/2020 20:39	70154703051	Lead	<1.0	15	ug/L
CHE-01-CF-P-172	11/20/2020 06:13	12/7/2020 20:41	70154703052	Lead	<1.0	15	ug/L
CHE-01-BF1-P-174	11/20/2020 06:14	12/7/2020 20:42	70154703053	Lead	<1.0	15	ug/L
CHE-01-BF2-P-175	11/20/2020 06:14	12/7/2020 20:44	70154703054	Lead	<1.0	15	ug/L
CHE-01-BF1-P-176	11/20/2020 06:16	12/7/2020 20:46	70154703055	Lead	<1.0	15	ug/L
CHE-02-BF1-P-178	11/20/2020 06:19	12/7/2020 20:47	70154703056	Lead	1.1	15	ug/L
CHE-02-BF2-P-179	11/20/2020 06:19	12/7/2020 20:52	70154703057	Lead	<1.0	15	ug/L
CHE-02-BF1-P-180	11/20/2020 06:19	12/7/2020 20:54	70154703058	Lead	<1.0	15	ug/L
CHE-02-CF-P-181	11/20/2020 06:20	12/7/2020 20:55	70154703059	Lead	8.5	15	ug/L
CHE-02-DW-P-182	11/20/2020 06:20	12/7/2020 21:00	70154703060	Lead	2.8	15	ug/L
CHE-02-CF-P-183	11/20/2020 06:21	12/7/2020 21:05	70154703061	Lead	<1.0	15	ug/L
CHE-02-DW-P-184	11/20/2020 06:21	12/7/2020 21:07	70154703062	Lead	1.3	15	ug/L
CHE-02-CF-P-185	11/20/2020 06:23	12/7/2020 21:11	70154703063	Lead	1.2	15	ug/L
CHE-02-DW-P-186	11/20/2020 06:23	12/7/2020 21:13	70154703064	Lead	13.5	15	ug/L
CHE-02-BF-P-187	11/20/2020 06:25	12/7/2020 21:15	70154703065	Lead	2.0	15	ug/L
CHE-02-CF-P-188	11/20/2020 06:25	12/7/2020 21:16	70154703066	Lead	1.3	15	ug/L
CHE-02-BF-P-190	11/20/2020 06:27	12/7/2020 21:18	70154703067	Lead	2.0	15	ug/L
CHE-02-CF-P-191	11/20/2020 06:27	12/7/2020 21:19	70154703068	Lead	1.3	15	ug/L
CHE-02-DW-P-192	11/20/2020 06:27	12/7/2020 21:21	70154703069	Lead	2.0	15	ug/L
CHE-02-CF-P-193	11/20/2020 06:28	12/7/2020 21:23	70154703070	Lead	1.3	15	ug/L
CHE-02-BF1-P-195	11/20/2020 06:29	12/7/2020 21:31	70154703071	Lead	<1.0	15	ug/L
CHE-02-BF2-P-196	11/20/2020 06:29	12/7/2020 21:32	70154703072	Lead	<1.0	15	ug/L
CHE-02-DW-P-197	11/20/2020 06:30	12/7/2020 21:34	70154703073	Lead	4.7	15	ug/L
CHE-02-BF1-P-198	11/20/2020 06:30	12/7/2020 21:36	70154703074	Lead	<1.0	15	ug/L
CHE-02-BF2-P-199	11/20/2020 06:30	12/7/2020 21:37	70154703075	Lead	<1.0	15	ug/L
CHE-01-CF-P-133A	11/20/2020 05:45	12/7/2020 21:39	70154703076	Lead	80.5	15	ug/L

NYSDOH Action Level for Lead of 15 ppb