

December 16, 2020

Paul Swieton
Rensselaer-Columbia-Greene Counties and
BOCES
10 Empire State Blvd.
Fl 2
Castleton On Hudson, NY 12033

RE: Project: ENLARGED CITY SCHOOL DIST 12/4
Pace Project No.: 70155846

Dear Paul Swieton:

Enclosed are the analytical results for sample(s) received by the laboratory on December 08, 2020. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Nicolette M. Lovari
nicolette.lovari@pacelabs.com
(631)694-3040
Project Manager

Enclosures

cc: Robert Garland, Troy City SD
Tim LeVan, Questar III



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Pace Analytical Services Long Island

575 Broad Hollow Rd, Melville, NY 11747

New York Certification #: 10478 Primary Accrediting Body

New Jersey Certification #: NY158

Pennsylvania Certification #: 68-00350

Connecticut Certification #: PH-0435

Maryland Certification #: 208

Rhode Island Certification #: LAO00340

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-01-CF-P-302		Lab ID: 70155846001	Collected: 12/04/20 05:00	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.4	ug/L	1.0	1		12/14/20 17:25	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-01-DW-P-303		Lab ID: 70155846002	Collected: 12/04/20 05:00	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.1	ug/L	1.0	1		12/14/20 17:26	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-01-CF-P-304		Lab ID: 70155846003	Collected: 12/04/20 05:04	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.0	ug/L	1.0	1		12/14/20 17:29	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-01-DW-P-305		Lab ID: 70155846004	Collected: 12/04/20 05:04	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.5	ug/L	1.0	1		12/14/20 17:30	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-01-KF1-P-306		Lab ID: 70155846005	Collected: 12/04/20 05:08	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	6.4	ug/L	1.0	1		12/14/20 17:31	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-01-KF2-P-308		Lab ID: 70155846006	Collected: 12/04/20 05:08	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.4	ug/L	1.0	1		12/14/20 17:32	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-01-KF3-P-309		Lab ID: 70155846007	Collected: 12/04/20 05:09	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.0	ug/L	1.0	1		12/14/20 17:33	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-01-DW-P-310		Lab ID: 70155846008	Collected: 12/04/20 05:06	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/14/20 17:33	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-01-DW-P-311		Lab ID: 70155846009	Collected: 12/04/20 05:06	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/14/20 17:34	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-01-CF-P-312		Lab ID: 70155846010	Collected: 12/04/20 05:10	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/14/20 17:35	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-01-DW-P-313		Lab ID: 70155846011	Collected: 12/04/20 05:10	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.2	ug/L	1.0	1		12/14/20 17:40	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-01-CF-P-314		Lab ID: 70155846012	Collected: 12/04/20 05:12	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.1	ug/L	1.0	1		12/14/20 17:41	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-01-DW-P-315		Lab ID: 70155846013	Collected: 12/04/20 05:12	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.6	ug/L	1.0	1		12/14/20 17:42	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-01-CF-P-316		Lab ID: 70155846014	Collected: 12/04/20 05:14	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.7	ug/L	1.0	1		12/14/20 17:43	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-01-DW-P-317		Lab ID: 70155846015	Collected: 12/04/20 05:14	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.0	ug/L	1.0	1		12/14/20 17:44	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-01-BF-P-318		Lab ID: 70155846016	Collected: 12/04/20 05:17	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.8	ug/L	1.0	1		12/14/20 17:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-01-BF-P-319		Lab ID: 70155846017	Collected: 12/04/20 05:17	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	10.8	ug/L	1.0	1		12/14/20 17:46	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-01-CF-P-320		Lab ID: 70155846018	Collected: 12/04/20 05:18	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.7	ug/L	1.0	1		12/14/20 17:47	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-01-DW-P-321		Lab ID: 70155846019	Collected: 12/04/20 05:18	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.9	ug/L	1.0	1		12/14/20 17:48	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-01-BF-P-322		Lab ID: 70155846020	Collected: 12/04/20 05:21	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/14/20 17:53	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-02-BF-P-323		Lab ID: 70155846021	Collected: 12/04/20 05:21	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/14/20 17:55	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-03-BF-P-324		Lab ID: 70155846022	Collected: 12/04/20 05:21	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/14/20 17:56	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-04-BF-P-325		Lab ID: 70155846023	Collected: 12/04/20 05:20	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/14/20 17:57	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-01-DW-P-326		Lab ID: 70155846024	Collected: 12/04/20 05:23	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/14/20 17:58	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-01-BF-P-327		Lab ID: 70155846025	Collected: 12/04/20 05:25	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/14/20 17:59	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-B-DW-P-329		Lab ID: 70155846026	Collected: 12/04/20 05:27	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	127	ug/L	1.0	1		12/14/20 18:00	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-01-DW-P-330		Lab ID: 70155846027	Collected: 12/04/20 05:28	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	54.6	ug/L	1.0	1		12/14/20 18:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-01-BF-P-332		Lab ID: 70155846028	Collected: 12/04/20 05:30	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	6.0	ug/L	1.0	1		12/14/20 18:04	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-01-BF-P-333		Lab ID: 70155846029	Collected: 12/04/20 05:32	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.2	ug/L	1.0	1		12/14/20 18:05	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-01-DW-P-335		Lab ID: 70155846030	Collected: 12/04/20 05:33	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/14/20 18:06	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-01-BF1-P-336		Lab ID: 70155846031	Collected: 12/04/20 05:36	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/14/20 18:09	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-01-BF2-P-337		Lab ID: 70155846032	Collected: 12/04/20 05:34	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/14/20 18:10	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-01-CF-P-338		Lab ID: 70155846033	Collected: 12/04/20 05:37	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/14/20 18:11	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-02-BF1-P-340		Lab ID: 70155846034	Collected: 12/04/20 05:40	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.1	ug/L	1.0	1		12/14/20 18:12	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-02-BF2-P-341		Lab ID: 70155846035	Collected: 12/04/20 05:40	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/14/20 18:14	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-02-BF3-P-342		Lab ID: 70155846036	Collected: 12/04/20 05:40	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/14/20 18:15	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-02-DW-P-343		Lab ID: 70155846037	Collected: 12/04/20 05:41	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.2	ug/L	1.0	1		12/14/20 18:16	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-02-BF-P-344		Lab ID: 70155846038	Collected: 12/04/20 05:43	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	9.8	ug/L	1.0	1		12/14/20 18:17	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-02-CF-P-345		Lab ID: 70155846039	Collected: 12/04/20 05:44	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.9	ug/L	1.0	1		12/14/20 18:18	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-02-BF-P-346		Lab ID: 70155846040	Collected: 12/04/20 05:45	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.5	ug/L	1.0	1		12/14/20 18:21	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-02-DW-P-347		Lab ID: 70155846041	Collected: 12/04/20 05:46	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/14/20 18:26	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-02-DW-P-348		Lab ID: 70155846042	Collected: 12/04/20 05:48	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/14/20 18:27	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-02-BF1-P-349		Lab ID: 70155846043	Collected: 12/04/20 05:49	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/14/20 18:28	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-02-BF2-P-350		Lab ID: 70155846044	Collected: 12/04/20 05:50	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		12/14/20 18:29	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-02-BF3-P-351		Lab ID: 70155846045	Collected: 12/04/20 05:50	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/14/20 18:30	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-02-BF4-P-352		Lab ID: 70155846046	Collected: 12/04/20 05:51	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/14/20 18:31	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-02-DW-P-353		Lab ID: 70155846047	Collected: 12/04/20 05:52	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	23.0	ug/L	1.0	1		12/14/20 18:32	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-02-BF-P-354		Lab ID: 70155846048	Collected: 12/04/20 05:54	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/14/20 18:33	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-02-BF-P-355		Lab ID: 70155846049	Collected: 12/04/20 05:54	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/14/20 18:33	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-02-CF-P-356		Lab ID: 70155846050	Collected: 12/04/20 05:56	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.2	ug/L	1.0	1		12/14/20 18:34	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-02-DW-P-357		Lab ID: 70155846051	Collected: 12/04/20 05:56	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	10.9	ug/L	1.0	1		12/14/20 18:39	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-02-CF-P-358		Lab ID: 70155846052	Collected: 12/04/20 05:57	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	10.3	ug/L	1.0	1		12/14/20 18:40	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-02-DW-P-359		Lab ID: 70155846053	Collected: 12/04/20 05:57	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	14.3	ug/L	1.0	1		12/14/20 18:41	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-02-CF-P-360		Lab ID: 70155846054	Collected: 12/04/20 05:59	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.6	ug/L	1.0	1		12/14/20 18:42	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-02-DW-P-361		Lab ID: 70155846055	Collected: 12/04/20 05:59	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.0	ug/L	1.0	1		12/14/20 18:43	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-02-CF-P-364		Lab ID: 70155846056	Collected: 12/04/20 06:01	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	6.6	ug/L	1.0	1		12/14/20 18:44	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-02-CF-P-366		Lab ID: 70155846057	Collected: 12/04/20 06:02	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.7	ug/L	1.0	1		12/14/20 18:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-02-DW-P-367		Lab ID: 70155846058	Collected: 12/04/20 06:02	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	6.3	ug/L	1.0	1		12/14/20 18:46	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-02-CF-P-370		Lab ID: 70155846059	Collected: 12/04/20 06:05	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	391	ug/L	1.0	1		12/14/20 18:49	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-02-DW-P-371		Lab ID: 70155846060	Collected: 12/04/20 06:05	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	161	ug/L	1.0	1		12/14/20 18:51	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-03-OF-P-372		Lab ID: 70155846061	Collected: 12/04/20 06:10	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.2	ug/L	1.0	1		12/14/20 18:54	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-03-DW-P-373		Lab ID: 70155846062	Collected: 12/04/20 06:10	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.1	ug/L	1.0	1		12/14/20 18:55	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-03-OF-P-374		Lab ID: 70155846063	Collected: 12/04/20 06:12	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	19.5	ug/L	1.0	1		12/14/20 18:56	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-03-DW-P-375		Lab ID: 70155846064	Collected: 12/04/20 06:12	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.6	ug/L	1.0	1		12/14/20 18:57	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-03-OF-P-376		Lab ID: 70155846065	Collected: 12/04/20 06:13	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	10.8	ug/L	1.0	1		12/14/20 19:00	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-03-OF-P-378		Lab ID: 70155846066	Collected: 12/04/20 06:15	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	8.6	ug/L	1.0	1		12/14/20 19:01	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-03-DW-P-379		Lab ID: 70155846067	Collected: 12/04/20 06:15	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.6	ug/L	1.0	1		12/14/20 19:02	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-03-OF-P-380		Lab ID: 70155846068	Collected: 12/04/20 06:17	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	12.3	ug/L	1.0	1		12/14/20 19:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-03-DW-P-381		Lab ID: 70155846069	Collected: 12/04/20 06:17	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.7	ug/L	1.0	1		12/14/20 19:04	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-03-OF-P-382		Lab ID: 70155846070	Collected: 12/04/20 06:19	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	9.0	ug/L	1.0	1		12/14/20 19:05	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-03-DW-P-383		Lab ID: 70155846071	Collected: 12/04/20 06:19	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	12.4	ug/L	1.0	1		12/14/20 19:08	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-03-OF-P-384		Lab ID: 70155846072	Collected: 12/04/20 06:21	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.1	ug/L	1.0	1		12/14/20 19:09	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-03-DW-P-385		Lab ID: 70155846073	Collected: 12/04/20 06:21	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	6.8	ug/L	1.0	1		12/14/20 19:12	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-03-DW-P-386		Lab ID: 70155846074	Collected: 12/04/20 06:23	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	21.3	ug/L	1.0	1		12/14/20 19:13	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-03-BF1-P-389		Lab ID: 70155846075	Collected: 12/04/20 06:25	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.4	ug/L	1.0	1		12/14/20 19:14	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-03-BF2-P-390		Lab ID: 70155846076	Collected: 12/04/20 06:25	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		12/14/20 19:14	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-03-BF1-P-391		Lab ID: 70155846077	Collected: 12/04/20 06:27	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/14/20 19:15	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-03-BF2-P-392		Lab ID: 70155846078	Collected: 12/04/20 06:28	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/14/20 19:16	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-03-BF3-P-393		Lab ID: 70155846079	Collected: 12/04/20 06:29	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/14/20 19:17	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-03-DW-P-395		Lab ID: 70155846080	Collected: 12/04/20 06:30	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/14/20 19:20	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-03-DW-P-396		Lab ID: 70155846081	Collected: 12/04/20 06:30	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/14/20 19:25	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-03-BF-P-397		Lab ID: 70155846082	Collected: 12/04/20 06:31	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.9	ug/L	1.0	1		12/14/20 19:26	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-03-SF-P-398		Lab ID: 70155846083	Collected: 12/04/20 06:32	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.8	ug/L	1.0	1		12/14/20 19:27	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-03-BF-P-399		Lab ID: 70155846084	Collected: 12/04/20 06:33	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.3	ug/L	1.0	1		12/14/20 19:28	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-03-DW-P-400		Lab ID: 70155846085	Collected: 12/04/20 06:33	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	6.2	ug/L	1.0	1		12/14/20 19:29	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-03-BF1-P-401		Lab ID: 70155846086	Collected: 12/04/20 06:35	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/14/20 19:30	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Sample: PS12-03-BF2-P-402		Lab ID: 70155846087	Collected: 12/04/20 06:36	Received: 12/08/20 11:10	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/14/20 19:31	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

QC Batch:	189448	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70155846001, 70155846002, 70155846003, 70155846004, 70155846005, 70155846006, 70155846007, 70155846008, 70155846009, 70155846010, 70155846011, 70155846012, 70155846013, 70155846014, 70155846015, 70155846016, 70155846017, 70155846018, 70155846019		

METHOD BLANK: 930085

Matrix: Water

Associated Lab Samples: 70155846001, 70155846002, 70155846003, 70155846004, 70155846005, 70155846006, 70155846007, 70155846008, 70155846009, 70155846010, 70155846011, 70155846012, 70155846013, 70155846014, 70155846015, 70155846016, 70155846017, 70155846018, 70155846019

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/14/20 17:20	

LABORATORY CONTROL SAMPLE: 930086

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	48.9	98	85-115	

MATRIX SPIKE SAMPLE: 930088

Parameter	Units	70155558005 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	4	5.2	115	70-130	

MATRIX SPIKE SAMPLE: 930090

Parameter	Units	70155846010 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	4	5.7	119	70-130	

SAMPLE DUPLICATE: 930087

Parameter	Units	70155558005 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 930089

Parameter	Units	70155846010 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: ENLARGED CITY SCHOOL DIST 12/4
Pace Project No.: 70155846

QC Batch:	189449	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70155846020, 70155846021, 70155846022, 70155846023, 70155846024, 70155846025, 70155846026, 70155846027, 70155846028, 70155846029, 70155846030, 70155846031, 70155846032, 70155846033, 70155846034, 70155846035, 70155846036, 70155846037, 70155846038, 70155846039		

METHOD BLANK:	930093	Matrix:	Water
Associated Lab Samples:	70155846020, 70155846021, 70155846022, 70155846023, 70155846024, 70155846025, 70155846026, 70155846027, 70155846028, 70155846029, 70155846030, 70155846031, 70155846032, 70155846033, 70155846034, 70155846035, 70155846036, 70155846037, 70155846038, 70155846039		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/14/20 17:49	

LABORATORY CONTROL SAMPLE:	930094					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.0	98	85-115	

MATRIX SPIKE SAMPLE:		930096					
		70155846020	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	4	5.1	120	70-130	

MATRIX SPIKE SAMPLE:		930098					
		70155846030	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	4	5.1	117	70-130	

SAMPLE DUPLICATE: 930095					
		70155846020	Dup		
Parameter	Units	Result	Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 930097

Parameter	Units	70155846030 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: ENLARGED CITY SCHOOL DIST 12/4
Pace Project No.: 70155846

QC Batch:	189450	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70155846040, 70155846041, 70155846042, 70155846043, 70155846044, 70155846045, 70155846046, 70155846047, 70155846048, 70155846049, 70155846050, 70155846051, 70155846052, 70155846053, 70155846054, 70155846055, 70155846056, 70155846057, 70155846058, 70155846059		

METHOD BLANK:	930100	Matrix:	Water
Associated Lab Samples:	70155846040, 70155846041, 70155846042, 70155846043, 70155846044, 70155846045, 70155846046, 70155846047, 70155846048, 70155846049, 70155846050, 70155846051, 70155846052, 70155846053, 70155846054, 70155846055, 70155846056, 70155846057, 70155846058, 70155846059		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/14/20 18:19	

LABORATORY CONTROL SAMPLE:	930101					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.1	98	85-115	

MATRIX SPIKE SAMPLE:		930103					
		70155846040	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	5.5	4	10.0	114	70-130	

MATRIX SPIKE SAMPLE:		930105					
		70155846050	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	3.2	4	7.7	112	70-130	

SAMPLE DUPLICATE:	930102				
Parameter	Units	70155846040 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	5.5	5.4	1	

SAMPLE DUPLICATE:	930104				
Parameter	Units	70155846050 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	3.2	3.3	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

QC Batch:	189451	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70155846060, 70155846061, 70155846062, 70155846063, 70155846064, 70155846065, 70155846066, 70155846067, 70155846068, 70155846069, 70155846070, 70155846071, 70155846072, 70155846073, 70155846074, 70155846075, 70155846076, 70155846077, 70155846078, 70155846079		

METHOD BLANK:	930106	Matrix:	Water
Associated Lab Samples:	70155846060, 70155846061, 70155846062, 70155846063, 70155846064, 70155846065, 70155846066, 70155846067, 70155846068, 70155846069, 70155846070, 70155846071, 70155846072, 70155846073, 70155846074, 70155846075, 70155846076, 70155846077, 70155846078, 70155846079		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/14/20 18:50	

LABORATORY CONTROL SAMPLE:	930107					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.5	99	85-115	

MATRIX SPIKE SAMPLE:		930109					
		70155846060	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	161	4	164	70	70-130	

MATRIX SPIKE SAMPLE:		930111					
		70155846070	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	9.0	4	13.6	115	70-130	

SAMPLE DUPLICATE: 930108					
		70155846060	Dup		
Parameter	Units	Result	Result	RPD	Qualifiers
Lead	ug/L	161	158	2	

SAMPLE DUPLICATE: 930110

Parameter	Units	70155846070 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	9.0	9.0	0	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

QC Batch:	189452	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70155846080, 70155846081, 70155846082, 70155846083, 70155846084, 70155846085, 70155846086, 70155846087		

METHOD BLANK:	930113	Matrix:	Water
Associated Lab Samples:	70155846080, 70155846081, 70155846082, 70155846083, 70155846084, 70155846085, 70155846086, 70155846087		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/14/20 19:18	

LABORATORY CONTROL SAMPLE:	930114					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	48.5	97	85-115	

MATRIX SPIKE SAMPLE:	930116						
Parameter	Units	70155846080 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	4	4.7	117	70-130	

SAMPLE DUPLICATE: 930115

Parameter	Units	70155846080 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70155846001	PS12-01-CF-P-302	EPA 200.8	189448		
70155846002	PS12-01-DW-P-303	EPA 200.8	189448		
70155846003	PS12-01-CF-P-304	EPA 200.8	189448		
70155846004	PS12-01-DW-P-305	EPA 200.8	189448		
70155846005	PS12-01-KF1-P-306	EPA 200.8	189448		
70155846006	PS12-01-KF2-P-308	EPA 200.8	189448		
70155846007	PS12-01-KF3-P-309	EPA 200.8	189448		
70155846008	PS12-01-DW-P-310	EPA 200.8	189448		
70155846009	PS12-01-DW-P-311	EPA 200.8	189448		
70155846010	PS12-01-CF-P-312	EPA 200.8	189448		
70155846011	PS12-01-DW-P-313	EPA 200.8	189448		
70155846012	PS12-01-CF-P-314	EPA 200.8	189448		
70155846013	PS12-01-DW-P-315	EPA 200.8	189448		
70155846014	PS12-01-CF-P-316	EPA 200.8	189448		
70155846015	PS12-01-DW-P-317	EPA 200.8	189448		
70155846016	PS12-01-BF-P-318	EPA 200.8	189448		
70155846017	PS12-01-BF-P-319	EPA 200.8	189448		
70155846018	PS12-01-CF-P-320	EPA 200.8	189448		
70155846019	PS12-01-DW-P-321	EPA 200.8	189448		
70155846020	PS12-01-BF-P-322	EPA 200.8	189449		
70155846021	PS12-02-BF-P-323	EPA 200.8	189449		
70155846022	PS12-03-BF-P-324	EPA 200.8	189449		
70155846023	PS12-04-BF-P-325	EPA 200.8	189449		
70155846024	PS12-01-DW-P-326	EPA 200.8	189449		
70155846025	PS12-01-BF-P-327	EPA 200.8	189449		
70155846026	PS12-B-DW-P-329	EPA 200.8	189449		
70155846027	PS12-01-DW-P-330	EPA 200.8	189449		
70155846028	PS12-01-BF-P-332	EPA 200.8	189449		
70155846029	PS12-01-BF-P-333	EPA 200.8	189449		
70155846030	PS12-01-DW-P-335	EPA 200.8	189449		
70155846031	PS12-01-BF1-P-336	EPA 200.8	189449		
70155846032	PS12-01-BF2-P-337	EPA 200.8	189449		
70155846033	PS12-01-CF-P-338	EPA 200.8	189449		
70155846034	PS12-02-BF1-P-340	EPA 200.8	189449		
70155846035	PS12-02-BF2-P-341	EPA 200.8	189449		
70155846036	PS12-02-BF3-P-342	EPA 200.8	189449		
70155846037	PS12-02-DW-P-343	EPA 200.8	189449		
70155846038	PS12-02-BF-P-344	EPA 200.8	189449		
70155846039	PS12-02-CF-P-345	EPA 200.8	189449		
70155846040	PS12-02-BF-P-346	EPA 200.8	189450		
70155846041	PS12-02-DW-P-347	EPA 200.8	189450		
70155846042	PS12-02-DW-P-348	EPA 200.8	189450		
70155846043	PS12-02-BF1-P-349	EPA 200.8	189450		
70155846044	PS12-02-BF2-P-350	EPA 200.8	189450		
70155846045	PS12-02-BF3-P-351	EPA 200.8	189450		
70155846046	PS12-02-BF4-P-352	EPA 200.8	189450		
70155846047	PS12-02-DW-P-353	EPA 200.8	189450		
70155846048	PS12-02-BF-P-354	EPA 200.8	189450		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: ENLARGED CITY SCHOOL DIST 12/4

Pace Project No.: 70155846

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70155846049	PS12-02-BF-P-355	EPA 200.8	189450		
70155846050	PS12-02-CF-P-356	EPA 200.8	189450		
70155846051	PS12-02-DW-P-357	EPA 200.8	189450		
70155846052	PS12-02-CF-P-358	EPA 200.8	189450		
70155846053	PS12-02-DW-P-359	EPA 200.8	189450		
70155846054	PS12-02-CF-P-360	EPA 200.8	189450		
70155846055	PS12-02-DW-P-361	EPA 200.8	189450		
70155846056	PS12-02-CF-P-364	EPA 200.8	189450		
70155846057	PS12-02-CF-P-366	EPA 200.8	189450		
70155846058	PS12-02-DW-P-367	EPA 200.8	189450		
70155846059	PS12-02-CF-P-370	EPA 200.8	189450		
70155846060	PS12-02-DW-P-371	EPA 200.8	189451		
70155846061	PS12-03-OF-P-372	EPA 200.8	189451		
70155846062	PS12-03-DW-P-373	EPA 200.8	189451		
70155846063	PS12-03-OF-P-374	EPA 200.8	189451		
70155846064	PS12-03-DW-P-375	EPA 200.8	189451		
70155846065	PS12-03-OF-P-376	EPA 200.8	189451		
70155846066	PS12-03-OF-P-378	EPA 200.8	189451		
70155846067	PS12-03-DW-P-379	EPA 200.8	189451		
70155846068	PS12-03-OF-P-380	EPA 200.8	189451		
70155846069	PS12-03-DW-P-381	EPA 200.8	189451		
70155846070	PS12-03-OF-P-382	EPA 200.8	189451		
70155846071	PS12-03-DW-P-383	EPA 200.8	189451		
70155846072	PS12-03-OF-P-384	EPA 200.8	189451		
70155846073	PS12-03-DW-P-385	EPA 200.8	189451		
70155846074	PS12-03-DW-P-386	EPA 200.8	189451		
70155846075	PS12-03-BF1-P-389	EPA 200.8	189451		
70155846076	PS12-03-BF2-P-390	EPA 200.8	189451		
70155846077	PS12-03-BF1-P-391	EPA 200.8	189451		
70155846078	PS12-03-BF2-P-392	EPA 200.8	189451		
70155846079	PS12-03-BF3-P-393	EPA 200.8	189451		
70155846080	PS12-03-DW-P-395	EPA 200.8	189452		
70155846081	PS12-03-DW-P-396	EPA 200.8	189452		
70155846082	PS12-03-BF-P-397	EPA 200.8	189452		
70155846083	PS12-03-SF-P-398	EPA 200.8	189452		
70155846084	PS12-03-BF-P-399	EPA 200.8	189452		
70155846085	PS12-03-DW-P-400	EPA 200.8	189452		
70155846086	PS12-03-BF1-P-401	EPA 200.8	189452		
70155846087	PS12-03-BF2-P-402	EPA 200.8	189452		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

Appendix D Page 1 of 4

CLIENT INFORMATION

Name: Enlarged City School District of Troy				
Address: 475 First Street Troy NY 12180				
Client Rep: Bob Garland				
SCHOOL/PROJECT INFORMATION				
BLDG NO./NAME:	PS12			
BLDG ADDRESS:	475 First Street Troy NY 12180			
CONTACT NAME & NUMBERS:	Bob Garland 518-328-5426			
(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

Date of Sampling: 12/4/2020
 Samples Taken By: Tim LeVan
 Samples Taken By: Rich Stevens

WO# : 70155846

70155846

SAMPLE DATA

Sample Description ID (ID must match container label)			Outlet Information										
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	30 Second Flush Draw	Time of Collection (24hr)	Service Connection Draw	Time of Collection (24hr)	Water Main Draw	Time of Collection (24hr)
302	PS12-01-CF-P-302	117	Sink			X	5:30						
303	PS12-01-DW-P-303	117	Water fountain			X	5:00						
304	PS12-01-CF-P-304	118	Sink			X	5:04						
305	PS12-01-DW-P-305	118	Water fountain			X	5:04						
306	PS12-01-KF1-P-306	Kitchen	Sink 1			X	5:08						
308	PS12-01-KF2-P-308	Kitchen	Sink 2			X	5:08						
309	PS12-01-KF3-P-309	Kitchen	Sink 3			X	5:09						
310	PS12-01-DW-P-310	Cafeteria	Water fountain			X	5:06						
311	PS12-01-DW-P-311	Cafeteria	Bottle filler			X	5:06						
312	PS12-01-CF-P-312	119	Sink			X	5:10						
313	PS12-01-DW-P-313	119	Water fountain			X	5:10						
314	PS12-01-CF-P-314	114	Sink			X	5:12						
315	PS12-01-DW-P-315	114	Water fountain			X	5:12						
316	PS12-01-CF-P-316	113	Sink			X	5:14						
317	PS12-01-DW-P-317	113	Water fountain			X	5:14						
318	PS12-01-BF-P-318	Girls room	Sink 1			X	5:17						
319	PS12-01-BF-P-319	Girls room	Sink 2			X	5:17						
320	PS12-01-CF-P-320	123	Sink			X	5:18						
321	PS12-01-DW-P-321	123	Water fountain			X	5:18						
322	PS12-01-BF-P-322	Girls room	Sink 1			X	5:21						
323	PS12-02-BF-P-323	Girls room	Sink 2			X	5:21						
324	PS12-03-BF-P-324	Girls room	Sink 3			X	5:21						
325	PS12-04-BF-P-325	Girls room	Sink 4			X	5:20						
326	PS12-01-DW-P-326	Corridor	Water fountain			X	5:23						
327	PS12-01-BF-P-327	Main office bathroom	Sink			X	5:25						

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:
<i>Tim LeVan</i>	<i>Bob Garland</i>	8:55	12/4/20

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab: PACE Analytical

Contact:

Comments: Provide Laboratory Data Report (LDR) and Chain of Custody

CLIENT INFORMATION

Name: Enlarged City School District of Troy
 Address: 475 First Street Troy NY 12180
 Client Rep: Bob Garland

Date of Sampling: 12/4/2020
 Samples Taken By: Tim LeVan
 Samples Taken By: Rich Stevens

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME: PS12
 BLDG ADDRESS: 475 First Street Troy NY 12180
 CONTACT NAME & NUMBERS: Bob Garland 518-328-5426

(1) Yr. Built (2) Yr 1st Add: (3) Yr 2nd Add: (4) Yr 1st Mod: (5) Yr 2nd Mod:

WO#: 70155846

PM: NPL
 CLIENT: QUESTAR
 Due Date: 12/22/20

SAMPLE DATA

Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	30 Second Flush Draw	Time of Collection (24hr)	Service Connection Draw	Time of Collection (24hr)	Water Main Draw	Time of Collection (24hr)
328	PS12-B-BF-P-328	Girls locker room	Sink			X	Not working No sample						
329	PS12-B-DW-P-329	Girls locker room	Water fountain			X	5:27						
330	PS12-01-DW-P-330	126 weight room	Water fountain			X	5:28						
331	PS12-01-BF-P-331	Weight room bathroom	Sink			X	Mixing valve, No sample						
332	PS12-01-BF-P-332	Custodians office	Sink			X	5:30						
333	PS12-01-BF-P-333	Boys locker room	Sink			X	5:32						
334	PS12-01-DW-P-334	Boys locker room	Water fountain			X	Off due to COVID 19						
335	PS12-01-DW-P-335	Corridor	Water fountain			X	5:33						
336	PS12-01-BF1-P-336	Boys room	Sink 1			X	5:36						
337	PS12-01-BF2-P-337	Boys room	Sink 2			X	5:37						
338	PS12-01-CF-P-338	Receiving	Sink			X	5:37						
339	PS12-01-BF3-P-339	Boys room	Sink 3			X	Not working No sample						
340	PS12-02-BF1-P-340	Boys room	Sink 1			X	5:40						
341	PS12-02-BF2-P-341	Boys room	Sink 2			X	5:40						
342	PS12-02-BF3-P-342	Boys room	Sink 3			X	5:40						
343	PS12-02-DW-P-343	Corridor	Water fountain			X	5:41						
344	PS12-02-BF-P-344	209 Bathroom	Sink			X	5:43						
345	PS12-02-CF-P-345	210	Sink			X	5:44						
346	PS12-02-BF-P-346	211 bathroom	Sink			X	5:45						
347	PS12-02-DW-P-347	Corridor	Water fountain			X	5:46						
348	PS12-02-DW-P-348	Corridor	Bottle filler			X	5:48						
349	PS12-02-BF1-P-349	Girls room	Sink 1			X	5:49						
350	PS12-02-BF2-P-350	Girls room	Sink 2			X	5:50						
351	PS12-02-BF3-P-351	Girls room	Sink 3			X	5:50						
352	PS12-02-BF4-P-352	Girls room	Sink 4			X	5:51						
353	PS12-02-DW-P-353	Corridor	Water fountain			X	5:52						

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By: Tim LeVan Received By: Bob Garland Time: 8:55 Date: 12/4/20

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)
 Lab: PACE Analytical
 Date: 12/4/20
 Contact: 518-328-5426
 Comments: Provide Laboratory Data Report (LDR) and Chain of Custody

CLIENT INFORMATION

Name:	Enlarged City School District of Troy
Address:	475 First Street Troy NY 12180
Client Rep:	Bob Garland

Date of Sampling:	12/4/2020
Samples Taken By:	Tim LeVan
Samples Taken By:	Rich Stevens

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	PS12
BLDG ADDRESS:	475 First Street Troy NY 12180
CONTACT NAME & NUMBERS:	Bob Garland 518-328-5426

(1) Yr. Built	(2) Yr. 1st Add:	(3) Yr. 2nd Add:	(4) Yr. 1st Mod:	(5) Yr. 2nd Mod:

SAMPLE DATA

Sample Description ID (ID must match container label)													
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Information									
				Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	30 Second Flush Draw	Time of Collection (24hr)	Service Connection Draw	Time of Collection (24hr)	Water Main Draw	Time of Collection (24hr)
354	PS12-02-BF-P-354	Bathroom sink	Sink 1			X	5:54						
355	PS12-02-BF-P-355	Bathroom sink	Sink 2			X	5:54						
356	PS12-02-CF-P-356	223	Sink			X	5:56						
357	PS12-02-DW-P-357	223	Water fountain			X	5:56						
358	PS12-02-CF-P-358	216	Sink			X	5:57						
359	PS12-02-DW-P-359	216	Water fountain			X	5:57						
360	PS12-02-CF-P-360	222	Sink			X	5:59						
361	PS12-02-DW-P-361	222	Water fountain			X	5:59						
362	PS12-02-CF-P-362	217	Sink			X	Not working, No Sample						
363	PS12-02-DW-P-363	217	Water fountain			X	Not working, No Sample						
364	PS12-02-CF-P-364	218	Sink 1			X	6:01						
365	PS12-02-CF-P-365	218	Sink 2			X	Not working, No Sample						
366	PS12-02-CF-P-366	221	Sink			X	6:02						
367	PS12-02-DW-P-367	221	Water fountain			X	6:02						
368	PS12-02-CF-P-368	219	Sink			X	Removed						
369	PS12-02-DW-P-369	219	Water fountain			X	Removed						
370	PS12-02-CF-P-370	220	Sink			X	6:05						
371	PS12-02-DW-P-371	220	Water fountain			X	6:05						
372	PS12-03-OF-P-372	320	Sink			X	6:10						
373	PS12-03-DW-P-373	320	Water fountain			X	6:10						
374	PS12-03-OF-P-374	319	Sink			X	6:12						
375	PS12-03-DW-P-375	319	Water fountain			X	6:12						
376	PS12-03-OF-P-376	321	Sink			X	6:13						
377	PS12-03-DW-P-377	321	Water fountain			X	Not working, No Sample						
378	PS12-03-OF-P-378	318	Sink			X	6:15						

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:
<i>Tim LeVan</i>	<i>Rich Stevens</i>	8:55	12/4/20

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab: Pace Analytical

Lab # 100

Contact:

Comments: Provide Laboratory Data Report (LDR) and Chain of Custody

CLIENT INFORMATION

Name:	Enlarged City School District of Troy
Address:	475 First Street Troy NY 12180
Client Rep:	Bob Garland

Date of Sampling:	12/4/2020
Samples Taken By:	Tim LeVan
Samples Taken By:	Rich Stevens

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	PS12
BLDG ADDRESS:	475 First Street Troy NY 12180
CONTACT NAME & NUMBERS:	Bob Garland 518-328-5426

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information									
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	30 Second Flush Draw	Time of Collection (24hr)	Service Connection Draw	Time of Collection (24hr)	Water Main Draw	Time of Collection (24hr)
379	PS12-03-DW-P-379	318	Water fountain			X	6:15						
380	PS12-03-OF-P-380	317	Sink			X	6:17						
381	PS12-03-DW-P-381	317	Water fountain			X	6:17						
382	PS12-03-OF-P-382	322	Sink			X	6:19						
383	PS12-03-DW-P-383	322	Water fountain			X	6:19						
384	PS12-03-OF-P-384	316	Sink			X	6:21						
385	PS12-03-DW-P-385	316	Water fountain			X	6:21						
386	PS12-03-DW-P-386	Corridor	Water fountain			X	6:23						
387	PS12-03-OF-P-387	323	Sink			X	No access, No sample						
388	PS12-03-DW-P-388	323	Water fountain			X	No access, No sample						
389	PS12-03-BF1-P-389	Corridor	Bathroom sink 1			X	6:25						
390	PS12-03-BF2-P-390	Corridor	Bathroom sink 2			X	6:25						
391	PS12-03-BF1-P-391	Girls room	Sink 1			X	6:27						
392	PS12-03-BF2-P-392	Girls room	Sink 2			X	6:28						
393	PS12-03-BF3-P-393	Girls room	Sink 3			X	6:29						
394	PS12-03-BF4-P-394	Girls room	Sink 4			X	Not working, No Sample						
395	PS12-03-DW-P-395	Corridor	Water fountain			X	6:30						
396	PS12-03-DW-P-396	Corridor	Bottle filler			X	6:30						
397	PS12-03-BF-P-397	Mens room	Sink			X	6:31						
398	PS12-03-SF-P-398	Faculty room	Sink			X	6:32						
399	PS12-03-BF-P-399	Womens room	Sink			X	6:33						
400	PS12-03-DW-P-400	Corridor	Water fountain			X	6:33						
401	PS12-03-BF1-P-401	Boys room	Sink 1			X	6:35						
402	PS12-03-BF2-P-402	Boys room	Sink 2			X	6:36						
403	PS12-03-BF3-P-403	Boys room	Sink 3			X	Not working, No Sample						

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:
Tim LeVan	Bob Garland	8:55	12/4/20

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab: PACE Analytical

101 of

Contact:

Comments: Provide Laboratory Data Report (LDR) and Chain of Custody



Sample Condition Upon Receipt

WO#: 70155846

PM: NML

Due Date: 12/22/20

CLIENT: QUESTAR

Client Name: _____

Project # _____

Courier: ☐ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ OtherTracking #: 9099 9901 1981Custody Seal on Cooler/Box Present: ☐ Yes ☐ No Seals intact: ☐ Yes ☐ NoPacking Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ Ziploc ☐ None ☐ Other HR12/8

Thermometer Used: TH091

Correction Factor: -0.2Cooler Temperature(°C): 22.5 Cooler Temperature Corrected(°C): 22.3

Temp should be above freezing to 6.0°C

USDA Regulated Soil (☐ N/A, water sample)Date and Initials of person examining contents: HR12/20

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC,

Did samples originate from a foreign source

NM, NY, OK, OR, SC, TN, TX, or VA (check map)? ☐ Yes ☐ Noincluding Hawaii and Puerto Rico)? ☐ Yes ☐ No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

Chain of Custody Present:		1.	COMMENTS:
Chain of Custody Filled Out:		2.	
Chain of Custody Relinquished:		3.	
Sampler Name & Signature on COC:		4.	
Samples Arrived within Hold Time:		5.	
Short Hold Time Analysis (<72hr):		6.	
Rush Turn Around Time Requested:		7.	
Sufficient Volume: (Triple volume provided for)		8.	
Correct Containers Used:		9.	
-Pace Containers Used:		10.	
Containers Intact:		11.	Note if sediment is visible in the dissolved container.
Filtered volume received for Dissolved tests		12.	
Sample Labels match COC:			
-Includes date/time/ID, Matrix: SL WT OIL			
All containers needing preservation have been checked?		13.	<input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot # <u>HC904495</u>			Sample #
All containers needing preservation are found to be in compliance with method recommendation?			
(HNO ₃ , H ₂ SO ₄ , HCl, NaOH>9 Sulfide, NAOH>12 Cyanide)			
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water).			
Per Method, VOA pH is checked after analysis			
Samples checked for dechlorination:		14.	Initial when completed: Lot # of added preservative: Date/Time preservative added:
KI starch test strips Lot #			Positive for Res. Chlorine? Y N
Residual chlorine strips Lot #		15.	
SM 4500 CN samples checked for sulfide?		16.	
Lead Acetate Strips Lot #		17.	
Headspace in VOA Vials (>6mm):			
Trip Blank Present:			
Trip Blank Custody Seals Present			
Pace Trip Blank Lot # (if applicable):			

Client Notification/ Resolution:

Field Data Required?

Y / N

Person Contacted: _____

Date/Time: _____

Comments/ Resolution: _____

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

Appendix D

Page 1 of 4

CLIENT INFORMATION

Name:	Enlarged City School District of Troy
Address:	475 First Street Troy NY 12180
Client Rep:	Bob Garland

Date of Sampling:	12/4/2020
Samples Taken By:	Tim LeVan
Samples Taken By:	Rich Stevens

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	PS12
BLDG ADDRESS:	475 First Street Troy NY 12180
CONTACT NAME & NUMBERS:	Bob Garland 518-328-5426

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information						
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Lead test Results ug/L from	Lead test Results ug/L from	Lead test Results ug/L from	Remediation
302	PS12-01-CF-P-302	117	Sink			X	4.4			
303	PS12-01-DW-P-303	117	Water fountain			X	4.1			
304	PS12-01-CF-P-304	118	Sink			X	2			
305	PS12-01-DW-P-305	118	Water fountain			X	2.5			
306	PS12-01-KF1-P-306	Kitchen	Sink 1			X	6.4			
308	PS12-01-KF2-P-308	Kitchen	Sink 2			X	7.4			
309	PS12-01-KF3-P-309	Kitchen	Sink 3			X	2			
310	PS12-01-DW-P-310	Cafeteria	Water fountain			X	<1.0			
311	PS12-01-DW-P-311	Cafeteria	Bottle filler			X	<1.0			
312	PS12-01-CF-P-312	119	Sink			X	<1.0			
313	PS12-01-DW-P-313	119	Water fountain			X	1.2			
314	PS12-01-CF-P-314	114	Sink			X	4.1			
315	PS12-01-DW-P-315	114	Water fountain			X	1.6			
316	PS12-01-CF-P-316	113	Sink			X	3.7			
317	PS12-01-DW-P-317	113	Water fountain			X	3			
318	PS12-01-BF-P-318	Girls room	Sink 1			X	4.8			
319	PS12-01-BF-P-319	Girls room	Sink 2			X	10.8			
320	PS12-01-CF-P-320	123	Sink			X	3.7			
321	PS12-01-DW-P-321	123	Water fountain			X	3.9			
322	PS12-01-BF-P-322	Girls room	Sink 1			X	<1.0			
323	PS12-02-BF-P-323	Girls room	Sink 2			X	<1.0			
324	PS12-03-BF-P-324	Girls room	Sink 3			X	<1.0			
325	PS12-04-BF-P-325	Girls room	Sink 4			X	<1.0			
326	PS12-01-DW-P-326	Corridor	Water fountain			X	<1.0			
327	PS12-01-BF-P-327	Main office bathroom	Sink			X	<1.0			

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab: PACE Analytical	
Contact:	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
PS12-01-CF-P-302	12/4/2020 05:00	12/14/2020 17:25	70155846001	Lead	4.4	15	ug/L
PS12-01-DW-P-303	12/4/2020 05:00	12/14/2020 17:26	70155846002	Lead	4.1	15	ug/L
PS12-01-CF-P-304	12/4/2020 05:04	12/14/2020 17:29	70155846003	Lead	2.0	15	ug/L
PS12-01-DW-P-305	12/4/2020 05:04	12/14/2020 17:30	70155846004	Lead	2.5	15	ug/L
PS12-01-KF1-P-306	12/4/2020 05:08	12/14/2020 17:31	70155846005	Lead	6.4	15	ug/L
PS12-01-KF2-P-308	12/4/2020 05:08	12/14/2020 17:32	70155846006	Lead	7.4	15	ug/L
PS12-01-KF3-P-309	12/4/2020 05:09	12/14/2020 17:33	70155846007	Lead	2.0	15	ug/L
PS12-01-DW-P-310	12/4/2020 05:06	12/14/2020 17:33	70155846008	Lead	<1.0	15	ug/L
PS12-01-DW-P-311	12/4/2020 05:06	12/14/2020 17:34	70155846009	Lead	<1.0	15	ug/L
PS12-01-CF-P-312	12/4/2020 05:10	12/14/2020 17:35	70155846010	Lead	<1.0	15	ug/L
PS12-01-DW-P-313	12/4/2020 05:10	12/14/2020 17:40	70155846011	Lead	1.2	15	ug/L
PS12-01-CF-P-314	12/4/2020 05:12	12/14/2020 17:41	70155846012	Lead	4.1	15	ug/L
PS12-01-DW-P-315	12/4/2020 05:12	12/14/2020 17:42	70155846013	Lead	1.6	15	ug/L
PS12-01-CF-P-316	12/4/2020 05:14	12/14/2020 17:43	70155846014	Lead	3.7	15	ug/L
PS12-01-DW-P-317	12/4/2020 05:14	12/14/2020 17:44	70155846015	Lead	3.0	15	ug/L
PS12-01-BF-P-318	12/4/2020 05:17	12/14/2020 17:45	70155846016	Lead	4.8	15	ug/L
PS12-01-BF-P-319	12/4/2020 05:17	12/14/2020 17:46	70155846017	Lead	10.8	15	ug/L
PS12-01-CF-P-320	12/4/2020 05:18	12/14/2020 17:47	70155846018	Lead	3.7	15	ug/L
PS12-01-DW-P-321	12/4/2020 05:18	12/14/2020 17:48	70155846019	Lead	3.9	15	ug/L
PS12-01-BF-P-322	12/4/2020 05:21	12/14/2020 17:53	70155846020	Lead	<1.0	15	ug/L
PS12-02-BF-P-323	12/4/2020 05:21	12/14/2020 17:55	70155846021	Lead	<1.0	15	ug/L
PS12-03-BF-P-324	12/4/2020 05:21	12/14/2020 17:56	70155846022	Lead	<1.0	15	ug/L
PS12-04-BF-P-325	12/4/2020 05:20	12/14/2020 17:57	70155846023	Lead	<1.0	15	ug/L
PS12-01-DW-P-326	12/4/2020 05:23	12/14/2020 17:58	70155846024	Lead	<1.0	15	ug/L
PS12-01-BF-P-327	12/4/2020 05:25	12/14/2020 17:59	70155846025	Lead	<1.0	15	ug/L
PS12-B-DW-P-329	12/4/2020 05:27	12/14/2020 18:00	70155846026	Lead	127	15	ug/L
PS12-01-DW-P-330	12/4/2020 05:28	12/14/2020 18:03	70155846027	Lead	54.6	15	ug/L
PS12-01-BF-P-332	12/4/2020 05:30	12/14/2020 18:04	70155846028	Lead	6.0	15	ug/L
PS12-01-BF-P-333	12/4/2020 05:32	12/14/2020 18:05	70155846029	Lead	1.2	15	ug/L
PS12-01-DW-P-335	12/4/2020 05:33	12/14/2020 18:06	70155846030	Lead	<1.0	15	ug/L
PS12-01-BF1-P-336	12/4/2020 05:36	12/14/2020 18:09	70155846031	Lead	<1.0	15	ug/L
PS12-01-BF2-P-337	12/4/2020 05:34	12/14/2020 18:10	70155846032	Lead	<1.0	15	ug/L
PS12-01-CF-P-338	12/4/2020 05:37	12/14/2020 18:11	70155846033	Lead	<1.0	15	ug/L
PS12-02-BF1-P-340	12/4/2020 05:40	12/14/2020 18:12	70155846034	Lead	2.1	15	ug/L
PS12-02-BF2-P-341	12/4/2020 05:40	12/14/2020 18:14	70155846035	Lead	<1.0	15	ug/L
PS12-02-BF3-P-342	12/4/2020 05:40	12/14/2020 18:15	70155846036	Lead	<1.0	15	ug/L
PS12-02-DW-P-343	12/4/2020 05:41	12/14/2020 18:16	70155846037	Lead	1.2	15	ug/L
PS12-02-BF-P-344	12/4/2020 05:43	12/14/2020 18:17	70155846038	Lead	9.8	15	ug/L
PS12-02-CF-P-345	12/4/2020 05:44	12/14/2020 18:18	70155846039	Lead	2.9	15	ug/L
PS12-02-BF-P-346	12/4/2020 05:45	12/14/2020 18:21	70155846040	Lead	5.5	15	ug/L
PS12-02-DW-P-347	12/4/2020 05:46	12/14/2020 18:26	70155846041	Lead	<1.0	15	ug/L
PS12-02-DW-P-348	12/4/2020 05:48	12/14/2020 18:27	70155846042	Lead	<1.0	15	ug/L
PS12-02-BF1-P-349	12/4/2020 05:49	12/14/2020 18:28	70155846043	Lead	<1.0	15	ug/L
PS12-02-BF2-P-350	12/4/2020 05:50	12/14/2020 18:29	70155846044	Lead	1.1	15	ug/L
PS12-02-BF3-P-351	12/4/2020 05:50	12/14/2020 18:30	70155846045	Lead	<1.0	15	ug/L
PS12-02-BF4-P-352	12/4/2020 05:51	12/14/2020 18:31	70155846046	Lead	<1.0	15	ug/L
PS12-02-DW-P-353	12/4/2020 05:52	12/14/2020 18:32	70155846047	Lead	23.0	15	ug/L
PS12-02-BF-P-354	12/4/2020 05:54	12/14/2020 18:33	70155846048	Lead	<1.0	15	ug/L
PS12-02-BF-P-355	12/4/2020 05:54	12/14/2020 18:33	70155846049	Lead	<1.0	15	ug/L
PS12-02-CF-P-356	12/4/2020 05:56	12/14/2020 18:34	70155846050	Lead	3.2	15	ug/L

PS12-02-DW-P-357	12/4/2020 05:56	12/14/2020 18:39	70155846051	Lead	10.9	15	ug/L
PS12-02-CF-P-358	12/4/2020 05:57	12/14/2020 18:40	70155846052	Lead	10.3	15	ug/L
PS12-02-DW-P-359	12/4/2020 05:57	12/14/2020 18:41	70155846053	Lead	14.3	15	ug/L
PS12-02-CF-P-360	12/4/2020 05:59	12/14/2020 18:42	70155846054	Lead	7.6	15	ug/L
PS12-02-DW-P-361	12/4/2020 05:59	12/14/2020 18:43	70155846055	Lead	5.0	15	ug/L
PS12-02-CF-P-364	12/4/2020 06:01	12/14/2020 18:44	70155846056	Lead	6.6	15	ug/L
PS12-02-CF-P-366	12/4/2020 06:02	12/14/2020 18:45	70155846057	Lead	2.7	15	ug/L
PS12-02-DW-P-367	12/4/2020 06:02	12/14/2020 18:46	70155846058	Lead	6.3	15	ug/L
PS12-02-CF-P-370	12/4/2020 06:05	12/14/2020 18:49	70155846059	Lead	391	15	ug/L
PS12-02-DW-P-371	12/4/2020 06:05	12/14/2020 18:51	70155846060	Lead	161	15	ug/L
PS12-03-OF-P-372	12/4/2020 06:10	12/14/2020 18:54	70155846061	Lead	5.2	15	ug/L
PS12-03-DW-P-373	12/4/2020 06:10	12/14/2020 18:55	70155846062	Lead	3.1	15	ug/L
PS12-03-OF-P-374	12/4/2020 06:12	12/14/2020 18:56	70155846063	Lead	19.5	15	ug/L
PS12-03-DW-P-375	12/4/2020 06:12	12/14/2020 18:57	70155846064	Lead	4.6	15	ug/L
PS12-03-OF-P-376	12/4/2020 06:13	12/14/2020 19:00	70155846065	Lead	10.8	15	ug/L
PS12-03-OF-P-378	12/4/2020 06:15	12/14/2020 19:01	70155846066	Lead	8.6	15	ug/L
PS12-03-DW-P-379	12/4/2020 06:15	12/14/2020 19:02	70155846067	Lead	3.6	15	ug/L
PS12-03-OF-P-380	12/4/2020 06:17	12/14/2020 19:03	70155846068	Lead	12.3	15	ug/L
PS12-03-DW-P-381	12/4/2020 06:17	12/14/2020 19:04	70155846069	Lead	4.7	15	ug/L
PS12-03-OF-P-382	12/4/2020 06:19	12/14/2020 19:05	70155846070	Lead	9.0	15	ug/L
PS12-03-DW-P-383	12/4/2020 06:19	12/14/2020 19:08	70155846071	Lead	12.4	15	ug/L
PS12-03-OF-P-384	12/4/2020 06:21	12/14/2020 19:09	70155846072	Lead	7.1	15	ug/L
PS12-03-DW-P-385	12/4/2020 06:21	12/14/2020 19:12	70155846073	Lead	6.8	15	ug/L
PS12-03-DW-P-386	12/4/2020 06:23	12/14/2020 19:13	70155846074	Lead	21.3	15	ug/L
PS12-03-BF1-P-389	12/4/2020 06:25	12/14/2020 19:14	70155846075	Lead	1.4	15	ug/L
PS12-03-BF2-P-390	12/4/2020 06:25	12/14/2020 19:14	70155846076	Lead	1.1	15	ug/L
PS12-03-BF1-P-391	12/4/2020 06:27	12/14/2020 19:15	70155846077	Lead	<1.0	15	ug/L
PS12-03-BF2-P-392	12/4/2020 06:28	12/14/2020 19:16	70155846078	Lead	<1.0	15	ug/L
PS12-03-BF3-P-393	12/4/2020 06:29	12/14/2020 19:17	70155846079	Lead	<1.0	15	ug/L
PS12-03-DW-P-395	12/4/2020 06:30	12/14/2020 19:20	70155846080	Lead	<1.0	15	ug/L
PS12-03-DW-P-396	12/4/2020 06:30	12/14/2020 19:25	70155846081	Lead	<1.0	15	ug/L
PS12-03-BF-P-397	12/4/2020 06:31	12/14/2020 19:26	70155846082	Lead	5.9	15	ug/L
PS12-03-SF-P-398	12/4/2020 06:32	12/14/2020 19:27	70155846083	Lead	4.8	15	ug/L
PS12-03-BF-P-399	12/4/2020 06:33	12/14/2020 19:28	70155846084	Lead	4.3	15	ug/L
PS12-03-DW-P-400	12/4/2020 06:33	12/14/2020 19:29	70155846085	Lead	6.2	15	ug/L
PS12-03-BF1-P-401	12/4/2020 06:35	12/14/2020 19:30	70155846086	Lead	<1.0	15	ug/L
PS12-03-BF2-P-402	12/4/2020 06:36	12/14/2020 19:31	70155846087	Lead	<1.0	15	ug/L

NYSDOH Action Level for Lead of 15 ppb