

November 19, 2020

Paul Swieton
Rensselaer-Columbia-Greene Counties and
BOCES
10 Empire State Blvd.
Fl 2
Castleton On Hudson, NY 12033

RE: Project: ENLARGED CITY SCHOOL DISTRICT
Pace Project No.: 70153670

Dear Paul Swieton:

Enclosed are the analytical results for sample(s) received by the laboratory on November 17, 2020. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Nicolette M. Lovari
nicolette.lovari@pacelabs.com
(631)694-3040
Project Manager

Enclosures

cc: Robert Garland, Troy City SD



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153670

Pace Analytical Services Long Island

575 Broad Hollow Rd, Melville, NY 11747

New York Certification #: 10478 Primary Accrediting Body

New Jersey Certification #: NY158

Pennsylvania Certification #: 68-00350

Connecticut Certification #: PH-0435

Maryland Certification #: 208

Rhode Island Certification #: LAO00340

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153670

Sample: PS16-B-CS-P-82		Lab ID: 70153670001	Collected: 11/13/20 05:45	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.7	ug/L	1.0	1		11/19/20 11:41	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153670

Sample: PS16-B-CF-P-84		Lab ID: 70153670002	Collected: 11/13/20 05:47	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	160	ug/L	1.0	1		11/19/20 11:44	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153670

Sample: PS16-B-DW-P-86		Lab ID: 70153670003	Collected: 11/13/20 05:41	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	12.5	ug/L	1.0	1		11/19/20 11:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153670

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: PS16-B-BF-P-87 Lab ID: 70153670004 Collected: 11/13/20 05:52 Received: 11/17/20 10:45 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	448	ug/L	1.0	1		11/19/20 11:47	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153670

Sample: PS16-01-BF1-P-89		Lab ID: 70153670005	Collected: 11/13/20 06:08	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.5	ug/L	1.0	1		11/19/20 11:49	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153670

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: PS16-01-BF2-P-90 Lab ID: 70153670006 Collected: 11/13/20 06:08 Received: 11/17/20 10:45 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.3	ug/L	1.0	1		11/19/20 11:49	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153670

Sample: PS16-01-FS-P-91		Lab ID: 70153670007	Collected: 11/13/20 06:02	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.9	ug/L	1.0	1		11/19/20 11:50	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153670

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: PS16-01-BF-P-92 Lab ID: 70153670008 Collected: 11/13/20 06:03 Received: 11/17/20 10:45 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/20 11:51	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153670

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: PS16-01-DW-P-93								
Lab ID: 70153670009								
Collected: 11/13/20 06:04								
Received: 11/17/20 10:45								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	6.2	ug/L	1.0	1		11/19/20 11:52	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153670

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: PS16-01-CF-P-94 Lab ID: 70153670010 Collected: 11/13/20 06:06 Received: 11/17/20 10:45 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.1	ug/L	1.0	1		11/19/20 11:53	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153670

Sample: PS16-01-NS1-P-95		Lab ID: 70153670011	Collected: 11/13/20 05:59	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.2	ug/L	1.0	1		11/19/20 11:56	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153670

Sample: PS16-01-BF-P-96		Lab ID: 70153670012		Collected: 11/13/20 05:55	Received: 11/17/20 10:45	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.0	ug/L	1.0	1		11/19/20 12:01	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153670

Sample: PS16-01-BF-P-98		Lab ID: 70153670013		Collected: 11/13/20 05:58	Received: 11/17/20 10:45	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	68.5	ug/L	1.0	1		11/19/20 12:02	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153670

Sample: PS16-01-BF2-P-99		Lab ID: 70153670014	Collected: 11/13/20 06:20	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.8	ug/L	1.0	1		11/19/20 12:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153670

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: PS16-01-BF1-P-100 Lab ID: 70153670015 Collected: 11/13/20 06:22 Received: 11/17/20 10:45 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.1	ug/L	1.0	1		11/19/20 12:04	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153670

Sample: PS16-01-DW-P-101		Lab ID: 70153670016		Collected: 11/13/20 06:21	Received: 11/17/20 10:45	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/19/20 12:05	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153670

Sample: PS16-01-DW-P-102		Lab ID: 70153670017		Collected: 11/13/20 06:25	Received: 11/17/20 10:45	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	18.0	ug/L	1.0	1		11/19/20 12:06	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153670

Sample: PS16-01-BF-P-103		Lab ID: 70153670018	Collected: 11/13/20 06:24	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.7	ug/L	1.0	1		11/19/20 12:07	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153670

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: PS16-01-BF-P-104 Lab ID: 70153670019 Collected: 11/13/20 06:26 Received: 11/17/20 10:45 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/20 12:08	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153670

Sample: PS16-01-BF-P-105		Lab ID: 70153670020	Collected: 11/13/20 06:28	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/19/20 12:10	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153670

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: PS16-01-CF-P-107 Lab ID: 70153670021 Collected: 11/13/20 06:35 Received: 11/17/20 10:45 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	10.3	ug/L	1.0	1		11/19/20 12:12	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153670

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: PS16-02-DW-P-109								
Lab ID: 70153670022								
Collected: 11/13/20 06:17								
Received: 11/17/20 10:45								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		11/19/20 12:14	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153670

Sample: PS16-02-DW-P-110		Lab ID: 70153670023		Collected: 11/13/20 06:10	Received: 11/17/20 10:45	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		11/19/20 12:15	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153670

Sample: PS16-02-DW-P-111		Lab ID: 70153670024		Collected: 11/13/20 06:11	Received: 11/17/20 10:45	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.2	ug/L	1.0	1		11/19/20 12:16	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153670

Sample: PS16-02-DW-P-112		Lab ID: 70153670025	Collected: 11/13/20 06:11	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/19/20 12:17	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153670

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: PS16-02-DW-P-113 Lab ID: 70153670026 Collected: 11/13/20 06:13 Received: 11/17/20 10:45 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/20 12:18	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153670

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: PS16-02-DW-P-114								
Lab ID: 70153670027								
Collected: 11/13/20 06:14								
Received: 11/17/20 10:45								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	5.8	ug/L	1.0	1		11/19/20 12:19	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153670

Sample: PS16-01-DW-P-104A		Lab ID: 70153670028	Collected: 11/13/20 06:30	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	17.9	ug/L	1.0	1		11/19/20 12:22	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153670

QC Batch:	186447	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70153670001, 70153670002, 70153670003, 70153670004, 70153670005, 70153670006, 70153670007, 70153670008, 70153670009, 70153670010

METHOD BLANK:	913480	Matrix:	Water
---------------	--------	---------	-------

Associated Lab Samples: 70153670001, 70153670002, 70153670003, 70153670004, 70153670005, 70153670006, 70153670007, 70153670008, 70153670009, 70153670010

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/19/20 11:25	

LABORATORY CONTROL SAMPLE:		913481				
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	53.6	107	85-115	

MATRIX SPIKE SAMPLE:		913484					
Parameter	Units	70153810001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.3	4	6.2	123	70-130	

MATRIX SPIKE SAMPLE:		913486					
Parameter	Units	70153670001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	5.7	4	10.4	119	70-130	

SAMPLE DUPLICATE:		913483				
Parameter	Units	70153810001 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	1.3	1.3	1		

SAMPLE DUPLICATE:		913485				
Parameter	Units	70153670001 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	5.7	5.6	0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: ENLARGED CITY SCHOOL DISTRICT
Pace Project No.: 70153670

QC Batch:	186448	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70153670011, 70153670012, 70153670013, 70153670014, 70153670015, 70153670016, 70153670017, 70153670018, 70153670019, 70153670020, 70153670021, 70153670022, 70153670023, 70153670024, 70153670025, 70153670026, 70153670027, 70153670028

METHOD BLANK: 913487 Matrix: Water
Associated Lab Samples: 70153670011, 70153670012, 70153670013, 70153670014, 70153670015, 70153670016, 70153670017, 70153670018, 70153670019, 70153670020, 70153670021, 70153670022, 70153670023, 70153670024, 70153670025, 70153670026, 70153670027, 70153670028

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/19/20 11:54	

LABORATORY CONTROL SAMPLE: 913488

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.8	106	85-115	

MATRIX SPIKE SAMPLE: 913490

Parameter	Units	70153670011 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	5.2	4	9.4	106	70-130	

MATRIX SPIKE SAMPLE: 913492

Parameter	Units	70153670021 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	10.3	4	14.7	110	70-130	

SAMPLE DUPLICATE: 913489

Parameter	Units	70153670011 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	5.2	5.0	3	

SAMPLE DUPLICATE: 913491

Parameter	Units	70153670021 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	10.3	10.2	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153670

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: ENLARGED CITY SCHOOL DISTRICT
Pace Project No.: 70153670

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70153670001	PS16-B-CS-P-82	EPA 200.8	186447		
70153670002	PS16-B-CF-P-84	EPA 200.8	186447		
70153670003	PS16-B-DW-P-86	EPA 200.8	186447		
70153670004	PS16-B-BF-P-87	EPA 200.8	186447		
70153670005	PS16-01-BF1-P-89	EPA 200.8	186447		
70153670006	PS16-01-BF2-P-90	EPA 200.8	186447		
70153670007	PS16-01-FS-P-91	EPA 200.8	186447		
70153670008	PS16-01-BF-P-92	EPA 200.8	186447		
70153670009	PS16-01-DW-P-93	EPA 200.8	186447		
70153670010	PS16-01-CF-P-94	EPA 200.8	186447		
70153670011	PS16-01-NS1-P-95	EPA 200.8	186448		
70153670012	PS16-01-BF-P-96	EPA 200.8	186448		
70153670013	PS16-01-BF-P-98	EPA 200.8	186448		
70153670014	PS16-01-BF2-P-99	EPA 200.8	186448		
70153670015	PS16-01-BF1-P-100	EPA 200.8	186448		
70153670016	PS16-01-DW-P-101	EPA 200.8	186448		
70153670017	PS16-01-DW-P-102	EPA 200.8	186448		
70153670018	PS16-01-BF-P-103	EPA 200.8	186448		
70153670019	PS16-01-BF-P-104	EPA 200.8	186448		
70153670020	PS16-01-BF-P-105	EPA 200.8	186448		
70153670021	PS16-01-CF-P-107	EPA 200.8	186448		
70153670022	PS16-02-DW-P-109	EPA 200.8	186448		
70153670023	PS16-02-DW-P-110	EPA 200.8	186448		
70153670024	PS16-02-DW-P-111	EPA 200.8	186448		
70153670025	PS16-02-DW-P-112	EPA 200.8	186448		
70153670026	PS16-02-DW-P-113	EPA 200.8	186448		
70153670027	PS16-02-DW-P-114	EPA 200.8	186448		
70153670028	PS16-01-DW-P-104A	EPA 200.8	186448		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

Appendix D

Page 1 of 2

CLIENT INFORMATION

Name: Enlarged City School District of Troy
 Address: 475 First Street Troy NY 12180
 Client Rep: Bob Garland

Date of Sampling: 11/13/2020
 Samples Taken By: Tracey Catalfamo
 Samples Taken By: Mike Bulmer

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME: PS 16
 BLDG ADDRESS: 40 Collins Avenue Troy, NY 12180
 CONTACT NAME & NUMBERS: Bob Garland 518-328-5426

(1) Yr. Built: 1951 (2) Yr 1st Add: 1953 (3) Yr 2nd Add: (4) Yr 1st Mod: (5) Yr 2nd Mod:



SAMPLE DATA

Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	30 Second Flush Draw	Time of Collection (24hr)	Service Connection Draw	Time of Collection (24hr)	Water Main Draw	Time of Collection (24hr)
82	PS16-B-CS-P-82	008 custodian office	Sink		1951	X	5:45						
83	PS16-01-ME-P-83	Boiler Rm	Sink		1951	X	Removed						
84	PS16-B-CF-P-84	023 Music	Sink		1951	X	5:47						
85	PS16-B-HC-P-85	Outside storage room	Hose connection		1951	X	Off due to COVID 19						
86	PS16-B-DW-P-86	Boys locker room	Water fountain		1951	X	5:41						
87	PS16-B-BF-P-87	Girls locker room	Sink 1		1951	X	5:52						
89	PS16-01-BF1-P-89	Girls room	Sink 1		1953	X	6:08						
90	PS16-01-BF2-P-90	Girls room	Sink 2		1953	X	6:08						
91	PS16-01-FS-P-91	Faculty lounge	Sink		1953	X	6:02						
92	PS16-01-BF-P-92	Faculty lounge bathroom	Sink		1953	X	6:03						
93	PS16-01-DW-P-93	Library corridor	Water fountain		1953	X	6:04						
94	PS16-01-CF-P-94	Counseling office	Sink		1953	X	6:06						
95	PS16-01-NS1-P-95	Nurse office	Sink 1		1951	X	5:59						
96	PS16-01-BF-P-96	Copy room bathroom	Sink		1951	X	5:55						
97	PS16-01-DW-P-97	Gym	Water Fountain		1951	X	Off due to COVID 19						

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By: [Signature] Received By: [Signature] Date: 11/13/20
 Time: 8:55
 Date: 10:45
 Time: 11:17/20

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (pb)

Lab: [Blank]
 Contact: [Blank]
 Comments: Provide Laboratory Data Report (LDR) and Chain of Custody

CLIENT INFORMATION

Name: Enlarged City School District of Troy
Address: 475 First Street Troy NY 12180
Client Rep: Bob Garland
SCHOOL/PROJECT INFORMATION
BLDG NO./NAME: PS 16
BLDG ADDRESS: 40 Collins Avenue Troy, NY 12180
CONTACT NAME & NUMBERS: Bob Garland 518-328-5426
(1) Yr. Built (2) Yr. 1st Add: 1951
(3) Yr. 2nd Add: (4) Yr. 1st Mod:
(5) Yr. 2nd Mod:

Date of Sampling: 11/13/2020
Samples Taken By: Tracey Catalfamo
Samples Taken By: Mike Bulmer

SAMPLE DATA

Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	30 Second Flush Draw	Time of Collection (24hr)	Service Connection Draw	Time of Collection (24hr)	Water Main Draw	Time of Collection (24hr)
98	PS16-01-BF-P-98	Principal bathroom	Sink		1951	X	5:58						
99	PS16-01-BF2-P-99	Girls room	Sink 1		1951	X	6:20						
100	PS16-01-BF1-P-100	Boys room	Sink 1		1951	X	6:22						
101	PS16-01-DW-P-101	Corridor by 106	Water fountain		1951	X	6:21						
102	PS16-01-DW-P-102	105	Water fountain		1951	X	6:25						
103	PS16-01-BF-P-103	105	Sink		1951	X	6:24						
104	PS16-01-BF-P-104	Rm 105	Sink		1951	X	6:26						
105	PS16-01-BF-P-105	Staff bathroom	Sink		1951	X	6:28						
106	PS16-01-DW-P-106	104	Water fountain		1951	X	Off due to COVID 19						
107	PS16-01-CF-P-107	104	Sink		1951	X	6:35						
108	PS16-01-BF-P-108	104	Sink		1951	X	Not Working, No Test						
109	PS16-02-DW-P-109	Corridor by 212	Water fountain		1951	X	6:17						
110	PS16-02-DW-P-110	Kitchen	Sink 1		1953	X	6:10						
111	PS16-02-DW-P-111	Kitchen	Sink 2		1953	X	6:11						
112	PS16-02-DW-P-112	Kitchen	Sink 3		1953	X	6:11						
113	PS16-02-DW-P-113	214	Sink		1953	X	6:13						
114	PS16-02-DW-P-114	Corridor by 217	Water fountain		1953	X	6:14						
104A	PS16-01-DW-P-104A	Corridor by 105	Water fountain			X	6:30						

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:
<i>Tracey Catalfamo</i>	<i>[Signature]</i>	8:55	11/13/20
		10:45	11/13/20

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab:	
Contact:	
Comments:	Provide Laboratory Data Report (LDR) and Chain of Custody



Sample Condition Upon Receipt

WO# : 70153670
PM: NML Due Date: 12/03/20
CLIENT: QUESTAR

Client Name: QUESTAR

Courier: Fed Ex UPS USPS Client Commercial Pace Other

Tracking #: 9099 9901 1308

Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No

Packing Material: Bubble Wrap Bubble Bags Ziploc None Other

Thermometer Used: TH091 Correction Factor: -0.2
Cooler Temperature (°C): 21.6 Cooler Temperature Corrected (°C): 21.4

Temperature Blank Present: Yes No

Type of Ice: Wet Blue None

Samples on ice, cooling process has begun

Date/Time 5035A kits placed in freezer

Temp should be above freezing to 6.0°C

USDA Regulated Soil (N/A, water sample)

Date and Initials of person examining contents: WJ 11/17/20

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? YES NO

Did samples originate from a foreign source (internationally, including Hawaii and Puerto Rico)? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

		COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr):	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Containers Intact:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12.
-Includes date/time/ID/Analysis Matrix SL <u>WT</u> OIL		
All containers needing preservation have been checked	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot # <u>H6904495</u>		Sample #
All containers needing preservation are found to be in compliance with EPA recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH > 9 Sulfide, NaOH > 12 Cyanide)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	Initial when completed: Lot # of added preservative: Date/Time preservative added
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis		
Samples checked for dechlorination:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
KI starch test strips Lot #		
Residual chlorine strips Lot #		
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	15.
Trip Blank Present:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	16.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable):		

Client Notification/ Resolution: _____ Field Data Required? Y / N
 Person Contacted: _____ Date/Time: _____
 Comments/ Resolution: _____

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

Appendix D

Page 1 of 2

CLIENT INFORMATION

Name:	Enlarged City School District of Troy
Address:	475 First Street Troy NY 12180
Client Rep:	Bob Garland

Date of Sampling:	11/13/2020
Samples Taken By:	Tracey Catalfamo
Samples Taken By:	Mike Bulmer

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	PS 16
BLDG ADDRESS:	40 Collins Avenue Troy, NY 12180
CONTACT NAME & NUMBERS:	Bob Garland 518-328-5426

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:
1951	1953			

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information						
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Lead test Results ug/L from	Lead test Results ug/L from	Lead test Results ug/L from	Remediation
82	PS16-B-CS-P-82	008 custodian office	Sink		1951	X	5.7			
83	PS16-01-MF-P-83	Boiler Rm	Sink		1951	X	Removed			
84	PS16-B-CF-P-84	023 Music	Sink		1951	X	160			Shut off for repair, Will Re-Test
85	PS16-B-HC-P-85	Outside storage room	Hose connection		1951	X	Off due to COVID 19			
86	PS16-B-DW-P-86	Boys locker room	Water fountain		1951	X	12.5			
87	PS16-B-BF-P-87	Girls locker room	Sink 1		1951	X	448			Shut off for repair , Will Re-Test
89	PS16-01-BF1-P-89	Girls room	Sink 1		1953	X	3.5			
90	PS16-01-BF2-P-90	Girls room	Sink 2		1953	X	2.3			
91	PS16-01-FS-P-91	Faculty lounge	Sink		1953	X	2.9			
92	PS16-01-BF-P-92	Faculty lounge bathroom	Sink		1953	X	<1.0			
93	PS16-01-DW-P-93	Library corridor	Water fountain		1953	X	6.2			
94	PS16-01-CF-P-94	Counseling office	Sink		1953	X	2.1			
95	PS16-01-NS1-P-95	Nurse office	Sink 1		1951	X	5.2			
96	PS16-01-BF-P-96	Copy room bathroom	Sink		1951	X	1.0			
97	PS16-01-DW-P-97	Gym	Water Fountain		1951	X	Off due to COVID 19			

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab:	
Contact:	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	

CLIENT INFORMATION

Name:	Enlarged City School District of Troy
Address:	475 First Street Troy NY 12180
Client Rep:	Bob Garland

Date of Sampling:	11/13/2020
Samples Taken By:	Tracey Catalfamo
Samples Taken By:	Mike Bulmer

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	PS 16
BLDG ADDRESS:	40 Collins Avenue Troy, NY 12180
CONTACT NAME & NUMBERS:	Bob Garland 518-328-5426

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:
1951	1953			

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information						
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Lead test Results ug/L from 11/13/2020	Lead test Results ug/L from	Lead test Results ug/L from	Remediation
98	PS16-01-BF-P-98	Principal bathroom	Sink			X	68.5			Shut off for repair, Will Re-Test
99	PS16-01-BF2-P-99	Girls room	Sink 1		1951	X	1.8			
100	PS16-01-BF1-P-100	Boys room	Sink 1		1951	X	2.1			
101	PS16-01-DW-P-101	Corridor by 106	Water fountain		1951	X	<1.0			
102	PS16-01-DW-P-102	105	Water fountain		1951	X	18.0			Shut off for repair , Will Re-Test
103	PS16-01-BF-P-103	105	Sink		1951	X	7.7			
104	PS16-01-BF-P-104	Rm 105	Sink		1951	X	<1.0			
105	PS16-01-BF-P-105	Staff bathroom	Sink		1951	X	<1.0			
106	PS16-01-DW-P-106	104	Water fountain		1951	X	Off due to COVID 19			
107	PS16-01-CF-P-107	104	Sink		1951	X	10.3			
108	PS16-01-BF-P-108	104	Sink		1951	X	Not Working, No Test			
109	PS16-02-DW-P-109	Corridor by 212	Water fountain		1951	X	<1.0			
110	PS16-02-DW-P-110	Kitchen	Sink 1		1953	X	1.1			
111	PS16-02-DW-P-111	Kitchen	Sink 2		1953	X	2.2			
112	PS16-02-DW-P-112	Kitchen	Sink 3		1953	X	<1.0			
113	PS16-02-DW-P-113	214	Sink		1953	X	<1.0			
114	PS16-02-DW-P-114	Corridor by 217	Water fountain		1953	X	5.8			
104A	PS16-01-DW-P-104A	Corridor by 105	Water fountain			X	17.9			Shut off for repair, Will Re-Test

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab:	
Contact:	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
PS16-B-CS-P-82	11/13/2020 05:45	11/19/2020 11:41	70153670001	Lead	5.7	15	ug/L
PS16-B-CF-P-84	11/13/2020 05:47	11/19/2020 11:44	70153670002	Lead	160	15	ug/L
PS16-B-DW-P-86	11/13/2020 05:41	11/19/2020 11:45	70153670003	Lead	12.5	15	ug/L
PS16-B-BF-P-87	11/13/2020 05:52	11/19/2020 11:47	70153670004	Lead	448	15	ug/L
PS16-01-BF1-P-89	11/13/2020 06:08	11/19/2020 11:49	70153670005	Lead	3.5	15	ug/L
PS16-01-BF2-P-90	11/13/2020 06:08	11/19/2020 11:49	70153670006	Lead	2.3	15	ug/L
PS16-01-FS-P-91	11/13/2020 06:02	11/19/2020 11:50	70153670007	Lead	2.9	15	ug/L
PS16-01-BF-P-92	11/13/2020 06:03	11/19/2020 11:51	70153670008	Lead	<1.0	15	ug/L
PS16-01-DW-P-93	11/13/2020 06:04	11/19/2020 11:52	70153670009	Lead	6.2	15	ug/L
PS16-01-CF-P-94	11/13/2020 06:06	11/19/2020 11:53	70153670010	Lead	2.1	15	ug/L
PS16-01-NS1-P-95	11/13/2020 05:59	11/19/2020 11:56	70153670011	Lead	5.2	15	ug/L
PS16-01-BF-P-96	11/13/2020 05:55	11/19/2020 12:01	70153670012	Lead	1.0	15	ug/L
PS16-01-BF-P-98	11/13/2020 05:58	11/19/2020 12:02	70153670013	Lead	68.5	15	ug/L
PS16-01-BF2-P-99	11/13/2020 06:20	11/19/2020 12:03	70153670014	Lead	1.8	15	ug/L
PS16-01-BF1-P-100	11/13/2020 06:22	11/19/2020 12:04	70153670015	Lead	2.1	15	ug/L
PS16-01-DW-P-101	11/13/2020 06:21	11/19/2020 12:05	70153670016	Lead	<1.0	15	ug/L
PS16-01-DW-P-102	11/13/2020 06:25	11/19/2020 12:06	70153670017	Lead	18.0	15	ug/L
PS16-01-BF-P-103	11/13/2020 06:24	11/19/2020 12:07	70153670018	Lead	7.7	15	ug/L
PS16-01-BF-P-104	11/13/2020 06:26	11/19/2020 12:08	70153670019	Lead	<1.0	15	ug/L
PS16-01-BF-P-105	11/13/2020 06:28	11/19/2020 12:10	70153670020	Lead	<1.0	15	ug/L
PS16-01-CF-P-107	11/13/2020 06:35	11/19/2020 12:12	70153670021	Lead	10.3	15	ug/L
PS16-02-DW-P-109	11/13/2020 06:17	11/19/2020 12:14	70153670022	Lead	<1.0	15	ug/L
PS16-02-DW-P-110	11/13/2020 06:10	11/19/2020 12:15	70153670023	Lead	1.1	15	ug/L
PS16-02-DW-P-111	11/13/2020 06:11	11/19/2020 12:16	70153670024	Lead	2.2	15	ug/L
PS16-02-DW-P-112	11/13/2020 06:11	11/19/2020 12:17	70153670025	Lead	<1.0	15	ug/L
PS16-02-DW-P-113	11/13/2020 06:13	11/19/2020 12:18	70153670026	Lead	<1.0	15	ug/L
PS16-02-DW-P-114	11/13/2020 06:14	11/19/2020 12:19	70153670027	Lead	5.8	15	ug/L
PS16-01-DW-P-104A	11/13/2020 06:30	11/19/2020 12:22	70153670028	Lead	17.9	15	ug/L

NYSDOH Action Level for Lead of 15 ppb