

November 19, 2020

Paul Swieton
Rensselaer-Columbia-Greene Counties and
BOCES
10 Empire State Blvd.
Fl 2
Castleton On Hudson, NY 12033

RE: Project: ENLARGED CITY SCHOOL DISTRICT
Pace Project No.: 70153671

Dear Paul Swieton:

Enclosed are the analytical results for sample(s) received by the laboratory on November 17, 2020. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Nicolette M. Lovari
nicolette.lovari@pacelabs.com
(631)694-3040
Project Manager

Enclosures

cc: Robert Garland, Troy City SD



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Pace Analytical Services Long Island

575 Broad Hollow Rd, Melville, NY 11747

New York Certification #: 10478 Primary Accrediting Body

New Jersey Certification #: NY158

Pennsylvania Certification #: 68-00350

Connecticut Certification #: PH-0435

Maryland Certification #: 208

Rhode Island Certification #: LAO00340

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-01-BF-P-01		Lab ID: 70153671001	Collected: 11/13/20 05:02	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.2	ug/L	1.0	1		11/19/20 12:23	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-01-DW-P-02		Lab ID: 70153671002	Collected: 11/13/20 05:03	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/19/20 12:24	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-01-DW-P-03		Lab ID: 70153671003	Collected: 11/13/20 05:04	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/19/20 12:27	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-01-BF-P-04		Lab ID: 70153671004	Collected: 11/13/20 05:05	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/19/20 12:30	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-01-ERF1-P-05		Lab ID: 70153671005	Collected: 11/13/20 05:05	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.5	ug/L	1.0	1		11/19/20 12:31	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-01-ERF2-P-06		Lab ID: 70153671006	Collected: 11/13/20 05:06	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	96.1	ug/L	1.0	1		11/19/20 12:33	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-01-ERF3-P-07		Lab ID: 70153671007	Collected: 11/13/20 05:06	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.0	ug/L	1.0	1		11/19/20 12:34	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-01-BF-P-08		Lab ID: 70153671008	Collected: 11/13/20 05:08	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		11/19/20 12:35	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-01-CRF-P-09		Lab ID: 70153671009	Collected: 11/13/20 05:09	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/19/20 12:36	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-01-SF-P-11		Lab ID: 70153671010	Collected: 11/13/20 05:12	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	24.7	ug/L	1.0	1		11/19/20 12:37	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-01-BF1-P-12		Lab ID: 70153671011	Collected: 11/13/20 05:13	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/19/20 12:38	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-01-BF2-P-13		Lab ID: 70153671012	Collected: 11/13/20 05:13	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/19/20 12:39	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-01-BF-P-14		Lab ID: 70153671013		Collected: 11/13/20 05:15		Received: 11/17/20 10:45		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	22.6	ug/L	1.0	1		11/19/20 12:40	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-01-DW-P-15		Lab ID: 70153671014		Collected: 11/13/20 05:17	Received: 11/17/20 10:45	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.3	ug/L	1.0	1		11/19/20 12:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-01-SF-P-16		Lab ID: 70153671015	Collected: 11/13/20 05:17	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	9.8	ug/L	1.0	1		11/19/20 12:46	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-01-CF-P-17		Lab ID: 70153671016	Collected: 11/13/20 05:18	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.9	ug/L	1.0	1		11/19/20 12:47	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-01-CF-P-18		Lab ID: 70153671017		Collected: 11/13/20 05:19	Received: 11/17/20 10:45	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	8.8	ug/L	1.0	1		11/19/20 12:48	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-01-CF-P-19		Lab ID: 70153671018		Collected: 11/13/20 05:21	Received: 11/17/20 10:45	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.9	ug/L	1.0	1		11/19/20 12:49	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-01-BF-P-20		Lab ID: 70153671019		Collected: 11/13/20 05:21		Received: 11/17/20 10:45		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.7	ug/L	1.0	1		11/19/20 12:50	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-01-CF-P-22		Lab ID: 70153671020	Collected: 11/13/20 05:22	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	10.9	ug/L	1.0	1		11/19/20 12:51	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-01-CF-P-23		Lab ID: 70153671021	Collected: 11/13/20 05:23	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.9	ug/L	1.0	1		11/19/20 12:52	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-01-CF-P-24		Lab ID: 70153671022	Collected: 11/13/20 05:24	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.6	ug/L	1.0	1		11/19/20 12:53	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-01-BF1-P-25		Lab ID: 70153671023	Collected: 11/13/20 05:24	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/19/20 12:57	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-02-BF1-P-27		Lab ID: 70153671024	Collected: 11/13/20 05:28	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/19/20 13:00	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-02-BF2-P-28		Lab ID: 70153671025	Collected: 11/13/20 05:28	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/19/20 13:01	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-02-CF-P-29		Lab ID: 70153671026	Collected: 11/13/20 05:29	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	6.9	ug/L	1.0	1		11/19/20 13:02	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-02-CF-P-30		Lab ID: 70153671027	Collected: 11/13/20 05:30	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	21.5	ug/L	1.0	1		11/19/20 13:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-02-CF-P-31		Lab ID: 70153671028	Collected: 11/13/20 05:31	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.5	ug/L	1.0	1		11/19/20 13:04	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-02-CF-P-32		Lab ID: 70153671029	Collected: 11/13/20 05:31	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.9	ug/L	1.0	1		11/19/20 13:05	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-02-CF-P-33		Lab ID: 70153671030	Collected: 11/13/20 05:32	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.9	ug/L	1.0	1		11/19/20 13:08	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-02-CF-P-34		Lab ID: 70153671031	Collected: 11/13/20 05:32	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/19/20 13:09	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-02-DW-P-35		Lab ID: 70153671032	Collected: 11/13/20 05:33	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/19/20 13:10	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-02-BF-P-36		Lab ID: 70153671033		Collected: 11/13/20 05:34	Received: 11/17/20 10:45	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.9	ug/L	1.0	1		11/19/20 13:11	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-02-BF-P-37		Lab ID: 70153671034	Collected: 11/13/20 05:34	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.5	ug/L	1.0	1		11/19/20 13:14	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-02-CF-P-38		Lab ID: 70153671035		Collected: 11/13/20 05:35		Received: 11/17/20 10:45		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	6.9	ug/L	1.0	1		11/19/20 13:15	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-02-BF1-P-39		Lab ID: 70153671036		Collected: 11/13/20 05:36		Received: 11/17/20 10:45		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.1	ug/L	1.0	1		11/19/20 13:16	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-03-SF-P-41		Lab ID: 70153671037	Collected: 11/13/20 05:38	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	47.8	ug/L	1.0	1		11/19/20 13:17	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-03-CF-P-42		Lab ID: 70153671038	Collected: 11/13/20 05:39	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.6	ug/L	1.0	1		11/19/20 13:19	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-03-DW-P-43		Lab ID: 70153671039		Collected: 11/13/20 05:39		Received: 11/17/20 10:45		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.4	ug/L	1.0	1		11/19/20 13:21	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-03-CF-P-44		Lab ID: 70153671040	Collected: 11/13/20 05:40	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.2	ug/L	1.0	1		11/19/20 13:21	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-03-CF-P-45		Lab ID: 70153671041	Collected: 11/13/20 05:40	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.4	ug/L	1.0	1		11/19/20 13:22	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-03-BF2-P-47		Lab ID: 70153671042	Collected: 11/13/20 05:41	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/19/20 13:23	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-03-CF-P-48		Lab ID: 70153671043	Collected: 11/13/20 05:41	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.7	ug/L	1.0	1		11/19/20 13:26	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-03-CF-P-49		Lab ID: 70153671044	Collected: 11/13/20 05:43	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.8	ug/L	1.0	1		11/19/20 13:31	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-03-BF-P-51		Lab ID: 70153671045		Collected: 11/13/20 05:46		Received: 11/17/20 10:45		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	15.8	ug/L	1.0	1		11/19/20 13:32	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-03-BF-P-52		Lab ID: 70153671046		Collected: 11/13/20 05:46		Received: 11/17/20 10:45		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.4	ug/L	1.0	1		11/19/20 13:33	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-03-BF1-P-53		Lab ID: 70153671047	Collected: 11/13/20 05:47	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/19/20 13:34	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-03-BF2-P-54		Lab ID: 70153671048	Collected: 11/13/20 05:47	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/19/20 13:35	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-03-NS-P-55		Lab ID: 70153671049		Collected: 11/13/20 05:49		Received: 11/17/20 10:45		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.7	ug/L	1.0	1		11/19/20 13:36	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-03-NBF-P-56		Lab ID: 70153671050	Collected: 11/13/20 05:49	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	40.7	ug/L	1.0	1		11/19/20 13:37	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-03-BF-P-57		Lab ID: 70153671051	Collected: 11/13/20 05:51	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.7	ug/L	1.0	1		11/19/20 13:38	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-03-KS1-P-58		Lab ID: 70153671052	Collected: 11/13/20 05:52	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.3	ug/L	1.0	1		11/19/20 13:39	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-03-KS2-P-59		Lab ID: 70153671053	Collected: 11/13/20 05:53	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.7	ug/L	1.0	1		11/19/20 13:40	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-03-BF-P-60		Lab ID: 70153671054	Collected: 11/13/20 05:55	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.6	ug/L	1.0	1		11/19/20 13:44	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-03-DW-P-61		Lab ID: 70153671055	Collected: 11/13/20 05:56	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/19/20 13:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-03-CF-P-62		Lab ID: 70153671056		Collected: 11/13/20 05:57		Received: 11/17/20 10:45		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	6.5	ug/L	1.0	1		11/19/20 13:46	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-03-DW-P-63		Lab ID: 70153671057		Collected: 11/13/20 05:57		Received: 11/17/20 10:45		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	8.6	ug/L	1.0	1		11/19/20 13:47	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-03-BF-P-64		Lab ID: 70153671058	Collected: 11/13/20 05:59	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.1	ug/L	1.0	1		11/19/20 13:48	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-03-BF-P-65		Lab ID: 70153671059	Collected: 11/13/20 05:59	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.9	ug/L	1.0	1		11/19/20 13:49	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-03-CF-P-66		Lab ID: 70153671060	Collected: 11/13/20 06:00	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.5	ug/L	1.0	1		11/19/20 13:50	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-03-CF-P-68		Lab ID: 70153671061	Collected: 11/13/20 06:01	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.6	ug/L	1.0	1		11/19/20 13:51	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-03-DW-P-69		Lab ID: 70153671062	Collected: 11/13/20 06:01	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		11/19/20 13:54	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-03-CF-P-70		Lab ID: 70153671063	Collected: 11/13/20 06:03	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.0	ug/L	1.0	1		11/19/20 13:57	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-03-DW-P-71		Lab ID: 70153671064	Collected: 11/13/20 06:03	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	19.1	ug/L	1.0	1		11/19/20 14:00	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-04-DW-P-72		Lab ID: 70153671065	Collected: 11/13/20 06:08	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		11/19/20 14:01	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-04-CF-P-73		Lab ID: 70153671066	Collected: 11/13/20 06:08	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.6	ug/L	1.0	1		11/19/20 14:02	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-04-DW-P-74		Lab ID: 70153671067	Collected: 11/13/20 06:08	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.2	ug/L	1.0	1		11/19/20 14:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-04-BF-P-75		Lab ID: 70153671068		Collected: 11/13/20 06:10		Received: 11/17/20 10:45		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/19/20 14:06	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-04-CF-P-76		Lab ID: 70153671069		Collected: 11/13/20 06:10		Received: 11/17/20 10:45		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.8	ug/L	1.0	1		11/19/20 14:07	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-04-DW-P-77		Lab ID: 70153671070	Collected: 11/13/20 06:10	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.7	ug/L	1.0	1		11/19/20 14:08	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-04-CF-P-78		Lab ID: 70153671071	Collected: 11/13/20 06:14	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.5	ug/L	1.0	1		11/19/20 14:08	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-04-DW-P-79		Lab ID: 70153671072	Collected: 11/13/20 06:14	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	9.1	ug/L	1.0	1		11/19/20 14:09	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-04-CF-P-80		Lab ID: 70153671073	Collected: 11/13/20 06:15	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	8.5	ug/L	1.0	1		11/19/20 14:10	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Sample: PS2-04-DW-P-81		Lab ID: 70153671074	Collected: 11/13/20 06:15	Received: 11/17/20 10:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.0	ug/L	1.0	1		11/19/20 14:13	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: ENLARGED CITY SCHOOL DISTRICT
Pace Project No.: 70153671

QC Batch: 186448	Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8	Analysis Description: 200.8 MET No Prep Drinking Water
	Laboratory: Pace Analytical Services - Melville

Associated Lab Samples: 70153671001, 70153671002

METHOD BLANK: 913487 Matrix: Water

Associated Lab Samples: 70153671001, 70153671002

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/19/20 11:54	

LABORATORY CONTROL SAMPLE: 913488

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.8	106	85-115	

MATRIX SPIKE SAMPLE: 913490

Parameter	Units	70153670011 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	5.2	4	9.4	106	70-130	

MATRIX SPIKE SAMPLE: 913492

Parameter	Units	70153670021 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	10.3	4	14.7	110	70-130	

SAMPLE DUPLICATE: 913489

Parameter	Units	70153670011 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	5.2	5.0	3	

SAMPLE DUPLICATE: 913491

Parameter	Units	70153670021 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	10.3	10.2	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

QC Batch:	186449	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70153671003, 70153671004, 70153671005, 70153671006, 70153671007, 70153671008, 70153671009, 70153671010, 70153671011, 70153671012, 70153671013, 70153671014, 70153671015, 70153671016, 70153671017, 70153671018, 70153671019, 70153671020, 70153671021, 70153671022		

METHOD BLANK:	913493	Matrix:	Water
Associated Lab Samples:	70153671003, 70153671004, 70153671005, 70153671006, 70153671007, 70153671008, 70153671009, 70153671010, 70153671011, 70153671012, 70153671013, 70153671014, 70153671015, 70153671016, 70153671017, 70153671018, 70153671019, 70153671020, 70153671021, 70153671022		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/19/20 12:25	

LABORATORY CONTROL SAMPLE:	913494					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	54.2	108	85-115	

MATRIX SPIKE SAMPLE:	913496						
Parameter	Units	70153671003 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	4	4.9	118	70-130	

MATRIX SPIKE SAMPLE:	913498						
Parameter	Units	70153671013 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	22.6	4	26.4	96	70-130	

SAMPLE DUPLICATE: 913495					
		70153671003	Dup		
Parameter	Units	Result	Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 913497

Parameter	Units	70153671013 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	22.6	22.3	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

QC Batch:	186450	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70153671023, 70153671024, 70153671025, 70153671026, 70153671027, 70153671028, 70153671029, 70153671030, 70153671031, 70153671032, 70153671033, 70153671034, 70153671035, 70153671036, 70153671037, 70153671038, 70153671039, 70153671040, 70153671041, 70153671042		

METHOD BLANK:	913499	Matrix:	Water
Associated Lab Samples:	70153671023, 70153671024, 70153671025, 70153671026, 70153671027, 70153671028, 70153671029, 70153671030, 70153671031, 70153671032, 70153671033, 70153671034, 70153671035, 70153671036, 70153671037, 70153671038, 70153671039, 70153671040, 70153671041, 70153671042		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/19/20 12:54	

LABORATORY CONTROL SAMPLE:	913500					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	53.7	107	85-115	

MATRIX SPIKE SAMPLE:		913502					
		70153671023	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	4	5.5	115	70-130	

MATRIX SPIKE SAMPLE:		913504					
		70153671033	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	4.9	4	9.7	121	70-130	

SAMPLE DUPLICATE: 913501					
		70153671023	Dup		
Parameter	Units	Result	Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 913503					
		70153671033	Dup		
Parameter	Units	Result	Result	RPD	Qualifiers
Lead	ug/L	4.9	5.0	2	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

QC Batch:	186451	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70153671043, 70153671044, 70153671045, 70153671046, 70153671047, 70153671048, 70153671049, 70153671050, 70153671051, 70153671052, 70153671053, 70153671054, 70153671055, 70153671056, 70153671057, 70153671058, 70153671059, 70153671060, 70153671061, 70153671062		

METHOD BLANK: 913505

Matrix: Water

Associated Lab Samples: 70153671043, 70153671044, 70153671045, 70153671046, 70153671047, 70153671048, 70153671049, 70153671050, 70153671051, 70153671052, 70153671053, 70153671054, 70153671055, 70153671056, 70153671057, 70153671058, 70153671059, 70153671060, 70153671061, 70153671062

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/19/20 13:24	

LABORATORY CONTROL SAMPLE: 913506

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	53.6	107	85-115	

MATRIX SPIKE SAMPLE: 913508

Parameter	Units	70153671043 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	4.7	4	9.4	117	70-130	

MATRIX SPIKE SAMPLE: 913510

Parameter	Units	70153671053 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.7	4	6.5	121	70-130	

SAMPLE DUPLICATE: 913507

Parameter	Units	70153671043 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	4.7	4.6	2	

SAMPLE DUPLICATE: 913509

Parameter	Units	70153671053 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.7	1.7	2	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

QC Batch:	186452	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70153671063, 70153671064, 70153671065, 70153671066, 70153671067, 70153671068, 70153671069, 70153671070, 70153671071, 70153671072, 70153671073, 70153671074		

METHOD BLANK: 913511

Matrix: Water

Associated Lab Samples: 70153671063, 70153671064, 70153671065, 70153671066, 70153671067, 70153671068, 70153671069, 70153671070, 70153671071, 70153671072, 70153671073, 70153671074

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/19/20 13:55	

LABORATORY CONTROL SAMPLE: 913512

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	54.6	109	85-115	

MATRIX SPIKE SAMPLE: 913514

Parameter	Units	70153671063 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	4.0	4	8.8	119	70-130	

MATRIX SPIKE SAMPLE: 913516

Parameter	Units	70153671073 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	8.5	4	13.1	115	70-130	

SAMPLE DUPLICATE: 913513

Parameter	Units	70153671063 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	4.0	4.0	1	

SAMPLE DUPLICATE: 913515

Parameter	Units	70153671073 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	8.5	8.5	0	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70153671001	PS2-01-BF-P-01	EPA 200.8	186448		
70153671002	PS2-01-DW-P-02	EPA 200.8	186448		
70153671003	PS2-01-DW-P-03	EPA 200.8	186449		
70153671004	PS2-01-BF-P-04	EPA 200.8	186449		
70153671005	PS2-01-ERF1-P-05	EPA 200.8	186449		
70153671006	PS2-01-ERF2-P-06	EPA 200.8	186449		
70153671007	PS2-01-ERF3-P-07	EPA 200.8	186449		
70153671008	PS2-01-BF-P-08	EPA 200.8	186449		
70153671009	PS2-01-CRF-P-09	EPA 200.8	186449		
70153671010	PS2-01-SF-P-11	EPA 200.8	186449		
70153671011	PS2-01-BF1-P-12	EPA 200.8	186449		
70153671012	PS2-01-BF2-P-13	EPA 200.8	186449		
70153671013	PS2-01-BF-P-14	EPA 200.8	186449		
70153671014	PS2-01-DW-P-15	EPA 200.8	186449		
70153671015	PS2-01-SF-P-16	EPA 200.8	186449		
70153671016	PS2-01-CF-P-17	EPA 200.8	186449		
70153671017	PS2-01-CF-P-18	EPA 200.8	186449		
70153671018	PS2-01-CF-P-19	EPA 200.8	186449		
70153671019	PS2-01-BF-P-20	EPA 200.8	186449		
70153671020	PS2-01-CF-P-22	EPA 200.8	186449		
70153671021	PS2-01-CF-P-23	EPA 200.8	186449		
70153671022	PS2-01-CF-P-24	EPA 200.8	186449		
70153671023	PS2-01-BF1-P-25	EPA 200.8	186450		
70153671024	PS2-02-BF1-P-27	EPA 200.8	186450		
70153671025	PS2-02-BF2-P-28	EPA 200.8	186450		
70153671026	PS2-02-CF-P-29	EPA 200.8	186450		
70153671027	PS2-02-CF-P-30	EPA 200.8	186450		
70153671028	PS2-02-CF-P-31	EPA 200.8	186450		
70153671029	PS2-02-CF-P-32	EPA 200.8	186450		
70153671030	PS2-02-CF-P-33	EPA 200.8	186450		
70153671031	PS2-02-CF-P-34	EPA 200.8	186450		
70153671032	PS2-02-DW-P-35	EPA 200.8	186450		
70153671033	PS2-02-BF-P-36	EPA 200.8	186450		
70153671034	PS2-02-BF-P-37	EPA 200.8	186450		
70153671035	PS2-02-CF-P-38	EPA 200.8	186450		
70153671036	PS2-02-BF1-P-39	EPA 200.8	186450		
70153671037	PS2-03-SF-P-41	EPA 200.8	186450		
70153671038	PS2-03-CF-P-42	EPA 200.8	186450		
70153671039	PS2-03-DW-P-43	EPA 200.8	186450		
70153671040	PS2-03-CF-P-44	EPA 200.8	186450		
70153671041	PS2-03-CF-P-45	EPA 200.8	186450		
70153671042	PS2-03-BF2-P-47	EPA 200.8	186450		
70153671043	PS2-03-CF-P-48	EPA 200.8	186451		
70153671044	PS2-03-CF-P-49	EPA 200.8	186451		
70153671045	PS2-03-BF-P-51	EPA 200.8	186451		
70153671046	PS2-03-BF-P-52	EPA 200.8	186451		
70153671047	PS2-03-BF1-P-53	EPA 200.8	186451		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: ENLARGED CITY SCHOOL DISTRICT

Pace Project No.: 70153671

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70153671048	PS2-03-BF2-P-54	EPA 200.8	186451		
70153671049	PS2-03-NS-P-55	EPA 200.8	186451		
70153671050	PS2-03-NBF-P-56	EPA 200.8	186451		
70153671051	PS2-03-BF-P-57	EPA 200.8	186451		
70153671052	PS2-03-KS1-P-58	EPA 200.8	186451		
70153671053	PS2-03-KS2-P-59	EPA 200.8	186451		
70153671054	PS2-03-BF-P-60	EPA 200.8	186451		
70153671055	PS2-03-DW-P-61	EPA 200.8	186451		
70153671056	PS2-03-CF-P-62	EPA 200.8	186451		
70153671057	PS2-03-DW-P-63	EPA 200.8	186451		
70153671058	PS2-03-BF-P-64	EPA 200.8	186451		
70153671059	PS2-03-BF-P-65	EPA 200.8	186451		
70153671060	PS2-03-CF-P-66	EPA 200.8	186451		
70153671061	PS2-03-CF-P-68	EPA 200.8	186451		
70153671062	PS2-03-DW-P-69	EPA 200.8	186451		
70153671063	PS2-03-CF-P-70	EPA 200.8	186452		
70153671064	PS2-03-DW-P-71	EPA 200.8	186452		
70153671065	PS2-04-DW-P-72	EPA 200.8	186452		
70153671066	PS2-04-CF-P-73	EPA 200.8	186452		
70153671067	PS2-04-DW-P-74	EPA 200.8	186452		
70153671068	PS2-04-BF-P-75	EPA 200.8	186452		
70153671069	PS2-04-CF-P-76	EPA 200.8	186452		
70153671070	PS2-04-DW-P-77	EPA 200.8	186452		
70153671071	PS2-04-CF-P-78	EPA 200.8	186452		
70153671072	PS2-04-DW-P-79	EPA 200.8	186452		
70153671073	PS2-04-CF-P-80	EPA 200.8	186452		
70153671074	PS2-04-DW-P-81	EPA 200.8	186452		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

Appendix D

Page 1 of 4

CLIENT INFORMATION

Name:	Enlarged City School District of Troy
Address:	475 First Street Troy NY 12180
Client Rep:	Bob Garland

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	PS2
BLDG ADDRESS:	470 Tenth Street Troy NY 12180
CONTACT NAME & NUMBERS:	Bob Garland 518-328-5426

Date of Sampling:	11/13/2020
Samples Taken By:	Tim LeVan
Samples Taken By:	Brock Crouch

WO#: 70153671



(1) Yr. Built	(2) Yr. 1st Add:	(3) Yr. 2nd Add:	(4) Yr. 1st Mod:	(5) Yr. 2nd Mod:
1970				

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information									
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	30 Second Flush Draw	Time of Collection (24hr)	Service Connection Draw	Time of Collection (24hr)	Water Main Draw	Time of Collection (24hr)
1	PS2-01-BF-P-01	Main office bathroom	Sink faucet		1970	X	5:02						
2	PS2-01-DW-P-02	Corridor	Water fountain		2018	X	5:03						
3	PS2-01-DW-P-03	Corridor	Water fountain		2018	X	5:04						
4	PS2-01-BF-P-04	Health Suite Bathroom	Sink faucet		2018	X	5:05						
5	PS2-01-ERF1-P-05	Health Suite exam room	Sink faucet		2018	X	5:05						
6	PS2-01-ERF2-P-06	Health Suite exam room	Sink faucet		1970	X	5:06						
7	PS2-01-ERF3-P-07	Health Suite exam room	Sink faucet		1970	X	5:06						
8	PS2-01-BF-P-08	Community Room bathroom	Sink faucet		2018	X	5:08						
9	PS2-01-CRF-P-09	Community Room	Sink faucet		2018	X	5:09						
10	PS2-01-CF-P-10	131 Music	Sink faucet		1970	X	Not working, No Sample						
11	PS2-01-SF-P-11	Break room in Gym	Sink faucet		1970	X	5:09						
12	PS2-01-BF1-P-12	Girls room	Sink faucet 1		1970	X	5:13						
13	PS2-01-BF2-P-13	Girls room	Sink faucet 2		1970	X	5:13						
14	PS2-01-BF-P-14	Ladies room	Sink faucet		1970	X	5:15						
15	PS2-01-DW-P-15	Corridor	Water fountain		1970	X	5:17						
16	PS2-01-SF-P-16	106 Waiting room	Sink faucet		1970	X	5:17						
17	PS2-01-CF-P-17	119	Sink faucet		1970	X	5:18						
18	PS2-01-CF-P-18	107	Sink faucet		1970	X	5:19						
19	PS2-01-CF-P-19	118	Sink faucet		1970	X	5:21						
20	PS2-01-BF-P-20	Mens room	Sink faucet		1970	X	5:21						
21	PS2-01-BF-P-21	Womens room	Sink faucet		1970	X	Mixing Valve, No Sample						
22	PS2-01-CF-P-22	117	Sink faucet		1970	X	5:22						
23	PS2-01-CF-P-23	Library	Sink faucet		1970	X	5:23						
24	PS2-01-CF-P-24	116	Sink faucet		1970	X	5:24						

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:
<i>[Signature]</i>	<i>[Signature]</i>	6:55	11/13/20

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab: PACE Analytical

Page

Contact:

Comments: Provide Laboratory Data Report (LDR) and Chain of Custody

Page

89

CLIENT INFORMATION

Name:	Enlarged City School District of Troy
Address:	475 First Street Troy NY 12180
Client Rep:	Bob Garland

Date of Sampling:	11/13/2020
Samples Taken By:	Tim LeVan
Samples Taken By:	Brock Crouch

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	PS2
BLDG ADDRESS:	470 Tenth Street Troy NY 12180
CONTACT NAME & NUMBERS:	Bob Garland 518-328-5426

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:
1970				

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information									
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	30 Second Flush Draw	Time of Collection (24hr)	Service Connection Draw	Time of Collection (24hr)	Water Main Draw	Time of* Collection (24hr)
25	PS2-01-BF1-P-25	Boys room	Sink faucet		1970	X	5:25						
26	PS2-01-BF2-P-26	Boys room	Sink faucet		1970	X	Cold not working, No Sample						
27	PS2-02-BF1-P-27	Boys room	Sink faucet		1970	X	5:28						
28	PS2-02-BF2-P-28	Boys room	Sink faucet		1970	X	5:28						
29	PS2-02-CF-P-29	209	Sink faucet		1970	X	5:29						
30	PS2-02-CF-P-30	206	Sink faucet		1970	X	5:30						
31	PS2-02-CF-P-31	210	Sink faucet		1970	X	5:31						
32	PS2-02-CF-P-32	205	Sink faucet		1970	X	5:31						
33	PS2-02-CF-P-33	211	Sink faucet		1970	X	5:32						
34	PS2-02-CF-P-34	204	Sink faucet		1970	X	5:32						
35	PS2-02-DW-P-35	Corridor	Water fountain		1970	X	5:33						
36	PS2-02-BF-P-36	Womens room	Sink faucet		1970	X	5:34						
37	PS2-02-BF-P-37	Mens room	Sink faucet		1970	X	5:34						
38	PS2-02-CF-P-38	203	Sink faucet		1970	X	5:35						
39	PS2-02-BF1-P-39	Girls room	Sink faucet 1		1970	X	5:36						
40	PS2-02-BF2-P-40	Girls room	Sink faucet 2		1970	X	Cold not working, No Sample						
41	PS2-03-SF-P-41	303 Office	Sink faucet		1970	X	5:38						
42	PS2-03-CF-P-42	302	Sink faucet		1970	X	5:39						
43	PS2-03-DW-P-43	Corridor	Water fountain		1970	X	5:39						
44	PS2-03-CF-P-44	305	Sink faucet		1970	X	5:40						
45	PS2-03-CF-P-45	306	Sink faucet		1970	X	5:40						
46	PS2-03-BF1-P-46	Boys room	Sink faucet 1		1970	X	Cold not working, No Sample						
47	PS2-03-BF2-P-47	Boys room	Sink faucet 2		1970	X	5:41						
48	PS2-03-CF-P-48	309	Sink faucet		1970	X	5:41						
49	PS2-03-CF-P-49	310	Sink faucet		1970	X	5:43						

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:
<i>Tim LeVan</i>	<i>[Signature]</i>	5:55	11/13/20
<i>Bob Garland</i>	<i>[Signature]</i>	11:17	10/15

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab: PACE Analytical

Lab: 80

Contact:

Comments: Provide Laboratory Data Report (LDR) and Chain of Custody

CLIENT INFORMATION

Name:	Enlarged City School District of Troy
Address:	475 First Street Troy NY 12180
Client Rep:	Bob Garland
SCHOOL/PROJECT INFORMATION	
BLDG NO./NAME:	PS2
BLDG ADDRESS:	470 Tenth Street Troy NY 12180
CONTACT NAME & NUMBERS:	Bob Garland 518-328-5426

Date of Sampling:	11/13/2020
Samples Taken By:	Tim LeVan
Samples Taken By:	Brock Crouch

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr 2nd Mod:
1970				

SAMPLE DATA

Sample Description ID (ID must match container label)													
Outlet Information													
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	30 Second Flush Draw	Time of Collection (24hr)	Service Connection Draw	Time of Collection (24hr)	Water Main Draw	Time of Collection (24hr)
50	PS2-03-CF-P-50	311	Sink faucet		1970	X	Cold not working, No Test						
51	PS2-03-BF-P-51	Mens room	Sink faucet		1970	X	5:46						
52	PS2-03-BF-P-52	Womens room	Sink faucet		1970	X	5:46						
53	PS2-03-BF1-P-53	Girls room	Sink faucet 1		1970	X	5:47						
54	PS2-03-BF2-P-54	Girls room	Sink faucet 2		1970	X	5:47						
55	PS2-03-NS-P-55	318 Nurse	Sink faucet		1970	X	5:49						
56	PS2-03-NBF-P-56	Nurse Bathroom	Sink faucet		1970	X	5:49						
57	PS2-03-BF-P-57	Womens room	Sink faucet		1970	X	5:51						
58	PS2-03-KS1-P-58	Cafeteria serving	Sink faucet 1		1970	X	5:52						
59	PS2-03-KS2-P-59	Cafeteria serving	Sink faucet 2		1970	X	5:53						
60	PS2-03-BF-P-60	Mens room	Sink faucet		1970	X	5:55						
61	PS2-03-DW-P-61	Corridor	Water fountain		1970	X	5:56						
62	PS2-03-CF-P-62	330	Sink faucet		1970	X	5:57						
63	PS2-03-DW-P-63	330	Water fountain		1970	X	5:57						
64	PS2-03-BF-P-64	Womens room	Sink faucet		1970	X	5:59						
65	PS2-03-BF-P-65	Mens room	Sink faucet		1970	X	5:59						
66	PS2-03-CF-P-66	333	Sink faucet		1970	X	6:00						
67	PS2-03-DW-P-67	333	Water fountain		1970	X	Off due to COVID 19						
68	PS2-03-CF-P-68	334	Sink faucet		1970	X	6:01						
69	PS2-03-DW-P-69	334	Water fountain		1970	X	6:01						
70	PS2-03-CF-P-70	336	Sink faucet		1970	X	6:03						
71	PS2-03-DW-P-71	336	Water fountain		1970	X	6:03						
72	PS2-04-DW-P-72	Corridor by 404	Water fountain		1970	X	6:08						
73	PS2-04-CF-P-73	404	Sink faucet		1970	X	6:08						
74	PS2-04-DW-P-74	404	Water fountain		1970	X	6:08						

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:
Tim LeVan	Bob Garland	8:55	11/13/20
Bob Garland	Bob Garland	10:45	11/13/20

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab: PACE Analytical

Page 87

Contact:

Comments: Provide Laboratory Data Report (LDR) and Chain of Custody

Date of Sampling: 11/13/2020
Samples Taken By: Tim LeVan
Samples Taken By: Brock Crouch

TRADING NO./NAME:

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:
1970				

Sample	Description	ID	ID must match container label
1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

Relinquished By:	Received By:	Time:	Date:
<i>[Signature]</i>	<i>[Signature]</i>	8:35	11/13/20
<i>[Signature]</i>	<i>[Signature]</i>	10:45	11/13/20

Lab: PACE Analytical

88

Contact:

Comments: Provide Laboratory Data Report (LDR) and Chain of Custody



Sample Condition Upon Receipt

WO#: 70153671

Client Name:

Pr

PM: NML

Due Date: 12/03/20

CLIENT: QUESTAR

Courier: ☒ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ Other

Tracking #: 9019 9901 1308

Custody Seal on Cooler/Box Present: ☐ Yes ☒ No Seals intact: ☐ Yes ☒ No

Temperature Blank Present: ☐ Yes ☒ No

Packing Material: ☒ Bubble Wrap ☐ Bubble Bags ☐ Ziploc ☒ None ☐ Other

Type of Ice: Wet Blue ☒ None

Thermometer Used: TH091

Correction Factor: -0.2

☐ Samples on ice, cooling process has begun

Cooler Temperature (°C): 21.6

Cooler Temperature Corrected (°C): 21.4

Date/Time 5035A kits placed in freezer

Temp should be above freezing to 6.0°C

USDA Regulated Soil (☐ N/A, water sample)

Date and Initials of person examining contents: KLB 11/17/20

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? ☐ YES ☒ NO

Did samples originate from a foreign source (internationally, including Hawaii and Puerto Rico)? ☐ Yes ☒ No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

		COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr):	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Containers Intact:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12.
-Includes date/time/ID/Analysis Matrix SL WT OIL		
All containers needing preservation have been checked	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot # HCG04445		Sample #
All containers needing preservation are found to be in compliance with EPA recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH>9 Sulfide, NAOH>12 Cyanide)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water).		
Per Method, VOA pH is checked after analysis		
Samples checked for dechlorination:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14.
KI starch test strips Lot #		
Residual chlorine strips Lot #		Positive for Res. Chlorine? Y N
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	15.
Trip Blank Present:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable):		

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time:

Comments/ Resolution:

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
PS2-01-BF-P-01	11/13/2020 05:02	11/19/2020 12:23	70153671001	Lead	1.2	15	ug/L
PS2-01-DW-P-02	11/13/2020 05:03	11/19/2020 12:24	70153671002	Lead	<1.0	15	ug/L
PS2-01-DW-P-03	11/13/2020 05:04	11/19/2020 12:27	70153671003	Lead	<1.0	15	ug/L
PS2-01-BF-P-04	11/13/2020 05:05	11/19/2020 12:30	70153671004	Lead	<1.0	15	ug/L
PS2-01-ERF1-P-05	11/13/2020 05:05	11/19/2020 12:31	70153671005	Lead	1.5	15	ug/L
PS2-01-ERF2-P-06	11/13/2020 05:06	11/19/2020 12:33	70153671006	Lead	96.1	15	ug/L
PS2-01-ERF3-P-07	11/13/2020 05:06	11/19/2020 12:34	70153671007	Lead	4.0	15	ug/L
PS2-01-BF-P-08	11/13/2020 05:08	11/19/2020 12:35	70153671008	Lead	1.1	15	ug/L
PS2-01-CRF-P-09	11/13/2020 05:09	11/19/2020 12:36	70153671009	Lead	<1.0	15	ug/L
PS2-01-SF-P-11	11/13/2020 05:12	11/19/2020 12:37	70153671010	Lead	24.7	15	ug/L
PS2-01-BF1-P-12	11/13/2020 05:13	11/19/2020 12:38	70153671011	Lead	<1.0	15	ug/L
PS2-01-BF2-P-13	11/13/2020 05:13	11/19/2020 12:39	70153671012	Lead	<1.0	15	ug/L
PS2-01-BF-P-14	11/13/2020 05:15	11/19/2020 12:40	70153671013	Lead	22.6	15	ug/L
PS2-01-DW-P-15	11/13/2020 05:17	11/19/2020 12:45	70153671014	Lead	1.3	15	ug/L
PS2-01-SF-P-16	11/13/2020 05:17	11/19/2020 12:46	70153671015	Lead	9.8	15	ug/L
PS2-01-CF-P-17	11/13/2020 05:18	11/19/2020 12:47	70153671016	Lead	7.9	15	ug/L
PS2-01-CF-P-18	11/13/2020 05:19	11/19/2020 12:48	70153671017	Lead	8.8	15	ug/L
PS2-01-CF-P-19	11/13/2020 05:21	11/19/2020 12:49	70153671018	Lead	5.9	15	ug/L
PS2-01-BF-P-20	11/13/2020 05:21	11/19/2020 12:50	70153671019	Lead	2.7	15	ug/L
PS2-01-CF-P-22	11/13/2020 05:22	11/19/2020 12:51	70153671020	Lead	10.9	15	ug/L
PS2-01-CF-P-23	11/13/2020 05:23	11/19/2020 12:52	70153671021	Lead	4.9	15	ug/L
PS2-01-CF-P-24	11/13/2020 05:24	11/19/2020 12:53	70153671022	Lead	4.6	15	ug/L
PS2-01-BF1-P-25	11/13/2020 05:24	11/19/2020 12:57	70153671023	Lead	<1.0	15	ug/L
PS2-02-BF1-P-27	11/13/2020 05:28	11/19/2020 13:00	70153671024	Lead	<1.0	15	ug/L
PS2-02-BF2-P-28	11/13/2020 05:28	11/19/2020 13:01	70153671025	Lead	<1.0	15	ug/L
PS2-02-CF-P-29	11/13/2020 05:29	11/19/2020 13:02	70153671026	Lead	6.9	15	ug/L
PS2-02-CF-P-30	11/13/2020 05:30	11/19/2020 13:03	70153671027	Lead	21.5	15	ug/L
PS2-02-CF-P-31	11/13/2020 05:31	11/19/2020 13:04	70153671028	Lead	4.5	15	ug/L
PS2-02-CF-P-32	11/13/2020 05:31	11/19/2020 13:05	70153671029	Lead	4.9	15	ug/L
PS2-02-CF-P-33	11/13/2020 05:32	11/19/2020 13:08	70153671030	Lead	4.9	15	ug/L
PS2-02-CF-P-34	11/13/2020 05:32	11/19/2020 13:09	70153671031	Lead	<1.0	15	ug/L
PS2-02-DW-P-35	11/13/2020 05:33	11/19/2020 13:10	70153671032	Lead	<1.0	15	ug/L
PS2-02-BF-P-36	11/13/2020 05:34	11/19/2020 13:11	70153671033	Lead	4.9	15	ug/L
PS2-02-BF-P-37	11/13/2020 05:34	11/19/2020 13:14	70153671034	Lead	1.5	15	ug/L
PS2-02-CF-P-38	11/13/2020 05:35	11/19/2020 13:15	70153671035	Lead	6.9	15	ug/L
PS2-02-BF1-P-39	11/13/2020 05:36	11/19/2020 13:16	70153671036	Lead	1.1	15	ug/L
PS2-03-SF-P-41	11/13/2020 05:38	11/19/2020 13:17	70153671037	Lead	47.8	15	ug/L
PS2-03-CF-P-42	11/13/2020 05:39	11/19/2020 13:19	70153671038	Lead	7.6	15	ug/L
PS2-03-DW-P-43	11/13/2020 05:39	11/19/2020 13:21	70153671039	Lead	1.4	15	ug/L
PS2-03-CF-P-44	11/13/2020 05:40	11/19/2020 13:21	70153671040	Lead	4.2	15	ug/L
PS2-03-CF-P-45	11/13/2020 05:40	11/19/2020 13:22	70153671041	Lead	3.4	15	ug/L
PS2-03-BF2-P-47	11/13/2020 05:41	11/19/2020 13:23	70153671042	Lead	<1.0	15	ug/L
PS2-03-CF-P-48	11/13/2020 05:41	11/19/2020 13:26	70153671043	Lead	4.7	15	ug/L
PS2-03-CF-P-49	11/13/2020 05:43	11/19/2020 13:31	70153671044	Lead	5.8	15	ug/L
PS2-03-BF-P-51	11/13/2020 05:46	11/19/2020 13:32	70153671045	Lead	15.8	15	ug/L
PS2-03-BF-P-52	11/13/2020 05:46	11/19/2020 13:33	70153671046	Lead	1.4	15	ug/L
PS2-03-BF1-P-53	11/13/2020 05:47	11/19/2020 13:34	70153671047	Lead	<1.0	15	ug/L
PS2-03-BF2-P-54	11/13/2020 05:47	11/19/2020 13:35	70153671048	Lead	<1.0	15	ug/L
PS2-03-NS-P-55	11/13/2020 05:49	11/19/2020 13:36	70153671049	Lead	2.7	15	ug/L
PS2-03-NBF-P-56	11/13/2020 05:49	11/19/2020 13:37	70153671050	Lead	40.7	15	ug/L

PS2-03-BF-P-57	11/13/2020 05:51	11/19/2020 13:38	70153671051	Lead	5.7	15	ug/L
PS2-03-KS1-P-58	11/13/2020 05:52	11/19/2020 13:39	70153671052	Lead	1.3	15	ug/L
PS2-03-KS2-P-59	11/13/2020 05:53	11/19/2020 13:40	70153671053	Lead	1.7	15	ug/L
PS2-03-BF-P-60	11/13/2020 05:55	11/19/2020 13:44	70153671054	Lead	3.6	15	ug/L
PS2-03-DW-P-61	11/13/2020 05:56	11/19/2020 13:45	70153671055	Lead	<1.0	15	ug/L
PS2-03-CF-P-62	11/13/2020 05:57	11/19/2020 13:46	70153671056	Lead	6.5	15	ug/L
PS2-03-DW-P-63	11/13/2020 05:57	11/19/2020 13:47	70153671057	Lead	8.6	15	ug/L
PS2-03-BF-P-64	11/13/2020 05:59	11/19/2020 13:48	70153671058	Lead	3.1	15	ug/L
PS2-03-BF-P-65	11/13/2020 05:59	11/19/2020 13:49	70153671059	Lead	5.9	15	ug/L
PS2-03-CF-P-66	11/13/2020 06:00	11/19/2020 13:50	70153671060	Lead	3.5	15	ug/L
PS2-03-CF-P-68	11/13/2020 06:01	11/19/2020 13:51	70153671061	Lead	1.6	15	ug/L
PS2-03-DW-P-69	11/13/2020 06:01	11/19/2020 13:54	70153671062	Lead	1.1	15	ug/L
PS2-03-CF-P-70	11/13/2020 06:03	11/19/2020 13:57	70153671063	Lead	4.0	15	ug/L
PS2-03-DW-P-71	11/13/2020 06:03	11/19/2020 14:00	70153671064	Lead	19.1	15	ug/L
PS2-04-DW-P-72	11/13/2020 06:08	11/19/2020 14:01	70153671065	Lead	1.1	15	ug/L
PS2-04-CF-P-73	11/13/2020 06:08	11/19/2020 14:02	70153671066	Lead	2.6	15	ug/L
PS2-04-DW-P-74	11/13/2020 06:08	11/19/2020 14:03	70153671067	Lead	5.2	15	ug/L
PS2-04-BF-P-75	11/13/2020 06:10	11/19/2020 14:06	70153671068	Lead	<1.0	15	ug/L
PS2-04-CF-P-76	11/13/2020 06:10	11/19/2020 14:07	70153671069	Lead	1.8	15	ug/L
PS2-04-DW-P-77	11/13/2020 06:10	11/19/2020 14:08	70153671070	Lead	4.7	15	ug/L
PS2-04-CF-P-78	11/13/2020 06:14	11/19/2020 14:08	70153671071	Lead	2.5	15	ug/L
PS2-04-DW-P-79	11/13/2020 06:14	11/19/2020 14:09	70153671072	Lead	9.1	15	ug/L
PS2-04-CF-P-80	11/13/2020 06:15	11/19/2020 14:10	70153671073	Lead	8.5	15	ug/L
PS2-04-DW-P-81	11/13/2020 06:15	11/19/2020 14:13	70153671074	Lead	4.0	15	ug/L

NYSDOH Action Level for Lead of 15 ppb

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

Appendix D

Page 1 of 2

CLIENT INFORMATION

Name:	Enlarged City School District of Troy
Address:	475 First Street Troy NY 12180
Client Rep:	Bob Garland

Date of Sampling:	11/13/2020
Samples Taken By:	Tracey Catalfamo
Samples Taken By:	Mike Bulmer

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	PS 16
BLDG ADDRESS:	40 Collins Avenue Troy, NY 12180
CONTACT NAME & NUMBERS:	Bob Garland 518-328-5426

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:
1951	1953			

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information						
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Lead test Results ug/L from	Lead test Results ug/L from	Lead test Results ug/L from	Remediation
82	PS16-B-CS-P-82	008 custodian office	Sink		1951	X	5.7			
83	PS16-01-MF-P-83	Boiler Rm	Sink		1951	X	Removed			
84	PS16-B-CF-P-84	023 Music	Sink		1951	X	160			Shut off for repair, Will Re-Test
85	PS16-B-HC-P-85	Outside storage room	Hose connection		1951	X	Off due to COVID 19			
86	PS16-B-DW-P-86	Boys locker room	Water fountain		1951	X	12.5			
87	PS16-B-BF-P-87	Girls locker room	Sink 1		1951	X	448			Shut off for repair , Will Re-Test
89	PS16-01-BF1-P-89	Girls room	Sink 1		1953	X	3.5			
90	PS16-01-BF2-P-90	Girls room	Sink 2		1953	X	2.3			
91	PS16-01-FS-P-91	Faculty lounge	Sink		1953	X	2.9			
92	PS16-01-BF-P-92	Faculty lounge bathroom	Sink		1953	X	<1.0			
93	PS16-01-DW-P-93	Library corridor	Water fountain		1953	X	6.2			
94	PS16-01-CF-P-94	Counseling office	Sink		1953	X	2.1			
95	PS16-01-NS1-P-95	Nurse office	Sink 1		1951	X	5.2			
96	PS16-01-BF-P-96	Copy room bathroom	Sink		1951	X	1.0			
97	PS16-01-DW-P-97	Gym	Water Fountain		1951	X	Off due to COVID 19			

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab:	
Contact:	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	

CLIENT INFORMATION

Name:	Enlarged City School District of Troy
Address:	475 First Street Troy NY 12180
Client Rep:	Bob Garland

Date of Sampling: 11/13/2020
Samples Taken By: Tracey Catalfamo
Samples Taken By: Mike Bulmer

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	PS 16
BLDG ADDRESS:	40 Collins Avenue Troy, NY 12180
CONTACT NAME & NUMBERS:	Bob Garland 518-328-5426

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:
1951	1953			

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information						
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Lead test Results ug/L from 11/13/2020	Lead test Results ug/L from	Lead test Results ug/L from	Remediation
98	PS16-01-BF-P-98	Principal bathroom	Sink			X	68.5			Shut off for repair, Will Re-Test
99	PS16-01-BF2-P-99	Girls room	Sink 1		1951	X	1.8			
100	PS16-01-BF1-P-100	Boys room	Sink 1		1951	X	2.1			
101	PS16-01-DW-P-101	Corridor by 106	Water fountain		1951	X	<1.0			
102	PS16-01-DW-P-102	105	Water fountain		1951	X	18.0			Shut off for repair , Will Re-Test
103	PS16-01-BF-P-103	105	Sink		1951	X	7.7			
104	PS16-01-BF-P-104	Rm 105	Sink		1951	X	<1.0			
105	PS16-01-BF-P-105	Staff bathroom	Sink		1951	X	<1.0			
106	PS16-01-DW-P-106	104	Water fountain		1951	X	Off due to COVID 19			
107	PS16-01-CF-P-107	104	Sink		1951	X	10.3			
108	PS16-01-BF-P-108	104	Sink		1951	X	Not Working, No Test			
109	PS16-02-DW-P-109	Corridor by 212	Water fountain		1951	X	<1.0			
110	PS16-02-DW-P-110	Kitchen	Sink 1		1953	X	1.1			
111	PS16-02-DW-P-111	Kitchen	Sink 2		1953	X	2.2			
112	PS16-02-DW-P-112	Kitchen	Sink 3		1953	X	<1.0			
113	PS16-02-DW-P-113	214	Sink		1953	X	<1.0			
114	PS16-02-DW-P-114	Corridor by 217	Water fountain		1953	X	5.8			
104A	PS16-01-DW-P-104A	Corridor by 105	Water fountain			X	17.9			Shut off for repair, Will Re-Test

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:
#			

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab:	
Contact:	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	

