

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

Appendix D

CLIENT INFORMATION

Name:	Enlarged City School District of Troy
Address:	475 First Street Troy NY 12180
Client Rep:	Bob Garland

Date of Sampling:	11/4/2020	5/12/2021
Samples Taken By:	Paul Swieton	Tim LeVan
Samples Taken By:	Tracey Catalfam	Dan French

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	PS 18
BLDG ADDRESS:	417 Hoosick Street Troy NY 12180
CONTACT NAME & NUMBERS:	Bob Garland 518-328-5426

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:
1927				

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information						
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Lead test Results ug/L from 11/4/2020	Lead test Results ug/L from 5/12/2021	Lead test Results ug/L from	Remediation
200	PS18-B-BF-P-200	Faculty bathroom/Old boys locker room	Sink			X	4.3			
201	PS18-01-BF1-P-201	Boys room	Sink 1			X	1.2			
202	PS18-01-BF2-P-202	Boys room	Sink 2			X	1.1			
203	PS18-01-BF3-P-203	Boys room	Sink 3			X	2.2			
204	PS18-01-DW-P-204	Corridor	Water fountain			X	1.9			
205	PS18-01-DW-P-205	Corridor	Water fountain			X	Out of Service			Removed
206	PS18-01-KF-P-206	Kitchen	Sink			X	6.0			
207	PS18-B-BF-P-207	Faculty bathroom/Old girls locker room	Sink			X	1.7			
208	PS18-01-BF1-P-208	Girls room	Sink 1			X	1.7			
209	PS18-01-BF2-P-209	Girls room	Sink 2			X	<1.0			
210	PS18-01-BF3-P-210	Girls room	Sink 3			X	<1.0			
211	PS18-02-DW-P-211	Corridor	Water fountain			X	1.3			
212	PS18-02-BF1-P-212	Girls room	Sink1			X	1.4			
213	PS18-02-BF2-P-213	Girls room	Sink 2			X	<1.0			
214	PS18-02-BF3-P-214	Girls room	Sink 3			X				Mixing valve, No Test
215	PS18-02-BF-P-215	219 bathroom	Sink			X	<1.0			
216	PS18-02-BF1-P-216	Boys room	Sink 1			X	1.6			
217	PS18-02-BF2-P-217	Boys room	Sink 2			X	<1.0			
218	PS18-02-BF3-P-218	Boys room	Sink 3			X	<1.0			
219	PS18-02-DW-P-219	Corridor	Water fountain			X	<1.0			
220	PS18-02-BF-P-220	Asst. Principal bathroom	Sink			X	27.5	13.2		
221	PS18-02-BF-P-221	Principal bathroom	Sink			X	4.5			
222	PS18-03-DW-P-222	Corridor	Water fountain			X	<1.0			
223	PS18-03-BF1-P-223	Boys room	Sink 1			X	<1.0			
224	PS18-03-BF2-P-224	Boys room	Sink 2			X	<1.0			

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab: Pace Analytical	
Contact:	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	