

Client Project	Sample ID	Lab ID	Collected Date	Method	Matrix	Parameter	Results	Units	PQL
CARROLL HILL SCHOOL	1-WF	70361209012	06/11/2025 05:43	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
CARROLL HILL SCHOOL	11-WF	70361209008	06/11/2025 05:38	EPA 200.8	Drinking Water	Lead	3.3	ug/L	1.0
CARROLL HILL SCHOOL	12-WF	70361209007	06/11/2025 05:37	EPA 200.8	Drinking Water	Lead	2.4	ug/L	1.0
CARROLL HILL SCHOOL	13-WF	70361209006	06/11/2025 05:35	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
CARROLL HILL SCHOOL	14-WF	70361209005	06/11/2025 05:34	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
CARROLL HILL SCHOOL	15-WF	70361209004	06/11/2025 05:33	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
CARROLL HILL SCHOOL	16-WF	70361209003	06/11/2025 05:32	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
CARROLL HILL SCHOOL	17-WF	70361209002	06/11/2025 05:31	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
CARROLL HILL SCHOOL	18-WF	70361209001	06/11/2025 05:30	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
CARROLL HILL SCHOOL	19-WF	70361209022	06/11/2025 05:54	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
CARROLL HILL SCHOOL	2-WF	70361209013	06/11/2025 05:44	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
CARROLL HILL SCHOOL	20-WF	70361209023	06/11/2025 05:55	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
CARROLL HILL SCHOOL	21-WF	70361209024	06/11/2025 05:56	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
CARROLL HILL SCHOOL	22-WF	70361209025	06/11/2025 05:57	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
CARROLL HILL SCHOOL	23-WF	70361209026	06/11/2025 05:58	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
CARROLL HILL SCHOOL	24-WF	70361209027	06/11/2025 05:59	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
CARROLL HILL SCHOOL	3-WF	70361209014	06/11/2025 05:45	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
CARROLL HILL SCHOOL	4-WF	70361209016	06/11/2025 05:47	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
CARROLL HILL SCHOOL	5-WF	70361209017	06/11/2025 05:48	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
CARROLL HILL SCHOOL	6-WF	70361209020	06/11/2025 05:51	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
CARROLL HILL SCHOOL	7-WF	70361209021	06/11/2025 05:52	EPA 200.8	Drinking Water	Lead	1.1	ug/L	1.0
CARROLL HILL SCHOOL	8-WF	70361209009	06/11/2025 05:40	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
CARROLL HILL SCHOOL	KITCHEN-SINK-1	70361209028	06/11/2025 06:00	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
CARROLL HILL SCHOOL	NURSE-SINK-BATHROOM	70361209019	06/11/2025 05:50	EPA 200.8	Drinking Water	Lead	1.7	ug/L	1.0
CARROLL HILL SCHOOL	NURSE-SINK-OFFICE	70361209018	06/11/2025 05:49	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
CARROLL HILL SCHOOL	OUTSIDE 4-WF	70361209015	06/11/2025 05:46	EPA 200.8	Drinking Water	Lead	2.5	ug/L	1.0
CARROLL HILL SCHOOL	OUTSIDE CAFE-BF	70361209011	06/11/2025 05:42	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
CARROLL HILL SCHOOL	OUTSIDE CAFE-WF	70361209010	06/11/2025 05:41	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
TROY COMMUNITY SHCOC	121B BOTTLE FILLER 1-COMBO	70360851009	06/10/2025 05:38	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
TROY COMMUNITY SHCOC	121B WF 1-COMBO	70360851010	06/10/2025 05:39	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
TROY COMMUNITY SHCOC	121B WF 2	70360851011	06/10/2025 05:40	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
TROY COMMUNITY SHCOC	220 BOTTLE FILLER 1-COMBO	70360851013	06/10/2025 05:42	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
TROY COMMUNITY SHCOC	220 WF 1-COMBO	70360851014	06/10/2025 05:43	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
TROY COMMUNITY SHCOC	220 WF 2	70360851015	06/10/2025 05:44	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
TROY COMMUNITY SHCOC	FL-SINK 1	70360851008	06/10/2025 05:37	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
TROY COMMUNITY SHCOC	GYM BOTTLE FILLER 1-COMBO	70360851001	06/10/2025 05:30	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
TROY COMMUNITY SHCOC	GYM WF 1-COMBO	70360851002	06/10/2025 05:31	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
TROY COMMUNITY SHCOC	GYM WF 2	70360851003	06/10/2025 05:32	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0
TROY COMMUNITY SHCOC	KITCHEN SINK 1	70360851012	06/10/2025 05:41	EPA 200.8	Drinking Water	Lead	<1.0	ug/L	1.0

TROY COMMUNITY SHCOC MAIN LOBBY BF1-COMBO	70360851005	06/10/2025 05:34	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY COMMUNITY SHCOC MAIN LOBBY WF1-COMBO	70360851006	06/10/2025 05:35	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY COMMUNITY SHCOC MAIN LOBBY WF2	70360851007	06/10/2025 05:36	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY COMMUNITY SHCOC NURSE SINK 1	70360851004	06/10/2025 05:33	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL 1ST FLOOR LEFT WF	70360832036	06/11/2025 06:41	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL 1ST FLOOR RIGHT WF	70360832035	06/11/2025 06:40	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL 2ND FLOOR	70360832037	06/11/2025 06:43	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL 2ND FLOOR GIRLS ROOM	70360832040	06/11/2025 06:44	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL CAFE-COMBO-BF	70360832009	06/11/2025 06:29	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL CAFE-COMBO-WF	70360832008	06/11/2025 06:28	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL FACULTY LOUNGE 2ND FLOOR-SINI	70360832019	06/11/2025 06:08	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL FACULTY LOUNGE 3RD FLOOR 305-	70360832024	06/11/2025 06:15	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL ICE MACHINE-1-ATHLETIC	70360832038	06/11/2025 06:33	EPA 200.8 Drinking Water	Lead	1.0	ug/L	1.0
TROY HIGH SCHOOL ICE MACHINE-2-KITCHEN	70360832039	06/11/2025 06:34	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL KITCHEN-SINK-1	70360832010	06/11/2025 06:30	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL KITCHEN-SINK-2	70360832011	06/11/2025 06:31	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL NURSE-SINK-1	70360832005	06/11/2025 06:04	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL OUTSIDE 009-COMBO-BF	70360832002	06/11/2025 06:01	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL OUTSIDE 009-COMBO-WF	70360832001	06/11/2025 06:00	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL OUTSIDE 128-WF	70360832014	06/11/2025 06:07	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL OUTSIDE 151-COMBO-BF	70360832004	06/11/2025 06:03	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL OUTSIDE 151-COMBO-WF	70360832003	06/11/2025 06:02	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL OUTSIDE 211-COMBO-BF	70360832018	06/11/2025 06:10	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL OUTSIDE 211-COMBO-WF	70360832017	06/11/2025 06:09	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL OUTSIDE 223-WF	70360832016	06/11/2025 06:11	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL OUTSIDE 228-WF	70360832015	06/11/2025 06:12	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL OUTSIDE 252-WF	70360832020	06/11/2025 06:13	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL OUTSIDE 256-WF	70360832021	06/11/2025 06:14	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL OUTSIDE 262-WF	70360832022	06/11/2025 06:26	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL OUTSIDE 323-WF	70360832033	06/11/2025 06:24	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL OUTSIDE 332-WF	70360832034	06/11/2025 06:25	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL OUTSIDE 345-COMBO-BF	70360832026	06/11/2025 06:17	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL OUTSIDE 345-COMBO-WF	70360832025	06/11/2025 06:16	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL OUTSIDE 352-WF	70360832023	06/11/2025 06:27	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL OUTSIDE-144-COMBO-BF	70360832013	06/11/2025 06:06	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL OUTSIDE-144-COMBO-WF	70360832012	06/11/2025 06:05	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL OUTSIDE-ATHLETIC OFFICE-BF	70360832007	06/11/2025 06:33	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL OUTSIDE-ATHLETIC OFFICE-WF	70360832006	06/11/2025 06:32	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL SINK-1	70360832027	06/11/2025 06:18	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL SINK-2	70360832028	06/11/2025 06:19	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0

TROY HIGH SCHOOL	SINK-3	70360832029	06/11/2025 06:20	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY HIGH SCHOOL	SINK-4	70360832030	06/11/2025 06:21	EPA 200.8 Drinking Water	Lead	6.9	ug/L	1.0
TROY HIGH SCHOOL	SINK-5	70360832031	06/11/2025 06:22	EPA 200.8 Drinking Water	Lead	2.2	ug/L	1.0
TROY HIGH SCHOOL	SINK-6	70360832032	06/11/2025 06:23	EPA 200.8 Drinking Water	Lead	6.8	ug/L	1.0
TROY MIDDLE SCHOOL	281-SINK-1	70360837008	06/10/2025 07:07	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	281-SINK-2	70360837009	06/10/2025 07:08	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	281-SINK-3	70360837010	06/10/2025 07:09	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	282-SINK-1	70360837005	06/10/2025 07:04	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	282-SINK-2	70360837006	06/10/2025 07:05	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	282-SINK-3	70360837007	06/10/2025 07:06	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	AUDITORIUM 1ST FLOOR LEFT	70360837036	06/10/2025 07:33	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	AUDITORIUM 1ST FLOOR RIGHT	70360837037	06/10/2025 07:34	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	AUDITORIUM 2ND FLOOR	70360837038	06/10/2025 07:35	EPA 200.8 Drinking Water	Lead	1.0	ug/L	1.0
TROY MIDDLE SCHOOL	BOYS LOCKER ROOM BF	70360837029	06/10/2025 07:22	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	BOYS LOCKER ROOM WF 1	70360837027	06/10/2025 07:20	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	BOYS LOCKER ROOM WF 2	70360837028	06/10/2025 07:21	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	GIRLS LOCKER ROOM BF	70360837035	06/10/2025 07:32	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	GIRLS LOCKER ROOM WF 1	70360837033	06/10/2025 07:29	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	GIRLS LOCKER ROOM WF 2	70360837034	06/10/2025 07:31	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	KITCHEN-SINK-1	70360837001	06/10/2025 07:00	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	NURSE-SINK-1	70360837020	06/10/2025 07:25	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	OUTSIDE 154 BF	70360837032	06/10/2025 07:28	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	OUTSIDE 154 WF 1	70360837030	06/10/2025 07:26	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	OUTSIDE 154 WF 2	70360837031	06/10/2025 07:27	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	OUTSIDE 186-BF	70360837026	06/10/2025 07:42	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	OUTSIDE 186-WF-1	70360837024	06/10/2025 07:40	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	OUTSIDE 186-WF-2	70360837025	06/10/2025 07:41	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	OUTSIDE CAFE-BF	70360837004	06/10/2025 07:03	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	OUTSIDE CAFE-WF-1	70360837002	06/10/2025 07:01	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	OUTSIDE CAFE-WF-2	70360837003	06/10/2025 07:02	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	OUTSIDE GYM-BF	70360837013	06/10/2025 07:12	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	OUTSIDE GYM-WF-1	70360837011	06/10/2025 07:10	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	OUTSIDE GYM-WF-2	70360837012	06/10/2025 07:11	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	OUTSIDE MEDIA CENTER 163-BF	70360837023	06/10/2025 07:24	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	OUTSIDE MEDIA CENTER 163-WF-1	70360837021	06/10/2025 07:22	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	OUTSIDE MEDIA CENTER 163-WF-2	70360837022	06/10/2025 07:23	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	OUTSIDE-123-WF-1	70360837018	06/10/2025 07:30	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	OUTSIDE-123-WF-2	70360837019	06/10/2025 07:31	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	OUTSIDE-203-BF	70360837016	06/10/2025 07:15	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	OUTSIDE-203-WF-1	70360837014	06/10/2025 07:13	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0

TROY MIDDLE SCHOOL	OUTSIDE-203-WF-2	70360837015	06/10/2025 07:14	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY MIDDLE SCHOOL	OUTSIDE-222-WF	70360837017	06/10/2025 07:16	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 12	113-WF	70361210021	06/11/2025 06:48	EPA 200.8 Drinking Water	Lead	1.2	ug/L	1.0
TROY SCHOOL 12	114-WF	70361210019	06/11/2025 06:46	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 12	117-WF	70361210017	06/11/2025 06:44	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 12	118-WF	70361210018	06/11/2025 06:45	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 12	119-WF	70361210020	06/11/2025 06:47	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 12	123-SINK	70361210022	06/11/2025 06:49	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 12	1ST FLOOR MAIN ENTRANCE-WF	70361210023	06/11/2025 06:50	EPA 200.8 Drinking Water	Lead	1.4	ug/L	1.0
TROY SCHOOL 12	1ST FLOOR NORTH STAIRS-WF	70361210027	06/11/2025 06:54	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 12	216-WF	70361210008	06/11/2025 06:35	EPA 200.8 Drinking Water	Lead	2.9	ug/L	1.0
TROY SCHOOL 12	217-SINK	70361210010	06/11/2025 06:37	EPA 200.8 Drinking Water	Lead	2.3	ug/L	1.0
TROY SCHOOL 12	218-SINK	70361210011	06/11/2025 06:38	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 12	221-WF	70361210012	06/11/2025 06:39	EPA 200.8 Drinking Water	Lead	5.1	ug/L	1.0
TROY SCHOOL 12	222-WF	70361210009	06/11/2025 06:36	EPA 200.8 Drinking Water	Lead	2.4	ug/L	1.0
TROY SCHOOL 12	223-WF	70361210007	06/11/2025 06:34	EPA 200.8 Drinking Water	Lead	2.6	ug/L	1.0
TROY SCHOOL 12	CAFE-BF	70361210014	06/11/2025 06:41	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 12	CAFE-SINK	70361210015	06/11/2025 06:42	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 12	CAFE-WF	70361210013	06/11/2025 06:40	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 12	FACULTY LOUGE	70361210028	06/11/2025 06:55	EPA 200.8 Drinking Water	Lead	1.0	ug/L	1.0
TROY SCHOOL 12	FACULTY LOUNGE-SINK	70361210003	06/11/2025 06:30	EPA 200.8 Drinking Water	Lead	1.2	ug/L	1.0
TROY SCHOOL 12	FLOOR 2 MAIN STAIRS-BF	70361210006	06/11/2025 06:33	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 12	FLOOR 2 MAIN STAIRS-WF	70361210005	06/11/2025 06:32	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 12	FLOOR 2 NORTY STAIRS-WF	70361210004	06/11/2025 06:31	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 12	FLOOR 3-BF	70361210002	06/11/2025 06:29	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 12	FLOOR 3-WF	70361210001	06/11/2025 06:28	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 12	KITCHEN-SINK-1	70361210016	06/11/2025 06:43	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 12	REGISTRAR-BF	70361210026	06/11/2025 06:53	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 12	REGISTRAR-WF-1	70361210024	06/11/2025 06:51	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 12	REGISTRAR-WF-2	70361210025	06/11/2025 06:52	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	177 FACULTY LOUNGE-WF	70361205015	06/11/2025 06:09	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	GYM-BF	70361205006	06/11/2025 06:00	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	GYM-WF-1	70361205004	06/11/2025 05:58	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	GYM-WF-2	70361205005	06/11/2025 05:59	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	MAINTENANCE SHOP-BF	70361205003	06/11/2025 05:57	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	MAINTENANCE SHOP-WF-1	70361205001	06/11/2025 05:55	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	MAINTENANCE SHOP-WF-2	70361205002	06/11/2025 05:56	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	NURSE EXAM ROOM 1-SINK	70361205010	06/11/2025 06:04	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	NURSE EXAM ROOM 2-SINK	70361205011	06/11/2025 06:05	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	OUTSIDE 211-WF-2	70361205023	06/11/2025 06:17	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0

TROY SCHOOL 14	OUTSIDE 111-BF	70361205021	06/11/2025 06:15	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	OUTSIDE 111-WF-1	70361205019	06/11/2025 06:13	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	OUTSIDE 111-WF-2	70361205020	06/11/2025 06:14	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	OUTSIDE 121-BF	70361205018	06/11/2025 06:12	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	OUTSIDE 121-WF-1	70361205016	06/11/2025 06:10	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	OUTSIDE 121-WF-2	70361205017	06/11/2025 06:11	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	OUTSIDE 131-BF	70361205014	06/11/2025 06:08	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	OUTSIDE 131-WF-1	70361205012	06/11/2025 06:06	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	OUTSIDE 131-WF-2	70361205013	06/11/2025 06:07	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	OUTSIDE 154-BF	70361205009	06/11/2025 06:03	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	OUTSIDE 154-WF-1	70361205007	06/11/2025 06:01	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	OUTSIDE 154-WF-2	70361205008	06/11/2025 06:02	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	OUTSIDE 211-BF	70361205024	06/11/2025 06:18	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	OUTSIDE 211-WF-1	70361205022	06/11/2025 06:16	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	OUTSIDE 221-BF	70361205027	06/11/2025 06:21	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	OUTSIDE 221-WF-1	70361205025	06/11/2025 06:19	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	OUTSIDE 221-WF-2	70361205026	06/11/2025 06:20	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	OUTSIDE 231-BF	70361205030	06/11/2025 06:24	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	OUTSIDE 231-WF-1	70361205028	06/11/2025 06:22	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	OUTSIDE 231-WF-2	70361205029	06/11/2025 06:23	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	OUTSIDE 244-BF	70361205033	06/11/2025 06:27	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	OUTSIDE 244-WF-1	70361205031	06/11/2025 06:25	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 14	OUTSIDE 244-WF-2	70361205032	06/11/2025 06:26	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 16	FACULTY LOUNGE-SINK	70361203005	06/11/2025 05:14	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 16	GYM-BF	70361203010	06/11/2025 05:19	EPA 200.8 Drinking Water	Lead	1.7	ug/L	1.0
TROY SCHOOL 16	GYM-WF	70361203009	06/11/2025 05:18	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 16	KITCHEN-SINK	70361203006	06/11/2025 05:15	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 16	NURSE-SINK	70361203001	06/11/2025 05:10	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 16	OUTSIDE 005-BF	70361203004	06/11/2025 05:13	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 16	OUTSIDE 005-WF-1	70361203002	06/11/2025 05:11	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 16	OUTSIDE 005-WF-2	70361203003	06/11/2025 05:12	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 16	OUTSIDE 111-BF	70361203015	06/11/2025 05:24	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 16	OUTSIDE 111-WF	70361203014	06/11/2025 05:23	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 16	OUTSIDE 205-BF	70361203012	06/11/2025 05:21	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 16	OUTSIDE 205-WF	70361203011	06/11/2025 05:20	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 16	OUTSIDE 309-BF	70361203008	06/11/2025 05:17	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 16	OUTSIDE 309-WF	70361203007	06/11/2025 05:16	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 16	OUTSIDE 405-WF	70361203013	06/11/2025 05:22	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 18	CAF-BF	70361201004	06/10/2025 05:49	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 18	CAFE-WF	70361201003	06/10/2025 05:48	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0

TROY SCHOOL 18	KITCHEN-SINK	70361201005	06/10/2025 05:50	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 18	NURSE-SINK	70361201002	06/10/2025 05:47	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 18	OUTSIDE 108-WF	70361201001	06/10/2025 05:45	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 18	OUTSIDE 207-WF	70361201006	06/10/2025 05:51	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 18	OUTSIDE 306-WF	70361201009	06/10/2025 05:54	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 18	OUTSIDE 307-BF	70361201008	06/10/2025 05:53	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 18	OUTSIDE 307-WF	70361201007	06/10/2025 05:52	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 2	1ST FLOOR NURSE-SINK	70361193003	06/11/2025 06:12	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 2	302 FACULTY LOUNGE-SINK	70361193007	06/11/2025 06:16	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 2	330-WF	70361193010	06/11/2025 06:19	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 2	333-WF	70361193011	06/11/2025 06:20	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 2	334-WF	70361193012	06/11/2025 06:21	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 2	343-WF	70361193013	06/11/2025 06:22	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 2	3RD FLOOR NURSE-SINK	70361193009	06/11/2025 06:18	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 2	404-WF	70361193014	06/11/2025 06:24	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 2	407-WF	70361193015	06/11/2025 06:25	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 2	408-WF	70361193016	06/11/2025 06:26	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 2	410-WF	70361193017	06/11/2025 06:27	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 2	BY ELEVATOR ROOM-BF	70361193005	06/11/2025 06:14	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 2	BY ELEVATOR ROOM-WF	70361193004	06/11/2025 06:13	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 2	OUTSIDE 137D-WF-1	70361193001	06/11/2025 06:10	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 2	OUTSIDE 137D-WF-2	70361193002	06/11/2025 06:11	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 2	OUTSIDE 304- WF	70361193008	06/11/2025 06:17	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 2	OUTSIDE CAFE-WF	70361193018	06/11/2025 06:28	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0
TROY SCHOOL 2	OUTSSIDE 204-WF	70361193006	06/11/2025 06:15	EPA 200.8 Drinking Water	Lead	<1.0	ug/L	1.0

